

NAKUSP, BC, Canada

WMO: 712160

Lat: 50.2694N

Lon: 117.8172W

Elev: 512

StdP: 95.32

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-12.9	-10.3	-17.5	0.9	-11.7	-14.7	1.1	-9.3	5.4	-2.8	4.5	-2.1	2.1	100	0.507

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.2	31.1	18.5	29.1	17.8	27.0	17.0	19.9	28.0	18.8	26.4	17.9	24.9	1.4	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.2	13.1	22.4	16.2	12.2	21.3	15.2	11.5	20.5	59.1	27.9	55.5	26.6	52.4	24.9	24.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
4.8	4.0	3.3	-14.8	34.9	3.2	2.3	-17.1	36.5	-18.9	37.8	-20.7	39.1	-23.0	40.7		
			-15.4	21.6	3.1	1.6	-17.7	22.7	-19.5	23.6	-21.3	24.5	-23.6	25.6		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	8.4	-1.4	-0.4	3.4	7.7	12.8	16.5	19.9	19.0	14.0	7.4	2.4	-1.6
	DBStd	8.28	4.11	3.69	2.99	2.59	3.20	3.04	3.11	2.97	3.07	2.85	3.22	3.86
	HDD10.0	1616	354	291	204	77	10	0	0	0	3	88	229	359
	HDD18.3	3781	613	524	463	318	173	72	21	29	134	338	479	618
	CDD10.0	1016	0	0	0	8	97	194	307	278	124	9	0	0
	CDD18.3	138	0	0	0	0	2	16	68	48	4	0	0	0
	CDH23.3	1534	0	0	0	0	56	213	726	489	51	0	0	0
	CDH26.7	498	0	0	0	0	8	57	272	152	10	0	0	0
Wind	WSAvg	1.3	1.3	1.3	1.3	1.3	1.4	1.4	1.3	1.2	1.2	1.3	1.5	1.5
Precipitation	PrecAvg	832	98	66	55	51	63	82	65	58	64	64	92	98
	PrecMax	1104	168	160	112	108	105	152	147	134	128	162	234	188
	PrecMin	604	18	14	2	14	9	26	8	4	7	11	22	47
	PrecStd	125	43	33	23	22	25	30	38	35	33	37	45	38
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.0	8.1	14.0	20.6	27.7	31.2	34.4	32.6	27.6	17.3	10.3	6.0
		MCWB	4.4	5.2	7.5	11.8	15.2	18.4	19.7	19.3	16.5	12.5	8.5	4.1
	2%	DB	4.3	5.9	11.2	17.4	24.8	28.1	31.9	30.2	24.5	14.9	8.4	4.4
		MCWB	3.4	4.0	6.6	9.9	14.0	16.7	18.9	18.0	15.9	11.3	7.1	3.3
	5%	DB	3.3	4.6	9.2	15.2	22.2	25.7	29.8	28.2	22.2	13.1	7.2	3.4
		MCWB	2.7	3.3	5.5	8.9	13.2	15.9	18.4	17.6	15.2	10.5	6.3	2.6
	10%	DB	2.6	3.5	7.6	13.2	19.8	23.3	27.6	26.1	19.8	11.5	6.2	2.5
		MCWB	2.1	2.5	4.8	8.1	12.3	15.1	17.7	17.0	14.1	9.5	5.5	1.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.0	5.9	8.7	12.5	16.6	19.6	21.6	20.9	18.0	13.7	9.2	5.0
		MCDB	5.8	6.8	11.6	18.7	23.9	28.4	31.3	29.6	24.1	15.5	9.9	5.4
	2%	WB	3.6	4.6	7.3	10.8	15.2	18.1	20.3	19.5	16.6	12.2	7.5	3.7
		MCDB	4.0	5.4	9.7	15.7	22.1	25.4	28.9	27.1	22.4	13.9	8.0	4.1
	5%	WB	2.9	3.6	6.3	9.7	14.0	16.9	19.3	18.5	15.7	11.0	6.5	2.9
		MCDB	3.2	4.4	8.5	13.6	20.3	23.5	27.2	25.7	20.9	12.4	7.0	3.3
	10%	WB	2.2	2.6	5.2	8.6	13.0	15.9	18.3	17.6	14.7	9.9	5.6	2.0
		MCDB	2.5	3.3	7.2	12.2	18.6	21.7	25.6	24.2	19.0	11.2	6.1	2.4
Mean Daily Temperature Range	5% DB	MDBR	3.8	5.8	8.0	10.8	12.6	12.2	14.2	13.7	11.0	7.1	4.2	3.4
		MCDBR	4.2	6.5	10.4	14.5	17.5	17.2	18.1	17.2	14.6	9.4	5.6	4.1
		MCWBR	3.3	4.7	6.4	7.7	8.2	7.7	7.7	7.3	7.1	5.8	4.2	3.3
	5% WB	MCDBR	3.9	5.7	9.3	12.3	14.7	14.8	16.1	15.3	12.8	7.7	4.8	3.8
		MCWBR	3.2	4.3	6.0	7.0	7.3	7.1	7.4	7.0	6.6	5.2	3.9	3.2
Clear-Sky Solar Irradiance	taub	0.286	0.288	0.309	0.358	0.385	0.404	0.375	0.389	0.353	0.334	0.299	0.274	
	taud	2.220	2.256	2.235	2.187	2.274	2.287	2.409	2.369	2.453	2.453	2.356	2.242	
	Ebn at Noon	737	849	893	881	871	855	877	844	842	790	726	693	
	Edh at Noon	73	91	111	132	127	126	110	110	91	76	64	61	
All-Sky Solar Radiation	RadAvg	0.88	1.81	2.80	4.37	5.17	5.34	6.22	5.33	3.63	2.04	0.93	0.70	
	RadStd	0.11	0.20	0.35	0.37	0.48	0.52	0.52	0.40	0.38	0.28	0.13	0.09	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	-1.18	N/A	N/A	N/A	N/A	N/A
(47) Regional (15 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page