

SALMON ARM, BC, Canada

WMO: 712180

Lat: **50.7030N**Lon: **119.2906W**Elev: **1150**StdP: **14.10**Time Zone: **-8.00 (NAP)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 1.0	(c) 8.2	(d) -5.8	(e) 4.2	(f) 2.7	(g) 1.6	(h) 6.2	(i) 9.6	(j) 18.5	(k) 19.3	(l) 15.7	(m) 19.3	(n) 3.4	(o) 210	(p) 0.496

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 26.5	(c) 89.2	(d) 68.4	(e) 86.0	(f) 67.2	(g) 82.8	(h) 65.4	(i) 71.0	(j) 85.4	(k) 68.8	(l) 82.9	(m) 66.7	(n) 80.1	(o) 3.5	(p) 340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
65.7	98.9	79.5	63.5	91.5	76.0	61.5	85.2	73.3	35.5	85.7	33.6	83.2	31.9	80.1	79.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 14.0	(b) 10.5	(c) 7.8	(e) -4.6	(f) 94.9	(g) 8.2	(h) 3.5	(i) -10.4	(j) 97.4	(k) -15.2	(l) 99.4	(m) -19.8	(n) 101.3	(o) -25.8	(p) 103.8		
(a) 14.0	(b) 10.5	(c) 7.8	(e) -4.8	(f) 75.6	(g) 8.6	(h) 2.6	(i) -11.0	(j) 77.5	(k) -16.1	(l) 79.0	(m) -20.9	(n) 80.5	(o) -27.2	(p) 82.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	47.5	28.2	30.1	38.9	47.8	56.7	62.7	68.9	67.1	57.8	45.8	36.1	28.2	
	DBStd	15.96	9.09	8.32	6.72	5.17	5.81	5.27	5.21	5.03	5.43	5.66	7.75	8.53	
	HDD50	2945	677	557	346	101	10	0	0	0	5	155	418	676	
	HDD65	6699	1142	977	809	515	264	104	23	37	222	597	868	1141	
	CDD50	2019	0	0	1	36	217	383	587	530	241	23	1	0	
	CDD65	296	0	0	0	0	6	36	144	102	8	0	0	0	
	CDH74	3963	0	0	0	5	161	529	1801	1318	149	0	0	0	
	CDH80	1320	0	0	0	0	25	146	695	431	23	0	0	0	
Wind	WSAvg	3.0	2.7	2.6	3.0	3.5	3.3	3.2	3.3	3.1	2.8	2.6	2.9	2.9	
Precipitation	PrecAvg	20.3	2.5	1.4	1.2	1.1	1.5	1.9	1.3	1.3	1.4	1.9	2.1	2.7	
	PrecMax	29.7	3.5	2.6	2.2	2.1	4.2	4.1	4.8	2.9	3.6	3.9	5.1	4.8	
	PrecMin	13.5	1.3	0.6	0.6	0.3	0.1	0.4	0.0	0.2	0.2	0.1	0.4	0.5	
	PrecStd	3.7	0.6	0.5	0.4	0.4	0.9	0.9	1.1	0.8	1.0	1.0	1.3	1.1	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	46.2	49.1	60.6	72.5	83.0	89.2	94.5	91.6	82.7	66.6	55.5	46.4	
		MCWB	40.5	42.5	49.4	57.3	64.5	68.4	70.2	68.4	64.0	56.7	47.3	40.7	
	2%	DB	41.5	44.9	55.8	67.3	78.5	84.2	90.6	87.8	78.4	61.8	50.9	42.2	
		MCWB	38.3	40.3	46.2	53.5	62.0	66.5	68.9	68.1	64.0	53.9	46.3	38.7	
	5%	DB	38.8	42.0	52.4	63.4	74.4	80.2	87.4	84.8	74.2	58.4	48.1	39.4	
		MCWB	37.0	38.4	44.5	50.9	59.1	64.0	67.9	66.6	61.3	51.6	44.7	37.1	
	10%	DB	36.9	39.6	49.3	59.7	70.4	76.0	84.0	81.7	70.3	55.6	45.7	37.3	
		MCWB	35.6	37.0	42.6	49.1	57.3	62.0	66.0	65.2	59.2	50.1	43.1	35.6	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	41.7	44.1	50.8	58.9	67.2	71.9	74.8	73.3	67.9	58.9	50.4	42.2
			MCDB	45.0	48.0	58.0	69.1	80.3	86.0	89.7	86.7	78.2	64.6	53.0	44.5
2%		WB	39.1	41.3	47.8	55.2	63.5	68.5	71.6	70.3	64.8	55.7	47.7	39.5	
		MCDB	40.9	43.7	53.6	64.8	74.9	81.5	86.8	84.1	75.4	59.6	49.6	41.1	
5%		WB	37.3	39.2	45.6	52.7	60.8	65.3	69.3	68.1	62.6	53.1	45.6	37.4	
		MCDB	38.5	41.1	50.8	61.0	71.2	77.5	84.2	82.1	71.6	56.8	47.2	38.8	
10%		WB	35.9	37.3	43.5	50.3	58.4	63.0	67.2	66.0	60.4	50.7	43.5	35.6	
		MCDB	36.9	39.0	48.2	57.7	68.5	73.5	81.3	79.2	68.7	54.4	45.4	36.9	
Mean Daily Temperature Range		5% DB	MDBR	9.7	13.8	17.5	22.1	23.5	22.7	26.5	26.8	23.1	17.0	11.0	9.3
			MCDBR	10.3	15.0	21.5	28.8	31.3	31.3	33.2	32.6	29.2	21.0	13.8	10.3
	MCWBR		8.1	10.8	13.1	16.6	17.5	17.3	17.2	17.2	17.1	13.5	9.5	8.0	
	5% WB	MCDBR	9.5	13.1	19.6	26.4	28.3	29.3	31.6	31.1	27.6	18.9	12.1	9.7	
		MCWBR	7.5	10.0	12.8	16.0	16.6	17.1	17.5	17.2	17.0	13.0	8.9	7.8	
Clear-Sky Solar Irradiance	taub	0.295	0.285	0.318	0.348	0.372	0.371	0.365	0.375	0.350	0.334	0.303	0.273		
	taud	2.250	2.350	2.364	2.369	2.360	2.396	2.446	2.413	2.466	2.479	2.446	2.369		
	Ebn at Noon	228	272	281	284	280	281	281	272	268	250	230	224		
	Edh at Noon	22	26	31	35	37	36	34	33	28	23	18	17		
All-Sky Solar Radiation	RadAvg	256	569	935	1388	1676	1753	1972	1694	1151	629	275	197		
	RadStd	28	58	106	116	143	174	172	109	106	84	34	27		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (16 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page