

POLLOCKVILLE AGDM, AB, Canada

WMO: 712590

Lat: 51.1253N

Lon: 111.7053W

Elev: 2461

StdP: 13.44

Time Zone: -7.00 (NAM)

Period: 03-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-25.4	-19.0	-31.6	1.0	-25.3	-24.8	1.5	-18.9	28.9	24.1	24.7	23.1	5.1	210	0.717

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	28.8	89.3	62.4	85.5	62.0	81.7	60.7	65.7	82.0	64.0	79.9	62.4	77.6	10.8	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
60.4	85.8	70.7	58.3	79.7	69.0	56.6	74.7	67.3	31.9	81.9	30.5	80.2	29.3	77.8	72.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
27.8	23.7	20.4	-33.5	95.1	5.5	3.4	-37.5	97.6	-40.8	99.5	-43.9	101.4	-47.9	103.9		
			-33.8	70.1	5.5	2.0	-37.7	71.5	-40.9	72.7	-44.0	73.8	-48.0	75.2		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	38.2	12.3	11.9	26.3	40.1	51.2	58.6	65.1	62.9	53.0	40.1	23.8	11.6
	DBStd	22.24	14.89	14.13	23.90	9.27	7.47	5.78	5.68	6.26	8.06	9.36	13.37	13.96
	HDD50	5722	1169	1066	735	310	77	4	0	1	57	326	786	1191
	HDD65	9915	1634	1486	1199	747	430	206	69	115	366	772	1235	1656
	CDD50	1427	0	0	1	14	113	262	468	401	148	19	1	0
	CDD65	144	0	0	0	0	1	14	72	50	7	0	0	0
	CDH74	3347	0	0	1	12	162	362	1402	1056	337	15	0	0
	CDH80	1152	0	0	0	0	27	91	528	391	114	1	0	0
	WSAvg	9.1	8.6	8.2	9.6	10.7	10.5	9.8	9.0	8.7	8.9	9.2	8.5	7.8
	PrecAvg	14.0	0.6	0.4	0.6	0.9	1.6	2.9	2.3	1.9	1.1	0.6	0.6	0.5
(15) Precipitation	PrecMax	18.3	1.7	0.9	1.4	2.0	3.3	6.0	5.8	3.4	2.9	1.3	2.1	0.7
	PrecMin	10.4	0.1	0.0	0.2	0.1	0.2	0.6	0.9	0.4	0.1	0.2	0.0	0.1
	PrecStd	2.6	0.4	0.2	0.3	0.5	0.9	1.3	1.1	1.0	0.7	0.3	0.5	0.2
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	45.8	44.6	63.3	75.1	83.3	88.2	94.6	93.6	89.5	76.3	61.0	45.9
		MCWB	38.6	37.0	46.9	52.6	57.9	63.1	64.6	62.4	59.6	54.3	46.7	39.5
	2%	DB	40.4	39.2	56.3	69.1	78.6	82.2	90.2	88.5	83.1	68.3	52.6	39.6
		MCWB	35.5	34.5	43.0	49.7	55.7	60.7	64.5	61.6	58.5	51.5	42.2	35.4
	5%	DB	36.9	35.5	50.1	63.4	74.0	78.0	85.9	84.6	77.0	62.8	46.5	35.9
		MCWB	33.5	32.3	40.1	46.3	53.7	59.3	63.3	61.4	56.6	48.5	38.9	32.6
	10%	DB	32.8	31.5	44.6	58.4	69.4	74.1	81.9	80.0	71.5	57.2	41.2	31.4
		MCWB	30.3	29.1	37.6	43.9	52.1	57.5	62.0	60.3	54.4	45.4	35.8	29.1
	0.4%	WB	39.0	38.1	48.2	53.5	59.7	65.9	69.7	66.7	62.0	55.8	47.6	39.8
		MCDB	45.2	43.2	62.1	73.2	78.2	80.1	86.4	82.3	82.0	73.2	61.1	45.2
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	35.8	34.9	44.0	50.2	57.2	63.2	66.7	64.6	59.4	52.4	42.5	35.7
		MCDB	39.7	38.5	54.4	67.0	75.4	77.6	83.4	81.5	78.7	65.9	51.1	39.1
	5%	WB	33.7	32.4	40.6	47.4	55.2	60.9	64.9	63.0	57.4	49.3	39.3	32.7
		MCDB	37.0	35.3	49.0	61.2	71.3	74.4	80.7	79.3	75.2	61.4	45.3	35.7
	10%	WB	30.4	29.2	37.6	44.8	52.9	58.9	63.3	61.3	55.0	46.4	36.1	29.1
		MCDB	32.9	31.7	43.8	56.2	66.7	71.3	78.5	76.8	70.5	56.5	40.6	31.4
(35) Mean Daily Temperature Range	5% DB	MDBR	20.6	21.4	22.0	26.0	27.7	25.3	28.8	28.6	29.0	27.0	22.0	19.8
		MCDBR	23.8	24.4	30.6	36.8	36.9	32.8	36.0	37.3	39.8	36.2	29.3	23.7
		MCWBR	19.5	19.9	18.3	18.9	17.1	14.7	14.1	14.6	18.1	20.2	19.4	19.2
		MCDBR	23.1	23.4	28.6	34.0	32.6	29.1	31.4	31.8	37.3	34.5	27.6	23.7
	5% WB	MCWBR	19.2	19.5	17.9	18.0	15.7	14.5	13.7	13.6	17.4	19.5	18.8	19.4
(40) Clear-Sky Solar Irradiance	taub		0.271	0.303	0.292	0.347	0.374	0.371	0.363	0.382	0.331	0.289	0.260	0.257
	taud		2.354	2.314	2.462	2.311	2.280	2.341	2.396	2.312	2.437	2.535	2.491	2.362
	Ebn at Noon		242	261	292	283	279	280	281	268	273	269	250	229
	Edh at Noon		20	27	28	37	40	38	35	36	29	21	17	16
(44) All-Sky Solar Radiation	RadAvg		371	697	1131	1543	1851	1952	2103	1706	1221	743	400	283
	RadStd		35	61	84	118	124	118	96	118	110	87	34	27

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (80 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page