

SCHULER AGDM, AB, Canada

WMO: 712690

Lat: 50.3069N

Lon: 110.0906W

Elev: 800

StdP: 92.08

Time Zone: -7.00 (NAM)

Period: 03-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-28.9	-25.9	-32.5	0.2	-28.9	-29.2	0.3	-25.8	13.7	-1.1	12.1	-2.1	3.5	260	0.722

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.2	32.3	16.6	30.3	16.3	28.1	15.9	18.7	27.5	17.8	26.3	16.8	25.5	4.8	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
16.0	12.5	21.1	14.7	11.5	20.4	13.7	10.8	19.4	56.6	27.5	53.2	26.2	50.2	25.5	25.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.4	10.9	9.6	DB	-33.3	35.6	2.7	1.6	-35.2	36.8	-36.8	37.8	-38.2	38.7	-40.2	39.9	(4)
(5)			WB	-33.4	21.2	2.6	1.5	-35.3	22.3	-36.9	23.1	-38.3	23.9	-40.2	25.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	5.0	-8.1	-8.9	-1.4	5.5	11.1	15.2	18.9	18.1	12.9	5.8	-2.2	-8.5	(6)
(7)		DBStd	11.73	8.53	8.09	7.84	4.89	4.51	3.19	3.05	3.56	4.80	5.50	7.31	8.06	(7)
(8)		HDD10.0	2748	561	529	354	147	41	2	0	0	24	151	368	572	(8)
(9)		HDD18.3	4995	819	762	612	386	226	104	30	48	172	388	617	831	(9)
(10)		CDD10.0	906	0	0	1	11	76	157	277	251	111	21	1	0	(10)
(11)		CDD18.3	111	0	0	0	0	3	8	49	41	9	1	0	0	(11)
(12)		CDH23.3	2088	0	0	0	6	99	189	817	738	228	12	0	0	(12)
(13)		CDH26.7	766	0	0	0	1	19	48	319	295	83	1	0	0	(13)
(14)	Wind	WSAvg	4.7	5.3	4.6	4.9	5.1	5.0	4.6	3.9	3.9	4.3	4.9	5.1	4.9	(14)
(15)	Precipitation	PrecAvg	349	14	12	16	24	44	79	44	42	29	22	14	14	(15)
(16)		PrecMax	510	43	37	40	61	135	161	111	124	71	59	43	30	(16)
(17)		PrecMin	210	3	1	0	1	1	42	5	1	0	6	2	4	(17)
(18)		PrecStd	78	10	9	9	16	32	35	28	27	17	13	10	7	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.8	9.6	17.8	23.7	29.2	30.9	35.0	34.6	32.5	25.0	17.4	9.1	(19)
(20)			MCWB	4.5	4.2	8.9	10.7	14.5	17.2	18.0	16.7	15.3	12.7	8.5	4.9	(20)
(21)		2%	DB	6.1	6.1	14.3	20.4	26.1	27.8	32.5	32.2	29.2	20.9	12.7	6.0	(21)
(22)			MCWB	3.0	2.4	7.0	9.6	13.3	16.4	17.5	16.1	14.6	10.9	6.4	2.6	(22)
(23)		5%	DB	4.5	3.6	11.3	17.7	23.5	25.4	30.2	30.1	25.8	17.6	9.8	4.1	(23)
(24)			MCWB	2.1	1.0	5.7	8.2	12.0	15.5	17.3	15.8	13.4	9.6	4.7	1.6	(24)
(25)		10%	DB	3.1	1.6	8.2	14.8	20.8	23.1	28.0	27.7	22.6	14.6	7.3	2.2	(25)
(26)			MCWB	1.1	-0.3	3.8	6.8	10.6	14.4	16.8	15.5	12.3	7.9	3.3	0.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.8	4.9	9.4	11.7	15.2	19.5	21.0	18.8	16.3	13.6	9.0	5.4	(27)
(28)			MCDB	8.1	8.7	17.0	21.5	25.7	27.3	29.0	28.3	28.4	23.1	15.3	8.9	(28)
(29)		2%	WB	3.2	2.6	7.4	10.1	13.9	17.6	19.5	17.8	15.1	11.6	7.0	3.1	(29)
(30)			MCDB	5.7	5.7	13.3	19.3	23.6	25.4	28.2	27.3	26.4	19.4	12.6	5.5	(30)
(31)		5%	WB	2.2	1.1	5.7	8.7	12.7	16.2	18.4	16.9	13.8	9.8	5.1	1.6	(31)
(32)			MCDB	4.4	3.5	10.7	16.5	21.7	23.8	26.8	26.6	24.4	16.5	9.3	3.9	(32)
(33)		10%	WB	1.1	-0.2	4.0	7.2	11.5	15.0	17.5	16.0	12.7	8.3	3.4	0.2	(33)
(34)			MCDB	3.1	1.6	8.1	13.7	19.4	21.7	25.7	25.5	21.5	14.1	6.8	2.1	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	9.9	10.6	11.2	12.9	13.3	12.5	15.2	15.1	13.9	12.6	10.7	9.5	(35)
(36)			MCDBR	10.1	12.3	14.6	18.3	17.9	16.8	19.5	20.0	20.2	16.8	14.2	9.7	(36)
(37)			MCWBR	7.8	9.2	8.5	9.4	7.7	7.7	7.5	7.3	8.1	8.6	8.7	7.3	(37)
(38)		5% WB	MCDBR	9.8	11.6	14.0	16.8	15.8	15.4	16.5	16.7	18.4	16.1	13.4	9.6	(38)
(39)			MCWBR	7.7	8.8	8.5	8.9	7.1	7.9	7.5	6.7	7.8	8.6	8.7	7.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.266	0.253	0.289	0.349	0.373	0.362	0.368	0.385	0.335	0.295	0.262	0.245	(40)	
(41)		taud	2.378	2.499	2.467	2.301	2.277	2.370	2.367	2.285	2.406	2.502	2.490	2.429	(41)	
(42)		Ebn at Noon	787	916	928	893	883	894	882	845	859	844	798	770	(42)	
(43)		Edh at Noon	62	71	89	118	126	116	115	119	94	71	55	51	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.21	2.21	3.56	4.91	5.84	6.27	6.80	5.50	3.97	2.44	1.35	0.94	(44)	
(45)		RadStd	0.12	0.19	0.25	0.34	0.39	0.39	0.36	0.38	0.33	0.26	0.11	0.09	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (42 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page