

BUSBY AGCM, AB, CanadaWMO: **712840**Lat: **53.9308N**Lon: **113.9217W**Elev: **2343**StdP: **13.49**Time Zone: **-7.00 (NAM)**Period: **08-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-24.6	-19.0	-31.1	1.0	-24.5	-25.0	1.5	-18.5	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.7	81.5	62.0	78.5	60.9	75.7	59.8	65.6	76.2	63.6	74.5	61.7	72.2	N/A	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
61.7	89.5	71.5	59.3	82.3	68.3	57.5	76.9	66.1	31.8	75.8	30.1	74.8	28.7	72.2	73.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
N/A	N/A	N/A	-32.5	86.9	4.6	3.2	-35.8	89.1	-38.5	91.0	-41.1	92.8	-44.4	95.1		
			-32.7	69.4	4.6	2.7	-36.0	71.3	-38.7	72.9	-41.2	74.4	-44.6	76.3		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	36.6	13.1	11.9	22.4	37.6	50.9	57.7	61.7	59.8	51.0	38.7	23.1	10.1
	DBStd	21.72	15.55	14.80	13.93	9.30	8.17	5.44	4.84	5.71	8.07	8.55	12.55	14.32
	HDD50	6037	1144	1066	857	382	89	7	0	3	83	361	807	1238
	HDD65	10404	1609	1486	1322	822	438	226	126	176	423	816	1257	1703
	CDD50	1157	0	0	0	10	118	238	361	307	112	11	0	0
	CDD65	50	0	0	0	0	2	7	23	15	3	0	0	0
	CDH74	975	0	0	0	2	90	136	344	286	114	3	0	0
	CDH80	154	0	0	0	0	11	15	52	53	23	0	0	0
	WSAvg	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	PrecAvg	16.9	0.8	0.4	0.6	1.1	1.9	3.0	3.4	2.2	1.3	0.7	0.7	0.6
(15) Precipitation	PrecMax	23.9	2.8	1.1	1.3	2.2	4.4	6.4	6.0	4.2	3.1	2.3	2.9	1.1
	PrecMin	10.1	0.1	0.0	0.2	0.1	0.4	0.8	1.1	1.1	0.2	0.2	0.2	0.1
	PrecStd	3.0	0.7	0.2	0.3	0.5	0.9	1.4	1.2	0.8	0.8	0.5	0.6	0.3
	PrecStd	3.0	0.7	0.2	0.3	0.5	0.9	1.4	1.2	0.8	0.8	0.5	0.6	0.3
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	44.8	44.1	52.1	72.3	81.5	82.2	85.2	84.8	83.3	70.8	53.8	41.9
		MCWB	37.2	37.0	42.3	51.3	56.2	61.1	65.2	62.5	60.9	53.9	44.7	35.3
	2%	DB	41.3	39.2	46.3	64.1	76.3	78.0	81.0	80.5	77.1	61.3	45.6	37.8
		MCWB	35.6	34.2	38.3	47.1	54.2	59.5	63.6	63.1	58.4	48.5	39.1	32.9
	5%	DB	38.6	36.0	42.1	57.8	72.0	74.3	77.8	77.0	72.2	56.6	41.9	34.2
		MCWB	33.9	32.0	36.2	43.7	52.5	57.7	62.7	61.9	56.7	45.5	36.5	30.1
	10%	DB	34.9	32.7	38.7	53.0	67.5	71.1	74.8	73.7	66.7	52.3	38.1	29.9
		MCWB	31.5	29.6	33.8	41.4	50.2	56.6	61.4	60.4	54.1	43.3	34.3	26.8
	0.4%	WB	37.7	37.7	42.9	51.7	58.0	64.4	69.7	68.2	62.5	53.9	44.8	36.3
		MCDB	43.2	43.2	50.5	71.3	75.9	76.1	80.1	76.7	78.5	69.1	51.5	40.9
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	36.2	34.9	39.2	47.5	55.8	61.5	66.6	65.4	59.7	49.6	40.1	33.2
		MCDB	40.9	38.7	45.1	62.7	71.6	73.4	76.7	76.4	74.6	59.4	44.5	37.1
	5%	WB	34.1	32.2	36.4	44.6	53.8	59.6	64.2	63.3	57.3	46.6	37.0	30.2
		MCDB	37.8	35.4	41.6	56.3	68.8	70.5	74.6	74.0	70.2	55.0	41.0	34.1
	10%	WB	31.4	29.7	34.1	42.1	51.6	58.0	62.3	61.4	55.1	44.2	34.6	26.8
		MCDB	35.1	33.0	38.2	51.8	65.7	68.5	72.3	71.5	65.4	51.0	38.1	29.5
(35) Mean Daily Temperature Range	5% DB	MDBR	17.4	18.6	18.1	19.3	23.1	21.3	21.7	22.9	23.0	18.9	15.4	16.3
		MCDBR	17.3	19.3	20.9	29.0	30.8	27.3	27.3	28.7	32.7	26.3	18.3	19.7
		MCWBR	12.9	15.2	14.1	14.9	13.9	12.4	13.4	13.6	16.1	14.9	12.2	15.9
	5% WB	MCDBR	17.3	18.7	19.7	26.9	27.8	23.4	24.4	25.3	30.6	24.9	16.6	19.7
		MCWBR	13.6	14.9	13.5	14.5	13.1	11.3	13.5	13.3	15.6	14.7	12.1	16.3
(40) Clear-Sky Solar Irradiance	taub		0.250	0.268	0.303	0.324	0.340	0.350	0.353	0.357	0.307	0.280	0.251	0.236
	taud		2.310	2.336	2.325	2.393	2.394	2.379	2.420	2.354	2.500	2.551	2.454	2.313
	Ebn at Noon		233	268	279	288	288	285	282	273	277	264	237	216
	Edh at Noon		17	24	31	33	35	36	34	34	26	19	15	14
	RadAvg		290	614	1089	1473	1789	1883	1913	1578	1091	620	297	210
(45) All-Sky Solar Radiation	RadStd		29	46	81	131	138	127	107	111	113	73	31	19

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (57 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page