

EGBERT CS, ON, Canada

WMO: 712960

Lat: 44.2331N

Lon: 79.7800W

Elev: 251

StdP: 98.35

Time Zone: -5.00 (NAE)

Period: 00-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-21.6	-18.5	-25.4	0.4	-20.9	-21.9	0.5	-18.0	9.3	-3.1	8.5	-5.1	2.5	330	0.548

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.0	30.7	22.1	28.8	21.0	27.2	20.2	23.6	28.2	22.6	26.8	21.6	25.4	4.3	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
22.2	17.4	25.8	21.2	16.3	24.8	20.2	15.3	23.8	71.8	28.5	67.8	26.8	64.0	25.6	29.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.5	7.5	6.7	DB	-26.3	33.1	2.9	1.8	-28.4	34.4	-30.1	35.4	-31.7	36.4	-33.9	37.7	(4)
(5)			WB	-26.5	25.5	2.9	1.7	-28.6	26.7	-30.3	27.6	-31.9	28.6	-34.1	29.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	7.2	-6.8	-6.2	-1.4	5.7	12.6	17.5	20.3	19.4	15.7	9.2	2.9	-3.3	(6)	
	DBStd	10.82	6.74	5.91	6.06	5.13	4.82	3.91	3.14	3.14	4.20	4.73	4.99	5.43	(7)	
	HDD10.0	2212	521	453	356	148	26	1	0	0	4	75	217	411	(8)	
	HDD18.3	4264	779	686	612	379	189	61	16	24	101	286	463	669	(9)	
	CDD10.0	1194	0	0	2	19	108	225	319	293	175	49	4	0	(10)	
	CDD18.3	206	0	0	0	1	12	36	76	59	22	2	0	0	(11)	
	CDH23.3	1781	0	0	1	13	122	342	640	454	194	16	0	0	(12)	
	CDH26.7	470	0	0	0	1	28	103	173	116	48	1	0	0	(13)	
(14) Wind	WSAvg	3.2	3.5	3.5	3.5	3.7	3.2	2.8	2.6	2.5	2.7	3.1	3.3	3.4	(14)	
(15) Precipitation	PrecAvg	830	59	53	56	68	73	77	83	77	72	70	70	66	(15)	
	PrecMax	1076	107	107	140	121	140	209	131	198	133	131	137	112	(16)	
	PrecMin	579	29	24	20	25	25	20	33	34	29	16	19	25	(17)	
	PrecStd	108	22	24	25	27	26	42	30	36	26	28	29	23	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.1	10.1	18.2	25.5	29.5	31.9	32.6	33.0	30.9	25.6	17.4	11.8	(19)	
		MCWB	9.1	7.6	13.6	17.0	19.5	22.3	23.1	22.7	21.6	18.4	12.4	10.5	(20)	
	2%	DB	6.2	6.3	13.0	20.6	26.9	29.8	30.5	29.4	27.9	22.2	14.6	8.1	(21)	
		MCWB	5.0	4.7	9.9	14.2	18.5	21.6	22.0	21.1	20.4	17.0	12.1	6.6	(22)	
	5%	DB	3.8	3.6	9.8	17.5	23.8	27.3	28.6	27.6	25.5	19.2	12.5	5.6	(23)	
		MCWB	2.7	2.0	6.9	11.7	16.7	20.3	21.1	20.7	19.3	15.2	10.0	4.5	(24)	
	10%	DB	2.0	1.8	6.8	14.3	21.3	24.9	26.9	25.8	23.2	16.6	10.2	3.6	(25)	
		MCWB	1.1	0.6	4.2	9.6	15.0	18.7	20.1	19.7	18.3	13.7	8.2	2.5	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.4	7.8	14.5	18.4	21.9	24.2	25.4	24.9	23.3	20.8	14.6	10.7	(27)	
		MCDB	10.0	9.0	17.6	22.5	26.3	29.6	30.1	29.3	27.8	23.8	15.7	11.8	(28)	
	2%	WB	5.1	4.9	10.2	15.1	19.8	22.8	23.7	23.2	21.7	17.8	12.4	6.8	(29)	
		MCDB	5.9	6.5	11.9	19.7	25.2	27.8	28.0	27.3	26.0	20.4	14.1	7.7	(30)	
	5%	WB	2.7	2.2	7.4	12.6	18.1	21.4	22.5	22.0	20.5	15.9	10.1	4.6	(31)	
		MCDB	3.5	3.3	9.7	16.5	22.8	25.8	26.6	25.8	24.3	18.5	12.0	5.6	(32)	
	10%	WB	1.1	0.6	4.4	10.1	16.1	19.9	21.4	20.9	19.1	14.0	8.4	2.5	(33)	
		MCDB	1.9	1.7	6.4	13.8	19.9	23.6	25.2	24.0	22.1	16.3	10.3	3.3	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	7.7	8.1	8.6	10.2	11.5	10.8	11.0	10.8	11.0	8.8	7.5	6.4	(35)	
		MCDBR	7.8	9.7	12.3	15.5	14.4	13.6	12.9	13.1	13.6	12.8	11.0	7.8	(36)	
	5% WB	MCWBR	7.2	8.5	9.1	9.8	8.1	7.2	6.2	6.3	7.2	8.1	8.5	7.0	(37)	
		MCWBR	7.3	9.1	11.9	13.7	12.7	12.2	11.0	10.6	11.5	11.3	10.0	7.7	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.281	0.298	0.317	0.356	0.386	0.408	0.403	0.394	0.362	0.343	0.308	0.281	(40)	
		taud	2.373	2.308	2.405	2.354	2.320	2.279	2.313	2.323	2.412	2.452	2.498	2.435	(41)	
	Edn at Noon		845	891	922	907	884	863	863	858	862	831	811	812	(42)	
		Edh at Noon	76	97	102	117	125	131	125	119	101	85	68	66	(43)	
(44) All-Sky Solar Radiation	RadAvg		1.37	2.22	3.52	4.48	5.39	5.88	5.93	5.12	4.05	2.38	1.43	1.01	(44)	
	RadStd		0.15	0.27	0.37	0.45	0.55	0.43	0.39	0.27	0.39	0.24	0.20	0.12	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	-1.79	-2.23	N/A	N/A	N/A	N/A	N/A
(47) Regional (51 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page