

ON EGBERT 1 W, ON, Canada

WMO: 712961

Lat: 44.2326N

Lon: 79.7810W

Elev: 807

StdP: 14.27

Time Zone: -5.00 (NAE)

Period: 04-19

WBAN: 64757

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-6.4	-1.1	-13.8	2.7	-5.7	-8.2	3.7	-0.8	16.9	22.1	15.9	21.7	4.3	N/A	0.504

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.8	86.8	70.2	83.4	68.7	80.8	67.5	72.8	82.0	71.3	80.2	69.8	77.4	7.6	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
69.9	113.4	76.7	68.5	107.9	75.8	67.0	102.2	74.4	37.0	82.0	35.6	80.9	34.3	77.0	78.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)		
15.3	13.5	12.0	-15.2	91.0	5.0	2.8	-18.8	93.0	-21.7	94.7	-24.6	96.2	-28.2	98.2		
			-16.4	76.2	4.9	1.9	-20.0	77.6	-22.8	78.8	-25.6	79.8	-29.1	81.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	44.9	19.8	20.5	29.2	42.1	54.9	63.5	68.6	66.6	60.3	48.4	36.7	26.1
	DBStd	19.51	12.10	10.66	11.11	8.72	8.77	6.84	5.58	5.50	7.39	8.36	9.18	9.74
	HDD50	4009	935	826	650	265	46	1	0	0	5	133	406	742
	HDD65	7710	1400	1246	1110	686	334	107	27	47	180	516	850	1207
	CDD50	2135	0	0	6	29	199	406	577	514	314	84	6	0
	CDD65	361	0	0	0	0	22	62	139	96	39	3	0	0
	CDH74	3087	0	0	2	13	239	587	1177	708	334	27	0	0
	CDH80	761	0	0	0	0	54	161	310	155	79	2	0	0
Wind	WSAvg	5.5	6.3	6.4	6.3	6.5	5.3	4.8	4.3	4.2	4.4	5.3	5.7	6.1
Precipitation	PrecAvg	32.7	2.3	2.1	2.2	2.7	2.9	3.0	3.3	3.0	2.8	2.8	2.8	2.6
	PrecMax	42.4	4.2	4.2	5.5	4.8	5.5	8.2	5.2	7.8	5.2	5.2	5.4	4.4
	PrecMin	22.8	1.1	0.9	0.8	1.0	1.0	0.8	1.3	1.3	1.1	0.6	0.7	1.0
	PrecStd	4.3	0.9	0.9	1.0	1.1	1.0	1.7	1.2	1.4	1.0	1.1	1.1	0.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.7	50.4	66.7	75.9	85.2	89.0	90.7	89.0	87.1	78.1	63.5	52.1
		MCWB	49.0	45.9	59.0	58.8	67.6	71.0	72.6	70.2	72.0	64.6	54.9	49.5
	2%	DB	43.8	43.4	55.9	67.6	80.8	84.7	86.9	83.8	82.0	71.7	57.9	46.0
		MCWB	41.3	40.0	49.7	54.6	65.6	67.6	70.3	68.5	69.2	61.6	51.7	43.6
	5%	DB	39.1	38.3	49.9	62.6	75.5	80.7	83.3	80.9	77.8	66.2	53.9	41.7
		MCWB	37.1	35.0	45.9	53.7	62.6	67.3	69.1	67.7	66.9	57.7	48.4	39.4
	10%	DB	35.7	34.9	44.5	57.3	71.1	76.8	80.5	77.9	73.5	61.7	49.8	38.1
		MCWB	33.6	32.4	39.5	48.0	59.5	64.1	67.2	66.4	64.8	55.7	45.7	35.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	48.0	49.5	60.6	60.8	70.3	73.7	75.7	73.7	74.1	67.8	57.3	50.9
		MCDB	49.5	52.4	71.1	66.8	81.3	84.8	86.3	79.9	83.4	72.9	60.4	53.2
	2%	WB	40.7	42.0	52.0	57.0	68.0	70.8	72.9	71.7	71.6	62.6	52.8	44.6
		MCDB	42.0	45.3	55.5	62.4	78.1	81.1	82.7	79.9	80.6	68.5	57.1	46.6
	5%	WB	36.3	37.1	46.2	52.3	65.4	68.4	71.3	70.0	69.5	59.5	49.0	40.8
		MCDB	38.2	39.9	51.2	58.6	74.3	76.0	80.4	77.0	75.8	64.6	53.5	42.8
	10%	WB	33.4	33.3	39.9	47.9	61.9	66.3	69.8	68.3	66.9	56.9	46.1	36.8
		MCDB	34.8	35.9	43.5	54.4	69.3	73.5	77.4	75.4	72.4	60.4	50.6	38.7
Mean Daily Temperature Range	5% DB	MDBR	13.8	13.9	15.3	18.3	20.9	19.5	19.8	19.2	19.6	15.7	13.5	11.2
		MCDBR	14.3	17.2	22.6	27.8	25.8	24.0	23.2	22.8	23.9	23.1	20.0	14.0
		MCWBR	13.7	15.0	16.0	18.8	14.4	13.0	11.0	11.0	11.8	13.6	14.8	12.3
	5% WB	MCDBR	14.0	18.2	21.0	24.7	22.5	20.9	19.7	18.3	20.1	19.0	18.5	14.1
		MCWBR	13.5	16.3	16.1	18.4	13.2	13.0	10.6	10.4	11.6	13.2	14.7	13.1
Clear-Sky Solar Irradiance	taub		0.282	0.298	0.317	0.356	0.387	0.408	0.403	0.395	0.362	0.344	0.309	0.281
	taud		2.372	2.308	2.404	2.353	2.320	2.278	2.312	2.322	2.412	2.452	2.497	2.435
	Ebn at Noon		268	283	292	288	280	274	273	272	273	263	257	258
	Edh at Noon		24	31	32	37	40	42	40	38	32	27	22	21
All-Sky Solar Radiation	RadAvg		434	705	1118	1420	1709	1866	1883	1625	1286	754	452	320
	RadStd		49	85	117	143	173	137	124	85	122	78	62	38

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (51 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page