

POINT PEELEE, ON, Canada

WMO: 713030

Lat: 41.9488N

Lon: 82.5192W

Elev: 580

StdP: 14.39

Time Zone: -5.00 (NAE)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	0.3	6.7	-6.0	4.1	1.4	-0.2	5.5	7.9	13.2	19.8	12.2	21.2	5.7	290	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.2	85.2	75.1	82.8	73.6	80.7	72.3	77.5	82.5	75.6	80.7	73.9	79.1	4.4	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
76.0	138.8	81.2	74.0	129.7	79.4	72.2	121.6	77.8	41.4	82.8	39.6	80.9	37.9	79.2	82.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
13.2	11.8	10.5	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
			-3.5	87.7	6.8	3.6	-8.4	90.2	-12.3	92.3	-16.1	94.3	-21.0	96.9
			-4.1	78.3	6.6	3.0	-8.8	80.5	-12.7	82.3	-16.4	84.0	-21.2	86.2
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	48.4	25.0	25.9	33.2	44.0	54.9	65.5	70.9	70.1	64.2	52.9	41.5	31.7	(6)
	DBStd	18.17	10.29	10.08	8.64	7.27	7.89	6.79	5.86	5.34	6.87	8.03	8.31	8.42	(7)
	HDD50	3118	776	674	522	207	34	0	0	0	1	60	276	568	(8)
	HDD65	6600	1241	1094	985	629	329	75	15	16	94	384	706	1032	(9)
	CDD50	2553	0	0	3	28	187	464	649	623	428	151	19	1	(10)
	CDD65	559	0	0	0	0	17	89	199	174	71	9	0	0	(11)
	CDH74	3431	0	0	0	3	79	467	1469	1051	348	14	0	0	(12)
	CDH80	602	0	0	0	0	12	79	304	147	59	1	0	0	(13)
	WSAvg	5.1	5.8	6.0	5.7	5.7	5.1	3.8	3.6	3.5	4.4	5.3	6.0	6.2	(14)
	PrecAvg	37.6	2.5	2.2	2.6	3.6	3.7	3.9	3.7	3.5	3.5	2.8	2.8	2.8	(15)
(16) Precipitation	PrecMax	45.7	5.6	5.3	5.4	5.4	7.2	6.3	8.6	8.5	8.1	4.7	5.5	7.2	(16)
	PrecMin	26.6	0.7	0.6	1.1	2.0	1.2	1.3	1.6	0.8	1.2	0.7	0.8	1.2	(17)
	PrecStd	4.9	1.2	1.2	1.1	1.0	1.7	1.4	1.6	1.8	1.6	0.9	1.0	1.3	(18)
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	47.3	51.0	59.9	69.9	81.0	86.1	88.6	86.8	85.6	75.6	64.2	55.9	(19)
		MCWB	45.3	47.3	52.7	58.3	68.1	73.6	77.7	77.7	75.8	69.0	56.3	52.7	(20)
	2%	DB	43.3	45.7	53.1	64.1	75.5	82.2	85.7	83.5	81.2	71.7	59.2	49.6	(21)
		MCWB	41.4	42.5	48.1	54.6	64.4	72.2	75.3	75.1	73.1	66.4	54.7	47.7	(22)
	5%	DB	40.5	41.6	48.8	59.4	71.4	79.1	83.4	81.4	78.0	68.8	56.1	45.7	(23)
		MCWB	38.7	38.8	45.0	51.3	62.9	70.0	74.1	73.4	70.7	63.6	51.8	43.8	(24)
	10%	DB	37.8	38.0	44.8	55.1	67.4	76.3	81.1	79.4	74.9	65.6	53.3	42.5	(25)
		MCWB	36.2	35.6	41.5	48.6	60.2	68.4	72.6	72.0	68.6	60.7	49.5	40.5	(26)
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	45.7	49.1	54.7	61.5	70.0	76.5	80.2	80.1	77.2	70.6	58.5	52.9	(27)
		MCDB	46.8	50.2	59.1	65.2	78.8	82.6	86.1	84.1	84.3	73.9	61.1	55.2	(28)
	2%	WB	41.9	43.1	48.8	56.0	66.8	74.1	78.0	77.2	74.4	67.6	55.3	48.3	(29)
		MCDB	42.9	44.7	51.9	62.9	73.1	79.8	83.0	81.7	79.6	70.7	58.4	49.7	(30)
	5%	WB	38.9	38.9	45.3	52.5	64.0	71.9	76.1	75.3	72.1	64.4	52.5	44.0	(31)
		MCDB	40.3	41.4	48.2	57.8	69.5	77.3	81.2	79.7	76.7	68.1	55.6	45.4	(32)
	10%	WB	36.1	35.9	41.8	49.6	61.3	69.8	74.1	73.4	69.8	61.1	49.8	40.9	(33)
		MCDB	37.6	37.9	44.6	54.7	66.4	75.1	79.7	78.0	74.1	64.9	52.7	42.3	(34)
(36) Mean Daily Temperature Range	5% DB	MDBR	11.6	12.8	13.4	15.1	15.2	15.6	16.2	15.2	15.1	13.2	10.8	9.3	(35)
		MCDBR	12.0	14.9	18.5	21.8	20.0	17.8	16.9	16.0	16.1	15.3	13.7	11.7	(36)
		MCWBR	10.9	12.6	14.3	13.8	10.6	9.7	9.3	9.0	9.3	10.1	10.5	10.6	(37)
	5% WB	MCDBR	12.0	14.3	17.4	19.3	18.5	16.1	15.8	13.9	15.4	14.2	13.4	11.5	(38)
		MCWBR	11.4	12.7	14.4	14.1	11.0	9.4	9.7	8.9	9.5	10.3	11.2	10.8	(39)
(40) Clear-Sky Solar Irradiance	taub		0.307	0.333	0.356	0.398	0.431	0.445	0.438	0.425	0.384	0.365	0.325	0.314	(40)
	taud		2.389	2.283	2.304	2.262	2.215	2.225	2.269	2.293	2.382	2.409	2.486	2.443	(41)
	Ebn at Noon		265	274	281	276	269	265	265	265	269	260	258	252	(42)
	Edh at Noon		26	33	37	41	44	44	42	40	34	29	23	23	(43)
(44) All-Sky Solar Radiation	RadAvg		439	708	1091	1462	1726	1936	1935	1691	1361	883	549	378	(44)
	RadStd		50	86	101	118	144	123	104	67	117	70	76	36	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (59 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+175	N/A

Nomenclature: See separate page