

TRACADIE, NS, Canada

WMO: 713080

Lat: 45.608N

Lon: 61.680W

Elev: 67

StdP: 100.53

Time Zone: -4.00 (NAA)

Period: 03-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-17.2	-14.8	-21.7	0.5	-15.8	-19.2	0.7	-13.8	12.8	0.9	11.8	-0.2	5.2	250	0.646

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.3	27.6	21.2	26.0	20.5	24.5	19.6	22.5	26.0	21.6	24.6	20.7	23.3	4.9	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.2	16.0	24.5	20.5	15.3	23.6	19.6	14.5	22.6	66.4	26.1	63.3	24.7	60.0	23.5	25.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
11.2	9.9	8.9	-20.4	30.6	2.3	1.1	-22.0	31.4	-23.4	32.0	-24.7	32.6	-26.4	33.4		
			-20.8	24.1	2.3	0.6	-22.5	24.5	-23.8	24.9	-25.1	25.3	-26.7	25.8		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	7.1	-4.1	-4.8	-1.8	3.8	9.0	13.9	19.3	19.2	15.8	10.1	4.9	-0.5		
	DBStd	9.42	5.74	5.29	4.57	4.26	3.96	3.78	3.09	2.61	3.46	3.82	4.47	4.96		
	HDD10.0	2023	437	416	366	193	68	7	0	0	1	46	162	327		
	HDD18.3	4216	694	649	623	437	291	141	26	21	92	256	402	585		
	CDD10.0	977	1	0	1	7	37	123	289	286	174	49	10	1		
	CDD18.3	130	0	0	0	0	1	8	56	49	16	1	0	0		
	CDH23.3	587	0	0	1	2	13	47	279	193	53	1	0	0		
	CDH26.7	82	0	0	0	0	2	3	46	24	7	0	0	0		
(14) Wind	WSAvg	4.5	4.9	4.8	4.9	4.6	4.2	3.9	4.0	3.8	4.3	4.4	4.9	4.9		
(15) Precipitation	PrecAvg	1383	126	111	114	109	104	93	86	106	113	136	146	147		
	PrecMax	1684	183	175	199	194	187	158	157	280	371	250	234	310		
	PrecMin	1032	67	51	54	43	43	40	40	46	11	49	84	82		
	PrecStd	149	30	33	41	34	35	32	32	46	76	55	39	48		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.2	11.6	13.9	19.8	25.2	26.9	29.9	29.1	27.6	22.1	18.0	14.1		
		MCWB	12.3	10.7	10.6	13.0	17.3	19.5	22.0	22.2	22.0	18.5	16.1	13.1		
	2%	DB	9.9	8.0	9.8	15.6	20.7	24.6	28.0	27.0	24.7	19.9	16.3	11.7		
		MCWB	9.2	6.9	7.9	12.3	15.0	18.9	21.3	21.2	20.1	17.5	15.1	10.9		
	5%	DB	6.6	4.8	7.1	13.0	18.1	22.5	26.3	25.5	22.9	17.9	14.6	8.8		
		MCWB	5.6	3.4	5.0	10.8	13.4	17.4	20.9	20.3	19.2	15.9	13.4	8.1		
	10%	DB	3.5	2.1	4.6	10.6	15.9	20.5	24.7	24.0	21.3	16.3	12.2	6.2		
		MCWB	2.6	1.0	2.8	8.3	12.2	16.6	19.8	19.5	18.6	14.3	10.9	5.5		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.4	10.8	11.9	15.2	18.9	21.8	23.5	23.4	22.9	19.9	16.4	13.2		
		MCDB	13.2	11.5	13.3	17.8	24.4	25.7	28.0	27.3	25.5	21.4	17.6	13.9		
	2%	WB	9.3	7.1	8.2	13.0	16.3	20.1	22.6	22.3	21.3	17.9	15.3	10.9		
		MCDB	9.9	7.7	9.6	15.3	19.2	22.8	26.6	25.3	23.7	19.2	16.3	11.6		
	5%	WB	5.9	3.8	5.6	11.0	14.4	18.5	21.7	21.4	20.2	16.3	13.7	8.2		
		MCDB	6.7	4.5	6.7	12.5	16.9	21.2	25.1	24.2	22.2	17.8	14.6	8.8		
	10%	WB	2.7	1.1	2.9	8.5	12.4	16.9	20.7	20.5	19.0	14.4	11.1	5.6		
		MCDB	3.4	1.9	4.3	10.5	15.0	19.8	23.5	23.1	20.8	15.9	12.1	6.2		
(35) Mean Daily Temperature Range	5% DB	MDBR	7.3	7.3	7.0	7.4	8.5	8.5	8.3	7.9	7.8	6.7	6.6	6.3		
		MCDBR	11.0	11.2	11.6	11.7	12.6	11.8	10.3	10.0	9.8	8.9	9.4	10.1		
	5% WB	MCWBR	11.1	10.7	10.2	8.7	8.0	7.3	5.6	5.6	6.5	7.0	8.8	10.2		
		MCWBR	11.1	11.6	11.1	11.3	11.5	10.4	8.9	8.5	8.4	8.2	9.3	10.0		
(40) Clear-Sky Solar Irradiance	taub		0.294	0.295	0.319	0.350	0.371	0.386	0.413	0.398	0.354	0.333	0.319	0.296		
		taud	2.465	2.446	2.428	2.420	2.415	2.406	2.364	2.400	2.499	2.536	2.510	2.493		
	Ebn at Noon		821	893	914	910	897	882	851	851	866	838	784	779		
		Edh at Noon	68	84	98	109	113	115	118	110	92	77	66	61		
(44) All-Sky Solar Radiation	RadAvg		1.22	2.08	3.33	4.17	4.97	5.33	5.34	4.85	3.83	2.42	1.34	0.91		
	RadStd		0.09	0.20	0.22	0.34	0.51	0.47	0.36	0.33	0.28	0.22	0.15	0.07		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (34 neighbors)		N/A	N/A	N/A	N/A	N/A	+0.41	N/A	N/A	N/A	N/A

Nomenclature: See separate page