

NAPPAN, NS, Canada

WMO: 713110

Lat: 45.7596N

Lon: 64.2414W

Elev: 65

StdP: 14.66

Time Zone: -4.00 (NAA)

Period: 03-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-4.4	0.4	-12.3	2.8	-2.7	-7.7	3.6	1.8	29.9	30.6	27.7	31.0	8.5	190	0.639

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.3	79.7	69.3	77.4	67.8	75.4	66.4	71.6	77.2	70.0	75.0	68.3	73.2	10.7	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
69.6	109.0	75.1	68.1	103.3	73.5	66.4	97.4	71.7	35.4	77.5	34.0	75.0	32.7	73.0	76.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 26.2	23.1	20.5	DB	-11.8	84.7	5.4	1.9	-15.7	86.0	-18.9	87.1	-21.9	88.1	-25.8	89.5	(4)
(5)			WB	-12.2	74.8	5.3	1.2	-16.0	75.6	-19.1	76.3	-22.1	77.0	-25.9	77.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	43.8	20.7	21.3	28.4	40.1	50.2	58.5	66.1	65.3	58.3	48.7	38.3	27.7		
	DBStd	17.67	11.56	9.79	8.45	6.87	6.02	5.61	4.23	4.44	6.55	7.28	8.68	9.98		
	HDD50	3942	908	803	669	308	72	5	0	0	8	114	363	692		
	HDD65	7908	1373	1223	1134	747	459	204	38	50	215	508	801	1156		
	CDD50	1672	0	0	1	11	78	261	500	476	258	73	13	1		
	CDD65	157	0	0	0	0	0	9	72	60	15	1	0	0		
	CDH74	750	0	0	0	0	8	51	358	277	54	2	0	0		
	CDH80	54	0	0	0	0	0	2	28	17	7	0	0	0		
(14) Wind	WSAvg	9.4	10.4	10.3	10.8	10.3	9.4	8.4	7.7	7.6	8.4	9.0	10.1	10.3		
(15) Precipitation	PrecAvg	47.7	4.4	3.7	4.0	3.7	3.6	3.5	3.9	3.5	3.4	4.3	4.3	5.1		
	PrecMax	68.7	11.6	5.8	6.5	9.2	9.6	7.3	7.0	7.4	6.7	7.8	8.4	13.0		
	PrecMin	31.4	0.9	1.3	1.1	1.0	0.7	1.0	0.7	0.2	0.4	1.9	1.5	2.0		
	PrecStd	8.3	2.2	1.1	1.3	1.8	1.9	1.5	1.9	1.9	1.5	1.8	1.6	2.2		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	57.0	50.8	54.8	66.2	74.3	78.2	83.2	82.2	79.0	72.0	65.1	57.0		
		MCWB	54.5	49.3	48.2	56.2	60.8	66.3	72.0	71.0	69.5	64.6	61.4	55.4		
	2%	DB	47.8	43.4	48.6	61.0	69.2	75.2	80.1	79.2	74.8	67.1	60.6	51.6		
		MCWB	46.4	41.3	44.3	54.5	58.9	65.1	70.2	68.6	66.9	61.8	58.1	50.0		
	5%	DB	41.9	38.7	44.4	56.6	65.4	72.3	78.0	77.1	71.8	63.9	56.7	46.2		
		MCWB	40.0	36.3	41.0	50.6	56.4	62.9	68.5	67.4	65.6	59.9	53.8	44.6		
	10%	DB	36.7	35.5	40.4	52.7	61.9	69.7	75.7	75.0	69.1	60.8	52.5	41.6		
		MCWB	34.9	33.4	36.5	46.9	54.2	61.1	67.0	66.4	63.8	56.8	49.4	39.5		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	54.6	49.4	49.9	60.3	65.0	69.9	73.8	73.3	71.5	67.1	62.2	55.7		
		MCDB	56.5	51.1	53.2	63.5	71.9	75.2	80.5	79.1	75.9	69.5	64.8	57.2		
	2%	WB	46.6	41.6	45.6	55.8	61.1	67.4	72.0	71.3	69.0	63.2	58.5	50.3		
		MCDB	47.8	42.9	47.5	58.8	66.5	72.5	78.3	76.5	73.1	65.9	60.5	51.7		
	5%	WB	40.3	36.9	41.1	51.5	58.3	65.1	70.4	69.6	66.9	60.6	54.3	44.8		
		MCDB	41.7	38.4	43.8	55.5	63.4	70.7	75.7	74.7	70.5	63.3	56.2	46.0		
	10%	WB	35.1	33.6	36.8	47.8	55.4	62.6	68.6	67.9	64.8	57.3	49.7	40.0		
		MCDB	36.6	35.1	39.9	51.7	60.5	67.6	73.5	73.2	68.5	60.3	52.1	41.5		
(35) Mean Daily Temperature Range	5% DB	MDBR	16.1	16.1	15.3	16.5	18.3	17.4	17.3	17.8	17.7	15.9	14.2	13.6		
		MCDBR	22.0	18.4	20.6	23.3	24.2	22.4	20.8	20.5	19.2	18.8	18.8	18.7		
		MCWBR	21.6	17.1	16.8	17.0	15.5	13.7	12.2	11.9	12.6	14.2	16.9	18.7		
	5% WB	MCDBR	21.9	18.7	19.2	20.4	20.4	19.0	17.5	16.6	16.4	15.9	18.4	18.9		
		MCWBR	21.9	18.2	17.3	17.0	14.7	12.7	11.4	10.7	12.0	13.6	17.5	19.0		
(40) Clear-Sky Solar Irradiance	taub		0.297	0.289	0.324	0.350	0.373	0.389	0.417	0.396	0.357	0.327	0.306	0.289		
	taud		2.410	2.432	2.412	2.408	2.388	2.360	2.318	2.365	2.465	2.542	2.537	2.496		
	Ebn at Noon		257	285	288	289	284	279	269	270	273	268	254	250		
	Edh at Noon		23	27	32	35	37	38	39	36	30	24	20	19		
(44) All-Sky Solar Radiation	RadAvg		444	698	1075	1347	1576	1707	1750	1562	1237	785	435	331		
	RadStd		39	59	71	127	165	141	118	108	98	81	49	26		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (45 neighbors)	N/A	N/A	N/A	+1.44	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	+0.70	N/A	N/A	N/A	N/A

Nomenclature: See separate page