

NAPPAN, NS, Canada

WMO: 713110

Lat: 45.7596N

Lon: 64.2414W

Elev: 20

StdP: 101.09

Time Zone: -4.00 (NAA)

Period: 03-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-20.2	-17.6	-24.6	0.4	-19.3	-22.1	0.5	-16.8	13.4	-0.8	12.4	-0.5	3.8	190	0.639

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.6	26.5	20.7	25.2	19.9	24.1	19.1	22.0	25.1	21.1	23.9	20.2	22.9	4.8	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.9	15.6	24.0	20.0	14.8	23.0	19.1	13.9	22.1	64.6	25.3	61.3	23.9	58.2	22.8	24.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.7	10.3	9.2	-24.3	29.3	3.0	1.0	-26.5	30.0	-28.3	30.6	-29.9	31.2	-32.1	31.9		
(5)			-24.6	23.8	2.9	0.7	-26.7	24.2	-28.4	24.6	-30.1	25.0	-32.2	25.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	6.5	-6.3	-5.9	-2.0	4.5	10.1	14.7	19.0	18.5	14.6	9.3	3.5	-2.4	(6)
(7)		DBStd	9.82	6.42	5.44	4.69	3.82	3.35	3.11	2.35	2.47	3.64	4.04	4.82	5.54	(7)
(8)		HDD10.0	2190	504	446	372	171	40	3	0	0	4	63	202	384	(8)
(9)		HDD18.3	4393	763	679	630	415	255	113	21	28	119	282	445	642	(9)
(10)		CDD10.0	929	0	0	1	6	43	145	278	264	143	41	7	1	(10)
(11)		CDD18.3	87	0	0	0	0	0	5	40	33	8	1	0	0	(11)
(12)		CDH23.3	417	0	0	0	0	4	28	199	154	30	1	0	0	(12)
(13)		CDH26.7	30	0	0	0	0	0	1	16	9	4	0	0	0	(13)
(14)	Wind	WSAvg	4.2	4.7	4.6	4.8	4.6	4.2	3.7	3.5	3.4	3.7	4.0	4.5	4.6	(14)
(15)	Precipitation	PrecAvg	1212	112	94	102	95	92	89	100	89	86	109	110	130	(15)
(16)		PrecMax	1746	294	147	166	234	244	186	179	187	170	198	213	330	(16)
(17)		PrecMin	797	24	33	29	25	17	26	18	6	11	49	37	51	(17)
(18)		PrecStd	211	57	28	33	45	48	39	47	49	38	46	40	57	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.9	10.4	12.6	19.0	23.5	25.7	28.4	27.9	26.1	22.2	18.4	13.9	(19)
(20)			MCWB	12.5	9.6	9.0	13.4	16.0	19.1	22.2	21.7	20.8	18.1	16.3	13.0	(20)
(21)		2%	DB	8.8	6.3	9.2	16.1	20.7	24.0	26.7	26.2	23.8	19.5	15.9	10.9	(21)
(22)			MCWB	8.0	5.2	6.8	12.5	15.0	18.4	21.2	20.4	19.4	16.6	14.5	10.0	(22)
(23)		5%	DB	5.5	3.7	6.9	13.6	18.6	22.4	25.5	25.1	22.1	17.7	13.7	7.9	(23)
(24)			MCWB	4.5	2.4	5.0	10.3	13.5	17.2	20.3	19.7	18.7	15.5	12.1	7.0	(24)
(25)		10%	DB	2.6	2.0	4.7	11.5	16.6	20.9	24.3	23.9	20.6	16.0	11.4	5.3	(25)
(26)			MCWB	1.6	0.8	2.5	8.3	12.3	16.2	19.4	19.1	17.7	13.8	9.7	4.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.6	9.6	10.0	15.7	18.4	21.1	23.2	22.9	21.9	19.5	16.8	13.1	(27)
(28)			MCDB	13.6	10.6	11.8	17.5	22.2	24.0	26.9	26.2	24.4	20.8	18.2	14.0	(28)
(29)		2%	WB	8.1	5.4	7.6	13.2	16.2	19.7	22.2	21.9	20.6	17.3	14.7	10.2	(29)
(30)			MCDB	8.8	6.1	8.6	14.9	19.2	22.5	25.7	24.7	22.8	18.8	15.9	10.9	(30)
(31)		5%	WB	4.6	2.7	5.1	10.8	14.6	18.4	21.3	20.9	19.4	15.9	12.4	7.1	(31)
(32)			MCDB	5.4	3.6	6.6	13.0	17.4	21.5	24.3	23.7	21.4	17.4	13.4	7.8	(32)
(33)		10%	WB	1.7	0.9	2.7	8.8	13.0	17.0	20.3	19.9	18.2	14.1	9.8	4.4	(33)
(34)			MCDB	2.6	1.7	4.4	10.9	15.8	19.8	23.1	22.9	20.3	15.7	11.2	5.3	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.9	8.9	8.5	9.1	10.2	9.7	9.6	9.9	9.8	8.9	7.9	7.6	(35)
(36)			MCDBR	12.2	10.2	11.4	13.0	13.4	12.4	11.5	11.4	10.7	10.5	10.5	10.4	(36)
(37)			MCWBR	12.0	9.5	9.3	9.5	8.6	7.6	6.8	6.6	7.0	7.9	9.4	10.4	(37)
(38)		5% WB	MCDBR	12.2	10.4	10.7	11.3	11.3	10.5	9.7	9.2	9.1	8.9	10.2	10.5	(38)
(39)			MCWBR	12.2	10.1	9.6	9.5	8.1	7.1	6.3	6.0	6.7	7.6	9.7	10.6	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.297	0.289	0.324	0.350	0.373	0.389	0.417	0.396	0.357	0.327	0.306	0.289	(40)	
(41)		taud	2.410	2.432	2.412	2.408	2.388	2.360	2.318	2.365	2.465	2.542	2.537	2.496	(41)	
(42)		Ebn at Noon	809	899	908	910	894	878	847	852	861	844	801	787	(42)	
(43)		Edh at Noon	71	84	100	110	116	120	124	114	94	76	64	60	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.40	2.20	3.39	4.25	4.97	5.38	5.52	4.92	3.90	2.47	1.37	1.04	(44)	
(45)		RadStd	0.12	0.18	0.23	0.40	0.52	0.45	0.37	0.34	0.31	0.26	0.15	0.08	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	+0.80	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (45 neighbors)	N/A	N/A	N/A	N/A	N/A	+0.39	N/A	N/A	N/A	N/A

Nomenclature: See separate page