

BEAUCEVILLE, QC, Canada

WMO: 713230

Lat: 46.2050N

Lon: 70.7850W

Elev: 752

StdP: 14.30

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-15.2	-10.5	-23.1	1.6	-14.3	-18.4	2.1	-9.6	15.6	20.4	13.7	16.6	3.8	170	0.537

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.5	83.8	68.6	81.0	67.0	78.3	65.6	71.8	79.4	69.9	76.9	68.2	74.8	6.2	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
69.3	110.6	75.0	67.5	104.0	73.5	65.8	97.8	71.8	36.0	79.0	34.4	77.1	33.0	74.8	80.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
13.8	11.9	10.5	-24.1	88.8	6.2	2.4	-28.5	90.6	-32.2	92.0	-35.7	93.4	-40.2	95.2
			-24.7	74.7	6.3	2.0	-29.2	76.2	-32.9	77.4	-36.4	78.6	-40.9	80.0

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	40.8	12.6	15.4	25.3	38.7	52.1	61.1	65.9	63.9	56.4	44.5	32.4	20.0
	DBStd	20.69	13.19	11.73	11.09	8.12	7.66	6.67	5.27	5.47	7.35	7.88	9.43	11.34
	HDD50	5003	1160	969	767	349	65	3	0	0	20	209	531	930
	HDD65	9012	1625	1389	1231	788	405	154	52	87	273	635	978	1395
	CDD50	1659	0	0	1	11	131	335	494	432	213	39	3	0
	CDD65	193	0	0	0	0	5	37	81	54	16	0	0	0
	CDH74	1771	0	0	0	9	119	396	679	422	143	3	0	0
	CDH80	344	0	0	0	1	20	87	141	67	28	0	0	0
Wind	WSAvg	4.6	4.5	4.9	5.3	5.5	5.1	4.4	4.1	3.9	4.0	4.6	4.7	4.4
Precipitation	PrecAvg	44.7	3.2	2.6	2.9	3.2	3.7	4.6	4.7	4.8	4.0	4.1	3.3	3.8
	PrecMax	57.0	5.9	5.1	5.4	6.8	6.3	8.7	7.7	9.3	7.2	8.2	4.8	6.7
	PrecMin	33.2	1.4	1.0	1.2	0.9	1.5	1.9	1.3	0.9	1.5	1.3	1.0	2.0
	PrecStd	5.3	1.1	1.0	1.0	1.6	1.3	1.6	1.3	1.8	1.5	1.8	0.9	1.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	47.8	46.9	56.7	72.8	82.8	86.7	87.9	85.4	83.9	72.9	61.8	47.5
		MCWB	46.2	41.6	47.3	57.1	63.6	69.4	72.2	69.5	70.0	60.5	55.9	45.8
	2%	DB	40.4	40.2	49.1	64.3	77.3	82.4	83.8	81.7	78.0	67.1	55.2	42.0
		MCWB	39.1	36.8	40.5	50.3	59.8	67.0	69.3	67.7	66.5	57.9	49.9	40.1
	5%	DB	35.4	36.5	44.1	57.7	72.2	78.8	80.7	78.8	73.7	61.8	50.0	37.8
		MCWB	33.9	33.8	38.1	46.8	58.0	65.0	68.0	66.7	64.4	54.8	46.0	36.0
	10%	DB	31.7	33.3	40.3	52.6	67.4	74.8	77.8	75.7	69.6	57.2	45.5	34.7
		MCWB	30.4	31.2	36.0	43.7	55.7	63.0	66.0	65.4	62.4	52.2	42.4	33.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	45.8	42.8	49.5	59.5	67.6	72.9	74.8	73.0	71.7	63.6	57.0	46.3
		MCDB	47.0	45.5	53.8	70.1	75.8	82.9	82.8	80.9	79.9	68.9	59.9	47.4
	2%	WB	38.8	37.0	42.9	52.9	63.7	70.1	72.0	70.8	68.7	59.5	51.0	40.4
		MCDB	39.6	39.0	46.0	59.6	72.5	77.9	79.6	77.2	75.4	64.6	53.7	41.7
	5%	WB	33.6	33.8	39.2	48.5	60.6	67.5	70.1	68.9	66.1	55.9	46.6	36.4
		MCDB	34.7	35.7	43.0	55.3	68.0	74.9	77.1	75.0	71.9	61.2	49.0	37.8
	10%	WB	29.8	30.9	36.3	44.7	57.1	65.1	68.3	67.2	63.4	52.6	42.5	33.2
		MCDB	31.3	32.9	40.4	51.2	65.2	71.7	75.0	73.4	68.6	56.4	45.1	34.3
Mean Daily Temperature Range	5% DB	MDBR	17.6	19.5	18.5	18.3	21.4	20.6	19.5	19.9	20.3	16.8	13.8	14.2
		MCDBR	19.3	20.8	23.2	29.6	30.0	26.7	23.6	24.0	24.9	24.8	21.3	14.7
		MCWBR	19.1	17.5	16.5	17.6	15.3	13.6	11.3	12.2	14.2	16.4	17.2	14.3
	5% WB	MCDBR	18.8	19.0	19.5	25.8	23.8	22.3	19.8	19.3	21.5	21.9	19.4	15.0
		MCWBR	18.5	17.0	15.2	17.3	14.3	12.7	11.0	11.3	13.5	15.8	16.9	14.8
Clear-Sky Solar Irradiance	taub		0.252	0.275	0.316	0.337	0.358	0.403	0.408	0.390	0.363	0.330	0.301	0.283
	taud		2.373	2.275	2.271	2.398	2.411	2.271	2.277	2.333	2.406	2.496	2.495	2.336
	Ebn at Noon		275	287	289	292	288	274	271	272	270	265	253	244
	Edh at Noon		23	30	36	35	36	42	41	37	31	25	21	21
All-Sky Solar Radiation	RadAvg		447	730	1118	1401	1586	1748	1727	1509	1201	697	410	302
	RadStd		65	93	89	131	171	114	161	94	104	61	52	31

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (28 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page