

OSBORNE HEAD, NS, Canada

WMO: 713240

Lat: 44.6133N

Lon: 63.4222W

Elev: 98

StdP: 14.64

Time Zone: -4.00 (NAA)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	5.2	9.1	-4.4	4.4	8.0	-1.3	5.2	12.0	46.7	33.3	41.5	33.2	14.7	280	0.746

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.5	74.6	63.5	71.4	63.5	69.1	63.4	68.0	70.3	66.4	68.5	65.2	67.2	12.5	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
67.1	100.0	69.0	65.6	94.8	67.4	64.4	90.8	66.1	32.4	70.3	31.1	68.7	30.2	67.3	74.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
36.4	31.3	27.4	DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	44.7	26.0	25.9	30.9	39.0	47.0	54.8	61.9	64.2	59.9	51.4	41.5	32.4
	DBStd	14.78	9.28	7.73	7.04	5.14	4.79	5.31	3.79	3.35	4.82	6.14	6.96	8.65
	HDD50	3345	743	674	594	332	119	15	0	0	1	58	263	546
	HDD65	7470	1208	1094	1057	780	557	310	110	53	163	423	704	1011
	CDD50	1405	0	0	2	2	27	157	369	441	297	101	9	0
	CDD65	56	0	0	0	0	0	2	14	30	9	1	0	0
	CDH74	122	0	0	0	0	2	22	29	52	14	3	0	0
	CDH80	15	0	0	0	0	0	3	2	9	1	0	0	0
(14) Wind	WSAvg	13.2	15.3	14.8	14.9	13.8	12.2	11.1	10.3	10.4	12.0	13.8	14.6	15.0
(15) Precipitation	PrecAvg	55.7	5.2	4.5	4.8	4.3	4.4	4.1	4.0	3.8	3.8	5.0	5.5	5.9
	PrecMax	70.7	10.7	9.0	9.6	8.2	8.4	13.7	9.0	12.6	8.9	10.1	10.2	10.0
	PrecMin	38.7	1.7	1.3	1.8	0.7	1.0	1.3	0.5	1.0	1.1	1.3	1.5	2.6
	PrecStd	7.8	1.9	1.9	1.8	1.7	1.8	2.2	1.9	2.4	1.8	2.0	2.2	2.0
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	47.0	44.1	57.5	60.2	70.1	76.5	77.5	79.1	75.9	69.8	59.1	51.1
		MCWB	45.7	42.7	49.0	48.5	54.8	62.0	63.6	65.9	67.2	60.4	56.1	49.9
	2%	DB	44.8	41.0	46.2	53.6	60.9	70.5	73.4	74.3	71.1	64.2	56.1	49.1
		MCWB	43.5	39.8	39.5	43.6	50.5	58.9	63.4	63.8	64.8	60.7	54.0	48.1
	5%	DB	42.2	38.7	42.3	48.6	57.1	65.8	69.8	71.1	68.4	62.0	54.1	47.2
		MCWB	41.1	37.4	38.7	42.2	49.0	57.8	62.9	65.1	63.4	59.4	52.4	46.2
	10%	DB	39.4	36.6	39.6	45.8	53.9	61.9	67.0	69.1	66.7	60.1	52.0	45.2
		MCWB	38.1	35.3	36.6	42.0	48.6	56.6	62.9	64.8	62.7	57.5	50.0	43.9
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.6	43.2	51.2	51.6	57.9	65.4	68.0	70.6	70.5	64.6	58.3	50.4
		MCDB	47.1	43.4	56.0	58.0	64.2	74.2	71.8	75.5	73.4	66.2	58.7	50.7
	2%	WB	44.0	40.1	42.1	46.8	53.6	61.7	65.8	68.5	67.4	62.2	54.8	48.3
		MCDB	44.5	40.7	44.6	49.4	57.5	66.9	68.8	70.8	68.9	63.4	55.4	48.9
	5%	WB	41.1	37.7	39.3	44.7	51.0	59.3	64.7	67.0	65.6	60.0	52.9	46.5
		MCDB	41.8	38.4	41.3	46.5	54.8	63.4	67.1	68.9	67.1	61.4	53.9	47.2
	10%	WB	38.3	35.5	37.1	42.5	49.1	57.5	63.7	65.7	63.9	58.1	50.5	44.2
		MCDB	39.5	36.4	39.2	45.2	52.4	60.4	65.9	67.5	65.6	59.8	51.6	45.2
(35) Mean Daily Temperature Range	5% DB	MDBR	13.0	11.8	11.7	10.9	10.8	10.6	9.3	9.5	10.7	10.8	10.6	11.8
		MCDBR	14.8	12.4	14.9	17.0	17.9	18.7	15.3	13.2	12.2	11.5	12.2	13.2
		MCWBR	15.6	12.7	12.5	11.0	10.6	10.1	8.0	7.1	8.4	9.4	12.2	13.9
	5% WB	MCDBR	14.2	12.9	13.6	13.6	15.4	15.0	10.9	9.2	9.2	10.1	11.7	13.1
		MCWBR	15.2	13.7	12.9	10.8	10.9	9.8	7.2	6.3	7.6	9.7	12.6	14.0
(40) Clear-Sky Solar Irradiance	taub		0.303	0.298	0.324	0.349	0.369	0.400	0.415	0.396	0.353	0.333	0.317	0.297
	taud		2.474	2.517	2.475	2.448	2.438	2.381	2.359	2.411	2.502	2.554	2.550	2.535
	Ebn at Noon		260	286	290	290	286	276	270	272	277	268	254	253
	Edh at Noon		22	25	30	34	35	37	38	35	29	24	21	19
(44) All-Sky Solar Radiation	RadAvg		453	738	1120	1368	1570	1706	1691	1582	1291	837	482	359
	RadStd		34	55	76	111	201	160	123	110	85	87	52	28

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (32 neighbors)	N/A	N/A	N/A	N/A	+0.67	+0.90	N/A	N/A	+101	+31

Nomenclature: See separate page