

BEDFORD RANGE, NS, Canada

WMO: 713250

Lat: 44.747N

Lon: 63.665W

Elev: 31

StdP: 14.68

Time Zone: -4.00 (NAA)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-0.2	4.8	-6.4	3.9	3.9	-3.0	4.7	8.5	20.9	30.8	19.0	26.9	3.2	320	0.537

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.6	82.8	68.1	79.9	66.8	77.4	65.5	71.4	78.9	69.7	76.6	68.1	73.9	7.2	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
69.0	106.7	75.1	67.3	100.4	73.1	65.8	95.2	71.6	35.2	78.6	33.7	76.8	32.4	74.0	77.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 17.9	15.5	13.6	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			-5.3	74.3	5.4	1.7	-9.2	75.5	-12.4	76.5	-15.5	77.5	-19.4	78.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	45.4	24.6	24.9	30.8	40.8	50.1	58.7	66.9	66.3	59.7	49.3	40.0	30.9		
	DBStd	16.55	10.39	9.36	8.15	6.29	5.68	5.60	4.27	4.30	6.49	7.11	8.15	9.34		
	HDD50	3458	786	704	598	286	67	5	0	0	5	101	314	592		
	HDD65	7364	1251	1124	1061	727	463	200	29	36	180	486	750	1057		
	CDD50	1768	0	0	2	9	70	266	523	506	296	80	15	1		
	CDD65	198	0	0	0	0	1	11	87	77	22	0	0	0		
	CDH74	1492	0	0	6	3	44	166	649	497	123	4	0	0		
	CDH80	273	0	0	1	0	12	32	133	69	26	0	0	0		
	WSAvg	5.7	5.9	6.4	6.8	6.7	6.1	5.5	4.7	4.5	4.7	5.1	5.7	5.8		
	PrecAvg	55.9	4.9	4.5	4.7	4.0	4.8	3.9	3.6	3.8	4.6	5.6	5.8	5.6		
(15) Precipitation	PrecMax	67.1	8.5	8.2	9.8	7.2	12.4	9.3	8.6	10.4	13.9	12.5	10.3	9.4		
	PrecMin	45.2	1.8	1.3	1.7	1.4	2.1	1.0	0.7	1.7	1.5	1.6	3.2	2.6		
	PrecStd	6.1	1.5	1.9	2.1	1.4	2.2	1.9	1.8	2.0	3.0	2.4	1.9	1.7		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.9	52.8	60.2	67.4	80.2	83.9	89.2	85.5	82.9	73.2	64.1	57.0		
		MCWB	51.3	49.9	49.9	53.1	60.7	65.9	70.7	70.6	70.5	61.5	60.3	56.0		
	2%	DB	48.4	46.6	51.2	60.1	70.9	78.3	83.3	81.8	77.0	67.9	60.4	52.9		
		MCWB	46.8	44.0	44.0	48.8	56.9	64.0	68.4	68.2	66.5	60.8	57.0	51.1		
	5%	DB	44.5	41.9	46.4	56.4	66.2	74.6	80.3	79.1	73.7	64.5	57.6	49.5		
		MCWB	42.4	39.1	41.0	47.8	54.3	61.8	67.4	66.8	64.9	59.3	54.8	47.9		
	10%	DB	39.9	37.9	42.8	52.5	61.8	70.9	77.5	76.6	70.8	61.9	54.3	45.7		
		MCWB	37.6	34.8	38.0	46.3	51.9	59.9	66.0	65.3	63.3	57.6	51.6	44.0		
	0.4%	WB	51.5	50.8	52.1	57.1	64.1	70.0	73.6	73.4	72.1	65.8	61.3	56.0		
		MCDB	52.7	52.4	57.4	62.0	74.4	80.5	82.0	81.1	78.7	69.5	63.7	57.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	46.9	44.3	45.8	53.8	59.5	66.5	71.7	71.1	69.1	62.6	58.0	51.4		
		MCDB	48.0	46.1	49.0	57.0	67.2	75.2	79.6	77.8	74.5	65.5	59.9	52.7		
	5%	WB	42.7	39.6	42.0	50.2	56.3	63.8	69.9	69.5	67.2	60.6	55.1	48.1		
		MCDB	44.1	41.5	45.4	53.3	63.5	70.7	77.4	75.6	71.4	63.5	57.1	49.5		
	10%	WB	38.0	35.3	38.2	47.3	53.3	61.6	68.2	67.7	65.3	57.9	51.8	44.1		
		MCDB	39.8	37.4	42.0	51.5	59.2	68.2	74.7	73.3	69.4	61.5	54.2	45.7		
	5% DB	MDBR	17.3	16.3	16.8	17.6	19.1	18.6	18.6	19.4	19.5	18.4	15.5	14.9		
		MCDBR	20.5	18.7	23.2	25.5	28.0	26.9	24.0	23.7	22.3	21.9	18.5	18.3		
		MCWBR	20.1	16.8	17.3	16.2	15.5	14.0	11.5	12.0	13.2	15.1	16.6	18.4		
		MCWBR	20.4	18.4	21.5	19.2	22.7	21.7	19.5	18.2	17.6	17.6	17.2	18.1		
(35) Clear-Sky Solar Irradiance	taub		0.305	0.295	0.325	0.349	0.370	0.399	0.416	0.397	0.355	0.331	0.315	0.296		
		taud	2.453	2.517	2.468	2.442	2.427	2.370	2.345	2.391	2.484	2.550	2.550	2.532		
	Ebn at Noon		259	287	290	290	285	276	270	271	276	269	255	252		
		Edh at Noon	23	25	30	34	36	38	38	35	30	24	21	19		
(44) All-Sky Solar Radiation	RadAvg		453	732	1110	1360	1567	1705	1705	1584	1281	828	474	354		
	RadStd		35	55	76	115	197	158	124	110	87	87	51	27		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (33 neighbors)	N/A	N/A	N/A	N/A	+0.65	+0.90	N/A	N/A	+90	+25	

Nomenclature: See separate page