

BEDFORD BASIN, NS, Canada

WMO: 713290

Lat: **44.710N**Lon: **63.630W**Elev: **11**StdP: **14.69**Time Zone: **-4.00 (NAA)**Period: **04-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	7.4	11.0	0.5	5.6	11.0	3.3	6.5	14.7	35.3	47.8	30.9	37.1	9.9	320	0.597

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	13.6	80.4	67.1	77.5	66.0	75.0	65.1	70.7	76.0	69.1	74.0	67.5	71.9	9.2	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
69.1	107.0	72.2	67.4	100.7	71.0	65.8	95.1	70.0	34.6	76.3	33.2	74.2	32.0	71.9	74.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 28.4	24.7	21.3	1.4	87.2	5.3	3.2	-2.5	89.5	-5.6	91.4	-8.6	93.2	-12.4	95.5		
(5)			0.7	72.9	5.2	1.1	-3.1	73.7	-6.1	74.3	-9.0	75.0	-12.7	75.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	47.0	27.3	27.6	32.5	41.8	50.2	58.9	67.1	67.5	61.7	52.4	42.7	33.3		
	DBStd	15.62	8.93	7.98	7.39	5.73	5.16	5.37	4.27	3.72	5.34	6.28	7.25	8.33		
	HDD50	2990	703	626	544	253	60	4	0	0	0	46	237	517		
	HDD65	6784	1168	1046	1007	697	461	194	26	17	126	390	670	982		
	CDD50	1907	0	0	2	6	65	269	529	543	352	122	18	1		
	CDD65	224	0	0	0	0	1	10	90	95	27	1	0	0		
	CDH74	770	0	0	1	0	11	62	351	287	56	2	0	0		
	CDH80	111	0	0	0	0	0	10	60	38	3	0	0	0		
	WSAvg	9.2	10.9	11.0	10.7	10.0	8.8	8.1	7.2	7.1	7.6	9.2	9.9	10.5		
	PrecAvg	55.9	4.9	4.5	4.7	4.0	4.8	3.9	3.6	3.8	4.6	5.6	5.8	5.6		
(15) Precipitation	PrecMax	67.1	8.5	8.2	9.8	7.2	12.4	9.3	8.6	10.4	13.9	12.5	10.3	9.4		
	PrecMin	45.2	1.8	1.3	1.7	1.4	2.1	1.0	0.7	1.7	1.5	1.6	3.2	2.6		
	PrecStd	6.1	1.5	1.9	2.1	1.4	2.2	1.9	1.8	2.0	3.0	2.4	1.9	1.7		
	PrecStd	6.1	1.5	1.9	2.1	1.4	2.2	1.9	1.8	2.0	3.0	2.4	1.9	1.7		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	51.3	50.1	57.7	62.8	74.5	80.4	85.7	84.8	79.1	72.2	61.7	55.9		
		MCWB	50.3	47.8	42.4	49.8	59.4	66.6	68.9	69.6	67.0	62.4	58.7	54.6		
	2%	DB	47.1	45.0	50.0	57.6	66.7	74.6	81.1	79.8	75.3	67.4	59.0	51.7		
		MCWB	45.6	43.0	43.4	47.5	54.9	62.3	67.1	67.2	65.2	60.4	56.5	50.3		
	5%	DB	43.9	41.8	45.8	54.2	62.4	71.2	77.6	77.0	72.3	64.2	56.6	49.1		
		MCWB	42.2	39.5	40.7	47.0	53.2	60.7	66.5	65.9	63.7	59.3	54.6	47.7		
	10%	DB	40.3	38.8	42.6	51.0	58.9	68.1	75.1	74.5	69.9	62.0	54.1	45.9		
		MCWB	38.3	36.7	38.6	44.7	51.1	59.1	65.6	65.3	63.3	57.7	51.9	44.3		
	0.4%	WB	50.4	48.9	47.6	55.0	62.4	68.0	72.5	72.8	70.1	66.5	60.4	54.4		
		MCDB	50.9	49.8	49.3	58.1	71.2	75.9	77.3	78.1	74.4	68.7	61.2	55.2		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	46.1	43.9	44.1	51.2	58.1	65.5	70.7	70.9	68.1	62.6	57.4	50.4		
		MCDB	46.7	45.1	46.2	54.9	63.1	71.6	76.3	76.3	71.5	64.6	58.5	51.4		
	5%	WB	42.3	40.4	41.4	48.4	55.1	63.5	69.1	69.2	66.7	60.6	55.1	47.7		
		MCDB	43.5	41.6	43.8	51.3	59.6	67.7	74.9	73.6	70.1	62.7	56.1	48.7		
	10%	WB	38.4	37.1	38.6	45.9	52.6	61.4	67.5	67.6	64.9	58.4	51.9	44.3		
		MCDB	40.0	38.7	41.5	49.6	57.0	65.9	72.5	71.4	68.8	61.1	53.6	45.5		
	5% DB	MDBR	13.6	13.0	13.2	13.3	13.8	13.8	13.5	13.6	14.3	12.6	11.7	12.0		
		MCDBR	17.0	15.0	17.6	19.1	20.8	20.0	18.4	17.8	16.4	14.5	13.9	15.0		
		MCWBR	17.6	14.3	13.1	12.2	11.5	10.0	7.8	7.6	9.2	9.4	13.0	16.1		
		MCWBR	17.3	15.5	15.4	15.4	17.0	16.1	14.4	13.3	13.0	11.5	12.9	15.0		
(35) Mean Daily Temperature Range	5% WB	MCWBR	18.1	15.6	14.4	12.1	11.5	9.8	7.7	7.1	9.1	10.3	13.5	15.9		
		MCWBR	18.1	15.6	14.4	12.1	11.5	9.8	7.7	7.1	9.1	10.3	13.5	15.9		
	Clear-Sky Solar Irradiance	taub	0.305	0.296	0.325	0.350	0.371	0.400	0.416	0.398	0.355	0.332	0.316	0.297		
		taud	2.457	2.517	2.469	2.442	2.428	2.371	2.346	2.394	2.487	2.550	2.549	2.532		
(42) All-Sky Solar Radiation	RadAvg	Ebn at Noon	259	286	290	290	285	276	270	271	276	268	254	252		
		Edh at Noon	23	25	30	34	36	38	38	35	30	24	21	19		
(44) All-Sky Solar Radiation	RadStd	RadAvg	454	734	1113	1362	1568	1706	1702	1584	1284	831	476	355		
		RadStd	35	55	76	114	199	158	124	110	87	87	51	27		

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
Station Only		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (33 neighbors)		N/A	N/A	N/A	N/A	+0.65	+0.90	N/A	N/A	+90	+25

Nomenclature: See separate page