

SAGLEK, NL, Canada

WMO: 713350

Lat: **58.488N**Lon: **62.586W**Elev: **1693**StdP: **13.82**Time Zone: **-4.00 (NAA)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-21.1	-17.0	N/A	N/A	N/A	N/A	N/A	N/A	60.9	-6.9	55.8	0.8	25.3	260	1.115

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.9	66.9	N/A	63.0	N/A	59.1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	15.1	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 50.8	43.5	39.1	DB	-24.8	71.7	5.5	4.3	-28.8	74.8	-32.1	77.3	-35.2	79.7	-39.2	82.9	(4)
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	23.5	0.8	-0.5	6.4	17.7	27.9	37.5	46.1	46.5	37.9	29.9	20.0	10.5	
	DBStd	18.23	11.06	10.60	10.98	9.12	8.01	7.77	8.21	7.51	6.69	5.71	6.19	9.83	
	HDD50	9792	1526	1414	1351	969	688	385	176	164	370	624	900	1225	
	HDD65	15140	1991	1834	1816	1419	1150	825	587	576	813	1089	1350	1690	
	CDD50	130	0	0	0	0	3	10	56	54	7	0	0	0	
	CDD65	4	0	0	0	0	0	1	2	1	0	0	0	0	
	CDH74	5	0	0	0	0	0	3	2	0	0	0	0	0	
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	
Wind	WSAvg	16.5	18.8	17.9	18.0	17.2	15.1	14.2	13.4	14.4	16.2	15.1	17.8	19.6	
Precipitation	PrecAvg	28.7	2.0	1.6	1.7	1.7	1.5	2.5	3.8	2.8	3.6	3.1	2.4	2.1	
	PrecMax	36.3	4.0	3.6	4.3	3.9	3.3	4.8	5.8	4.0	7.0	6.2	4.4	5.1	
	PrecMin	22.1	0.3	0.1	0.2	0.6	0.3	1.2	2.3	1.4	1.5	1.7	0.9	0.4	
	PrecStd	3.1	0.9	0.9	1.0	0.8	0.7	0.7	0.9	0.7	1.3	1.0	0.8	1.1	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	31.4	30.3	38.2	45.4	61.5	67.1	72.5	71.1	64.3	51.5	37.7	34.6	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	27.6	26.7	29.7	39.4	52.7	59.1	67.4	66.7	58.5	46.1	33.6	30.7	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	22.5	20.6	26.1	34.6	46.2	54.6	63.1	63.1	52.9	41.5	30.9	27.4	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	10%	DB	16.8	14.7	22.5	30.8	40.2	49.9	58.8	58.7	48.4	37.8	28.1	23.6	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	8.8	9.3	9.9	9.7	9.4	10.2	10.5	9.9	8.5	6.4	6.0	7.4	
		MCDBR	12.8	14.6	15.2	14.5	17.5	18.2	15.1	15.5	15.5	13.2	9.5	7.3	
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		Clear-Sky Solar Irradiance	taub	0.207	0.231	0.275	0.329	0.322	0.325	0.340	0.325	0.303	0.276	0.229	0.201
taud	2.156		2.217	2.122	1.993	2.163	2.403	2.480	2.544	2.568	2.527	2.290	2.099		
Ebn at Noon	212		262	276	275	288	289	282	280	270	247	202	170		
Edh at Noon	14		23	34	46	42	34	31	27	23	17	13	11		
All-Sky Solar Radiation	RadAvg	159	448	914	1409	1760	1610	1449	1192	792	379	164	90		
	RadStd	17	46	105	153	157	121	107	128	66	33	17	10		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page