

LA SCIE, NL, Canada

WMO: 713370

Lat: 49.913N

Lon: 55.671W

Elev: 194

StdP: 99.02

Time Zone: -3.50 (NAF)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-18.4	-16.5	-22.1	0.5	-17.7	-20.0	0.6	-15.7	13.2	-4.6	11.9	-4.7	4.6	280	0.720

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.4	26.3	18.6	24.3	17.8	22.5	17.0	20.1	23.9	19.0	22.3	17.9	21.2	5.0	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.8	13.9	22.1	17.7	13.0	20.9	16.6	12.1	19.8	58.8	24.2	55.0	22.4	51.4	21.2	24.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.2	9.9	8.8	DB	-21.2	30.1	2.0	1.3	-22.6	31.0	-23.8	31.8	-24.9	32.5	-26.3	33.4	(4)
(5)			WB	-21.6	22.3	2.0	0.9	-23.0	23.0	-24.2	23.6	-25.3	24.1	-26.7	24.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	3.6	-7.2	-7.3	-4.5	0.4	5.3	10.5	15.8	15.8	11.5	5.9	0.8	-4.1	(6)	
	DBStd	9.14	4.68	4.83	4.37	3.51	4.24	4.99	4.03	3.56	3.88	3.66	3.87	4.26	(7)	
	HDD10.0	2851	534	483	449	288	158	54	5	2	27	137	276	437	(8)	
	HDD18.3	5399	792	717	708	538	403	238	99	92	207	384	525	696	(9)	
	CDD10.0	533	0	0	0	0	13	70	183	183	72	11	1	0	(10)	
	CDD18.3	39	0	0	0	0	0	4	19	14	3	0	0	0	(11)	
	CDH23.3	270	0	0	0	0	4	42	128	78	17	1	0	0	(12)	
	CDH26.7	40	0	0	0	0	1	6	21	11	2	0	0	0	(13)	
(14) Wind	WSAvg	4.3	4.9	4.7	4.8	4.4	3.8	3.7	3.5	3.5	4.1	4.2	4.6	4.9	(14)	
(15) Precipitation	PrecAvg	1157	93	91	84	78	88	92	102	109	107	116	101	106	(15)	
	PrecMax	1490	156	233	179	163	173	155	159	156	250	228	152	185	(16)	
	PrecMin	907	44	36	32	27	29	42	37	35	33	47	54	53	(17)	
	PrecStd	132	35	40	37	36	29	32	36	35	48	47	29	38	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.8	7.1	8.6	14.3	23.4	27.6	28.9	28.1	25.7	18.7	13.9	8.3	(19)	
		MCWB	7.5	6.6	5.1	8.8	14.7	18.4	19.7	20.5	18.4	14.5	12.4	7.5	(20)	
	2%	DB	4.0	3.9	4.8	10.2	18.9	24.2	26.6	25.4	21.9	15.8	11.5	5.2	(21)	
		MCWB	3.7	3.1	2.7	6.7	12.3	16.8	18.8	18.6	17.0	12.7	10.7	4.7	(22)	
	5%	DB	1.1	1.2	2.8	7.8	15.6	21.6	24.5	23.6	19.7	13.6	9.1	3.2	(23)	
		MCWB	0.7	0.4	1.1	4.8	10.6	15.7	17.9	17.9	15.7	11.6	8.1	2.9	(24)	
	10%	DB	-0.7	-0.6	1.1	5.8	12.7	19.0	22.5	21.8	17.7	11.6	6.6	1.6	(25)	
		MCWB	-1.1	-1.1	-0.2	3.4	8.6	14.2	17.2	17.1	14.5	9.8	5.6	1.3	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.7	6.7	5.6	10.1	16.0	20.2	21.8	21.7	19.6	15.7	12.9	7.6	(27)	
		MCDB	7.9	7.0	7.5	12.8	20.3	24.3	26.9	26.2	22.2	17.5	13.6	8.0	(28)	
	2%	WB	3.7	3.2	3.2	7.5	13.4	18.1	20.2	20.1	17.9	13.4	10.7	4.7	(29)	
		MCDB	4.0	3.7	4.5	9.4	17.6	22.1	24.2	23.7	20.5	14.5	11.2	5.0	(30)	
	5%	WB	0.8	0.6	1.4	5.5	11.2	16.3	19.1	18.9	16.3	11.6	8.2	2.8	(31)	
		MCDB	1.0	1.1	2.5	7.5	14.9	20.4	22.6	22.1	18.9	13.0	8.9	3.0	(32)	
	10%	WB	-1.0	-1.0	0.0	3.6	9.0	14.6	17.9	17.8	14.7	9.7	5.7	1.2	(33)	
		MCDB	-0.8	-0.7	0.9	5.5	12.4	18.8	21.3	20.9	17.2	11.3	6.4	1.4	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	7.0	7.6	7.4	7.0	8.6	9.2	9.4	8.5	8.0	6.5	5.5	5.7	(35)	
		MCDBR	9.0	9.7	9.7	10.7	14.4	13.4	12.3	11.2	10.9	9.8	8.8	7.6	(36)	
	5% WB	MCWBR	9.1	9.2	8.1	7.7	9.2	7.8	6.9	6.6	7.3	7.6	8.6	7.6	(37)	
		MCWBR	8.9	9.0	9.0	10.0	13.3	12.3	11.1	10.2	10.2	9.1	8.9	7.5	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.287	0.287	0.316	0.343	0.361	0.374	0.398	0.376	0.354	0.324	0.300	0.292	(40)	
		taud	2.387	2.378	2.300	2.335	2.407	2.417	2.396	2.453	2.500	2.539	2.506	2.363	(41)	
	Ebn at Noon	Ebn at Noon	763	863	890	902	897	885	856	860	845	814	750	693	(42)	
		Edh at Noon	64	81	105	114	111	111	112	101	87	70	57	57	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	0.84	1.63	2.85	3.98	4.78	5.08	5.24	4.31	3.21	1.95	1.01	0.64	(44)	
	RadStd	RadStd	0.07	0.21	0.34	0.47	0.44	0.54	0.43	0.29	0.27	0.21	0.10	0.05	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (14 neighbors)	N/A	N/A	+1.31	N/A	+0.42	+0.57	N/A	N/A	N/A	N/A

Nomenclature: See separate page