

BROCKET AGDM, AB, Canada

WMO: 713410

Lat: 49.6107N

Lon: 113.7591W

Elev: 1073

StdP: 89.08

Time Zone: -7.00 (NAM)

Period: 02-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-26.4	-23.0	-30.0	0.3	-26.2	-26.3	0.4	-22.7	19.5	-0.6	18.0	0.6	3.2	310	0.772

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.4	30.9	15.7	29.0	15.1	27.0	14.8	17.9	26.1	16.8	25.6	15.8	24.4	5.3	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.0	12.1	21.8	13.6	11.1	20.0	12.5	10.3	18.5	55.0	25.8	51.3	25.6	48.2	24.4	23.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 17.9	15.6	13.5	DB	-30.5	34.2	5.2	2.1	-34.2	35.7	-37.3	36.9	-40.2	38.1	-44.0	39.6	(4)
(5)			WB	-30.7	20.7	5.2	1.6	-34.4	21.9	-37.4	22.8	-40.3	23.6	-44.0	24.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	5.9	-3.8	-4.6	-0.5	5.0	10.0	14.1	17.9	17.3	12.6	6.3	0.4	-4.2
	DBStd	10.05	8.25	8.10	7.68	5.06	4.49	3.13	3.05	3.40	4.78	5.53	6.94	7.67
	HDD10.0	2280	429	409	326	161	56	4	0	1	27	137	291	440
	HDD18.3	4592	686	643	583	401	259	131	44	58	178	373	538	698
	CDD10.0	798	1	0	1	10	57	127	246	229	105	22	2	0
	CDD18.3	70	0	0	0	0	1	4	31	28	6	0	0	0
	CDH23.3	1542	0	0	0	3	51	120	616	573	172	6	0	0
	CDH26.7	482	0	0	0	0	9	24	211	192	45	1	0	0
Wind	WSAvg	5.8	7.5	6.0	6.1	5.7	5.2	5.0	4.2	4.1	5.0	6.1	7.1	7.1
Precipitation	PrecAvg	535	21	20	29	44	75	114	51	46	46	26	26	22
	PrecMax	868	37	49	67	90	154	375	187	121	151	52	58	58
	PrecMin	306	5	1	8	12	4	33	0	1	6	3	4	4
	PrecStd	150	8	12	14	19	43	76	45	33	34	16	15	12
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.3	12.4	16.4	23.0	28.0	29.9	33.7	33.0	30.5	23.2	16.8	10.4
		MCWB	6.0	4.7	7.0	9.6	13.0	16.9	16.5	15.3	14.0	11.7	8.0	5.1
	2%	DB	9.6	9.5	13.3	19.3	24.5	26.3	31.2	30.8	27.9	19.6	13.0	8.3
		MCWB	4.2	3.5	5.8	8.6	11.9	15.4	16.4	15.1	13.4	10.2	6.6	3.6
	5%	DB	7.5	7.3	11.3	16.4	21.6	24.3	29.0	28.8	25.2	16.9	10.7	6.6
		MCWB	2.9	2.2	4.9	7.2	10.8	14.4	16.0	14.7	12.8	9.1	5.4	2.5
	10%	DB	5.6	5.5	9.1	13.4	19.0	22.0	26.9	26.7	22.0	14.3	8.7	5.1
		MCWB	1.8	1.2	3.7	5.8	9.7	13.2	15.8	14.3	11.6	7.6	4.1	1.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.9	5.6	8.0	10.8	14.3	18.7	20.1	17.9	15.7	12.6	8.8	6.0
		MCDB	11.6	10.6	14.8	21.2	24.6	27.2	27.6	26.9	26.0	20.4	15.1	9.8
	2%	WB	4.5	3.9	6.5	9.1	12.5	16.7	18.5	16.9	14.2	10.7	7.2	4.2
		MCDB	9.0	9.0	12.3	17.9	22.1	24.4	26.6	26.5	25.2	18.4	12.4	7.4
	5%	WB	3.1	2.5	5.1	7.7	11.3	15.2	17.5	15.9	13.2	9.4	5.6	2.9
		MCDB	6.7	6.9	10.6	15.5	20.3	22.3	25.8	25.2	23.3	16.1	10.2	6.2
	10%	WB	2.0	1.2	3.9	6.2	10.3	13.9	16.5	15.0	12.0	7.9	4.3	1.6
		MCDB	5.5	5.3	8.9	12.7	18.1	20.7	24.9	24.5	21.5	13.7	8.5	5.0
Mean Daily Temperature Range	5% DB	MDBR	9.6	10.7	10.8	11.8	12.4	12.4	15.4	15.6	13.3	11.1	9.1	8.9
		MCDBR	9.5	11.8	13.3	16.9	17.4	17.1	19.6	19.9	19.3	14.2	10.3	8.5
		MCWBR	6.2	7.4	7.5	8.4	7.6	8.2	8.0	7.4	7.8	7.1	6.2	5.8
	5% WB	MCDBR	9.1	11.8	12.5	16.0	15.6	15.5	16.7	17.0	17.7	14.0	10.1	8.9
MCWBR		6.6	7.8	7.4	8.2	7.1	8.1	8.1	7.2	7.5	7.3	6.4	6.5	
Clear-Sky Solar Irradiance	taub	0.250	0.259	0.285	0.333	0.340	0.334	0.336	0.351	0.316	0.285	0.262	0.234	
	taud	2.405	2.420	2.438	2.334	2.388	2.446	2.449	2.394	2.470	2.532	2.488	2.428	
	Ebn at Noon	826	907	934	913	918	924	916	884	888	865	808	803	
	Edh at Noon	61	78	92	114	113	108	106	107	89	70	57	52	
All-Sky Solar Radiation	RadAvg	1.20	2.20	3.40	4.75	5.65	6.25	6.98	5.59	3.95	2.44	1.33	0.95	
	RadStd	0.10	0.17	0.29	0.33	0.48	0.47	0.41	0.36	0.35	0.25	0.11	0.09	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (63 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page