

OYEN AGDM, AB, Canada

WMO: 713420

Lat: 51.3797N

Lon: 110.3552W

Elev: 767

StdP: 92.45

Time Zone: -7.00 (NAM)

Period: 02-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-29.5	-26.7	-33.1	0.2	-29.4	-30.1	0.3	-26.7	13.2	-4.8	11.7	-5.6	3.7	250	0.736

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.7	31.1	17.0	28.9	16.3	26.8	15.8	19.1	26.7	17.9	25.3	16.9	24.2	4.7	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.7	13.1	21.6	15.3	12.0	20.6	14.2	11.1	19.2	57.5	26.7	53.7	25.4	50.4	24.4	24.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.3	10.7	9.4	DB	-33.5	34.3	2.6	2.0	-35.3	35.8	-36.8	37.0	-38.3	38.1	-40.2	39.6	(4)
(5)			WB	-33.3	21.2	2.7	1.6	-35.3	22.3	-36.9	23.3	-38.4	24.1	-40.4	25.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	3.8	-10.2	-11.0	-3.3	4.3	10.9	15.1	18.4	17.1	12.1	4.8	-3.3	-10.0	(6)
(7)		DBStd	12.18	8.25	7.78	7.91	5.58	4.59	3.40	3.26	3.63	4.90	5.56	6.90	7.92	(7)
(8)		HDD10.0	3088	626	588	414	180	46	3	0	1	32	177	401	620	(8)
(9)		HDD18.3	5390	884	821	672	421	234	108	40	68	194	420	650	878	(9)
(10)		CDD10.0	828	0	0	1	9	73	154	259	221	96	14	1	0	(10)
(11)		CDD18.3	89	0	0	0	0	2	11	41	29	7	0	0	0	(11)
(12)		CDH23.3	1457	0	0	1	3	73	170	580	462	162	6	0	0	(12)
(13)		CDH26.7	474	0	0	0	0	12	42	208	157	55	0	0	0	(13)
(14)	Wind	WSAvg	4.8	5.3	4.8	5.1	5.3	5.2	4.8	4.2	4.1	4.4	5.0	4.9	4.8	(14)
(15)	Precipitation	PrecAvg	330	14	8	13	21	37	73	53	43	25	14	13	11	(15)
(16)		PrecMax	471	47	18	36	61	80	150	128	84	83	33	44	18	(16)
(17)		PrecMin	172	2	1	3	3	3	17	20	5	1	4	0	2	(17)
(18)		PrecStd	75	10	5	7	15	23	32	24	21	21	7	11	5	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.0	5.2	15.8	23.2	28.4	30.9	34.4	33.2	31.7	24.1	15.2	6.9	(19)
(20)			MCWB	2.6	2.3	8.1	10.7	14.1	17.3	18.5	16.5	15.4	12.6	7.9	3.5	(20)
(21)		2%	DB	4.1	3.1	11.9	19.5	25.4	27.5	31.3	30.5	27.8	19.7	10.2	4.5	(21)
(22)			MCWB	1.7	0.9	5.9	9.2	12.6	15.5	18.3	16.2	14.3	10.4	5.1	2.0	(22)
(23)		5%	DB	2.7	1.5	8.9	16.4	22.9	25.1	29.0	28.3	24.5	16.1	7.4	2.8	(23)
(24)			MCWB	0.8	-0.2	4.4	7.5	11.7	15.2	17.2	16.1	13.3	8.6	3.4	0.6	(24)
(25)		10%	DB	1.0	-0.4	6.0	13.7	20.4	22.8	26.6	25.8	21.4	13.2	4.8	0.4	(25)
(26)			MCWB	-0.6	-1.7	2.7	6.3	10.5	14.2	17.0	15.5	12.0	7.2	1.9	-1.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.0	2.7	8.6	11.4	15.1	19.0	21.8	19.4	16.3	13.2	8.2	3.9	(27)
(28)			MCD B	5.3	4.8	15.1	21.6	24.8	27.4	28.9	27.0	27.9	22.4	14.8	6.3	(28)
(29)		2%	WB	1.8	1.1	6.2	9.6	13.6	17.2	20.0	18.1	14.9	10.9	5.6	2.2	(29)
(30)			MCD B	3.7	2.8	11.0	18.1	23.1	24.3	27.3	26.3	25.9	18.2	9.6	4.4	(30)
(31)		5%	WB	0.9	-0.1	4.5	8.1	12.4	16.0	18.7	17.0	13.8	9.2	3.7	0.6	(31)
(32)			MCD B	2.7	1.5	8.5	15.3	21.0	23.2	26.1	25.1	23.3	15.2	6.7	2.6	(32)
(33)		10%	WB	-0.6	-1.7	2.7	6.8	11.3	14.9	17.7	16.1	12.5	7.6	2.1	-1.1	(33)
(34)			MCD B	1.0	-0.3	5.7	12.6	19.0	21.2	24.6	23.8	20.4	12.8	4.5	0.4	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	9.5	9.4	10.2	12.1	13.2	11.8	13.7	13.7	13.2	11.7	9.2	8.7	(35)
(36)			MCDBR	9.3	10.2	13.7	17.2	17.1	15.7	17.7	18.4	18.5	16.3	12.1	9.7	(36)
(37)			MCWBR	7.6	8.3	8.4	8.7	7.7	6.8	7.1	7.1	7.8	8.6	7.9	7.7	(37)
(38)		5% WB	MCD BR	9.2	10.0	12.9	15.6	14.9	13.7	15.1	15.5	17.2	15.5	11.3	9.5	(38)
(39)			MCWBR	7.7	8.4	8.3	8.2	7.1	6.7	7.2	6.7	7.6	8.5	7.8	7.6	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.260	0.293	0.295	0.348	0.375	0.367	0.368	0.383	0.329	0.289	0.262	0.252	(40)	
(41)		taud	2.354	2.308	2.436	2.301	2.266	2.348	2.376	2.296	2.434	2.519	2.473	2.363	(41)	
(42)		Ebn at Noon	774	834	913	890	877	887	880	843	861	842	779	725	(42)	
(43)		Edh at Noon	60	84	90	117	127	118	113	116	90	68	54	51	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.17	2.23	3.59	4.86	5.85	6.08	6.54	5.32	3.82	2.32	1.23	0.88	(44)	
(45)		RadStd	0.12	0.20	0.27	0.39	0.39	0.38	0.28	0.39	0.34	0.28	0.11	0.09	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (49 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page