

EDGERTON AGCM, AB, Canada

WMO: 713600

Lat: 52.7778N

Lon: 110.4328W

Elev: 2129

StdP: 13.60

Time Zone: -7.00 (NAM)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-25.3	-20.0	-31.9	1.0	-25.2	-26.1	1.4	-19.8	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.5	83.2	63.2	80.1	62.4	77.0	61.0	67.1	78.1	65.0	75.7	63.1	73.3	N/A	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
63.2	93.7	72.7	61.0	86.7	69.7	59.1	80.9	67.9	32.8	78.0	31.1	75.9	29.7	73.5	75.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
N/A	N/A	N/A	DB	-33.1	88.3	3.1	3.7	-35.4	91.0	-37.2	93.2	-38.9	95.3	-41.2	98.0
			WB	-33.3	71.1	3.1	2.9	-35.5	73.2	-37.4	74.8	-39.1	76.4	-41.4	78.5

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	36.8	10.8	9.4	22.4	37.5	51.5	59.1	63.5	60.9	52.6	39.7	23.0	9.5	(6)
(7)		DBStd	22.73	15.29	14.55	13.98	9.60	7.86	5.62	4.87	5.43	8.03	8.68	12.65	14.26	(7)
(8)		HDD50	6143	1215	1137	856	385	78	7	0	2	64	332	811	1256	(8)
(9)		HDD65	10368	1680	1557	1320	826	419	189	88	147	377	783	1261	1721	(9)
(10)		CDD50	1326	0	0	0	9	125	279	419	339	141	14	0	0	(10)
(11)		CDD65	80	0	0	0	0	2	12	42	19	5	0	0	0	(11)
(12)		CDH74	1399	0	0	0	5	117	182	533	367	190	5	0	0	(12)
(13)		CDH80	294	0	0	0	0	12	25	125	73	59	0	0	0	(13)
(14)	Wind	WSAvg	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(14)
(15)	Precipitation	PrecAvg	15.2	0.7	0.4	0.6	1.1	1.6	2.8	2.0	1.1	0.7	0.6	0.6	(15)	
(16)		PrecMax	20.6	1.5	0.9	1.4	3.2	3.4	4.7	5.4	5.0	2.9	1.6	2.0	1.1	(16)
(17)		PrecMin	9.5	0.2	0.2	0.0	0.1	0.2	0.9	1.0	0.2	0.0	0.1	0.1	0.2	(17)
(18)		PrecStd	3.0	0.4	0.2	0.3	0.7	0.9	1.1	1.0	1.0	0.9	0.4	0.5	0.2	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	43.6	43.0	56.2	71.8	81.9	82.9	88.5	86.0	86.9	72.7	56.9	42.3	(19)
(20)			MCWB	37.0	36.9	45.0	49.8	56.6	61.7	67.3	63.0	60.7	54.8	43.0	35.6	(20)
(21)		2%	DB	39.9	38.0	49.8	65.6	77.6	78.8	83.3	81.4	79.5	64.5	47.7	37.8	(21)
(22)			MCWB	35.1	33.7	40.4	47.6	55.5	60.8	66.3	63.6	59.0	50.4	39.4	33.2	(22)
(23)		5%	DB	36.8	34.6	43.7	59.6	72.9	75.5	79.9	78.3	73.9	58.9	42.5	33.6	(23)
(24)			MCWB	32.8	31.5	37.4	44.4	53.4	59.2	64.8	62.7	57.0	47.5	36.6	29.9	(24)
(25)		10%	DB	32.9	31.4	39.4	54.1	68.3	72.3	76.3	74.7	68.5	54.1	38.4	29.3	(25)
(26)			MCWB	29.8	28.8	34.6	41.9	51.0	57.4	63.1	61.6	54.4	44.7	34.1	26.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	37.5	37.4	45.7	50.9	58.9	65.7	70.8	69.2	62.7	55.9	45.2	36.5	(27)
(28)			MCDWB	42.5	42.3	55.6	70.2	76.7	77.8	82.6	78.7	79.9	70.2	54.5	41.3	(28)
(29)		2%	WB	35.4	34.1	40.6	47.7	56.5	62.9	68.1	66.3	60.0	51.8	40.6	33.4	(29)
(30)			MCDWB	39.7	37.1	48.4	63.5	73.2	74.8	79.1	77.2	76.4	59.7	46.5	37.7	(30)
(31)		5%	WB	32.9	31.8	37.7	45.0	54.7	61.0	66.1	64.0	57.6	48.4	37.1	29.9	(31)
(32)			MCDWB	36.5	34.7	43.6	57.4	69.8	71.4	77.1	74.2	71.8	57.4	41.5	33.2	(32)
(33)		10%	WB	29.9	28.7	34.8	42.5	52.7	59.1	64.2	62.2	55.5	45.5	34.3	26.7	(33)
(34)			MCDWB	33.0	31.5	38.8	52.9	66.4	69.6	74.2	72.0	67.2	53.8	38.1	29.5	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	18.0	18.6	18.3	20.5	23.9	20.9	21.5	22.3	24.0	20.8	15.9	15.7	(35)
(36)			MCDBR	19.2	19.8	22.9	31.2	31.1	27.1	27.7	30.6	34.9	30.1	21.8	19.9	(36)
(37)			MCWBR	15.6	16.3	15.5	16.0	13.6	11.8	13.1	14.5	16.1	17.0	14.7	16.1	(37)
(38)		5% WB	MCDWB	19.1	19.2	21.9	29.2	27.8	22.8	25.3	25.5	31.7	28.1	19.8	19.2	(38)
(39)			MCWBR	15.9	16.1	15.2	15.4	13.2	11.0	12.9	13.3	15.3	16.3	14.1	16.0	(39)
(40)		Clear-Sky Solar Irradiance	taub	0.246	0.290	0.286	0.333	0.355	0.372	0.365	0.378	0.316	0.280	0.255	0.231	(40)
(41)	taud		2.344	2.244	2.418	2.357	2.345	2.331	2.385	2.323	2.468	2.543	2.455	2.363	(41)	
(42)	Ebn at Noon		245	259	290	286	284	279	279	268	276	267	242	232	(42)	
(43)	Edh at Noon		18	27	29	35	37	38	35	36	27	20	16	15	(43)	
(44)	All-Sky Solar Radiation	RadAvg	338	673	1140	1502	1839	1891	1988	1617	1141	676	338	252	(44)	
(45)		RadStd	31	50	87	140	127	134	102	129	121	93	35	23	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (57 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page