

EDGERTON AGCM, AB, Canada

WMO: 713600

Lat: 52.7778N

Lon: 110.4328W

Elev: 649

StdP: 93.77

Time Zone: -7.00 (NAM)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-31.9	-28.9	-35.5	0.1	-31.8	-32.3	0.2	-28.8	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.9	28.5	17.3	26.7	16.9	25.0	16.1	19.5	25.6	18.3	24.3	17.3	22.9	N/A	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.3	13.4	22.6	16.1	12.4	21.0	15.0	11.6	20.0	58.5	25.5	54.5	24.4	51.1	23.0	24.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	-36.2	31.3	1.7	2.1	-37.4	32.8	-38.4	34.0	-39.4	35.1	-40.7	36.6
			-36.3	21.7	1.7	1.6	-37.5	22.9	-38.5	23.8	-39.5	24.7	-40.8	25.8
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	2.7	-11.8	-12.6	-5.3	3.0	10.9	15.0	17.5	16.0	11.4	4.3	-5.0	-12.5
	DBStd	12.63	8.50	8.08	7.77	5.34	4.37	3.12	2.71	3.02	4.46	4.82	7.03	7.92
	HDD10.0	3413	675	632	476	214	43	4	0	1	36	184	451	698
	HDD18.3	5760	933	865	733	459	233	105	49	82	209	435	701	956
	CDD10.0	737	0	0	0	5	69	155	233	188	78	8	0	0
	CDD18.3	44	0	0	0	0	1	7	23	11	3	0	0	0
	CDH23.3	777	0	0	0	3	65	101	296	204	106	3	0	0
	CDH26.7	163	0	0	0	0	7	14	69	41	33	0	0	0
Wind	WSAvg	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Precipitation	PrecAvg	385	19	11	15	28	40	70	71	52	29	17	15	15
	PrecMax	522	39	23	35	81	86	120	137	127	73	41	50	28
	PrecMin	242	5	4	1	2	6	23	25	6	0	2	3	4
	PrecStd	77	9	5	8	18	24	27	26	26	22	9	12	6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.4	6.1	13.5	22.1	27.7	28.3	31.4	30.0	30.5	22.6	13.8	5.7
		MCWB	2.8	2.7	7.2	9.9	13.6	16.5	19.6	17.2	15.9	12.7	6.1	2.0
	2%	DB	4.4	3.3	9.9	18.7	25.3	26.0	28.5	27.5	26.4	18.0	8.7	3.2
		MCWB	1.7	1.0	4.7	8.6	13.1	16.0	19.0	17.5	15.0	10.2	4.1	0.7
	5%	DB	2.7	1.5	6.5	15.3	22.7	24.2	26.6	25.7	23.3	14.9	5.9	0.9
		MCWB	0.4	-0.3	3.0	6.9	11.9	15.1	18.2	17.0	13.9	8.6	2.6	-1.2
	10%	DB	0.5	-0.4	4.1	12.3	20.2	22.4	24.6	23.7	20.3	12.3	3.6	-1.5
		MCWB	-1.2	-1.8	1.5	5.5	10.6	14.1	17.3	16.4	12.5	7.0	1.2	-2.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.1	3.0	7.6	10.5	14.9	18.7	21.5	20.6	17.1	13.3	7.3	2.5
		MCDB	5.8	5.7	13.1	21.2	24.8	25.4	28.1	25.9	26.6	21.2	12.5	5.2
	2%	WB	1.9	1.2	4.8	8.7	13.6	17.2	20.0	19.1	15.6	11.0	4.8	0.8
		MCDB	4.3	2.9	9.1	17.5	22.9	23.8	26.2	25.1	24.7	15.4	8.1	3.2
	5%	WB	0.5	-0.1	3.2	7.2	12.6	16.1	19.0	17.8	14.2	9.1	2.8	-1.2
		MCDB	2.5	1.5	6.4	14.1	21.0	21.9	25.1	23.4	22.1	14.1	5.3	0.6
	10%	WB	-1.2	-1.8	1.6	5.8	11.5	15.1	17.9	16.8	13.0	7.5	1.3	-3.0
		MCDB	0.6	-0.3	3.8	11.6	19.1	20.9	23.5	22.2	19.6	12.1	3.4	-1.4
Mean Daily Temperature Range	5% DB	MDBR	10.0	10.3	10.1	11.4	13.3	11.6	11.9	12.4	13.3	11.5	8.8	8.7
		MCDBR	10.7	11.0	12.7	17.3	17.3	15.1	15.4	17.0	19.4	16.7	12.1	11.1
		MCWBR	8.7	9.1	8.6	8.9	7.5	6.6	7.3	8.1	8.9	9.4	8.2	8.9
	5% WB	MCDBR	10.6	10.7	12.2	16.2	15.5	12.7	14.0	14.2	17.6	15.6	11.0	10.7
		MCWBR	8.8	8.9	8.4	8.6	7.3	6.1	7.2	7.4	8.5	9.0	7.8	8.9
Clear-Sky Solar Irradiance	taub	0.246	0.290	0.286	0.333	0.355	0.372	0.365	0.378	0.316	0.280	0.255	0.231	
	taud	2.344	2.244	2.418	2.357	2.345	2.331	2.385	2.323	2.468	2.543	2.455	2.363	
	Ebn at Noon	771	817	915	902	894	879	879	844	869	842	762	730	
	Edh at Noon	57	86	90	109	116	119	111	112	85	64	51	46	
All-Sky Solar Radiation	RadAvg	1.07	2.12	3.60	4.73	5.80	5.96	6.27	5.10	3.60	2.13	1.07	0.80	
	RadStd	0.10	0.16	0.27	0.44	0.40	0.42	0.32	0.41	0.38	0.29	0.11	0.07	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (57 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page