

INUVIK CS, NT, Canada

WMO: 713640

Lat: 68.318N

Lon: 133.534W

Elev: 338

StdP: 14.52

Time Zone: -7.00 (NAM)

Period: 03-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-34.7	-31.3	-41.8	0.5	-34.7	-38.1	0.6	-31.0	25.8	-0.4	21.7	-1.2	3.6	110	0.808

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.3	78.0	59.5	73.8	57.8	70.1	56.2	61.4	73.7	59.6	70.4	57.8	67.6	6.7	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
56.6	69.1	64.9	54.5	64.0	63.5	52.5	59.3	62.2	27.5	73.8	26.3	70.2	25.1	67.9	68.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	17.0	14.5	13.0	DB	-37.8	83.4	4.5	3.2	-41.0	85.7	-43.6	87.6	-46.1	89.4	-49.4	91.7
(5)				WB	-37.9	64.2	4.5	1.9	-41.2	65.6	-43.8	66.7	-46.3	67.8	-49.6	69.2

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	20.3	-10.8	-8.2	-5.3	13.2	35.2	52.5	57.3	51.3	39.6	23.0	1.5	-8.0
	DBStd	27.51	13.87	14.05	13.64	12.92	12.23	9.59	7.85	8.40	7.70	8.68	10.21	11.15
	HDD50	11422	1885	1628	1715	1104	480	84	25	87	324	837	1455	1798
	HDD65	16366	2350	2048	2180	1554	925	389	256	432	763	1301	1905	2263
	CDD50	571	0	0	0	0	21	158	252	127	12	1	0	0
	CDD65	37	0	0	0	0	0	12	18	7	0	0	0	0
	CDH74	327	0	0	0	0	12	121	138	56	0	0	0	0
	CDH80	48	0	0	0	0	1	20	19	8	0	0	0	0
Wind	WSAvg	6.2	5.1	5.1	5.9	6.8	7.3	7.9	7.1	6.7	6.6	5.8	4.9	4.7
Precipitation	PrecAvg	10.2	0.6	0.4	0.5	0.5	0.7	0.9	1.5	1.8	1.1	1.1	0.6	0.6
	PrecMax	14.8	1.7	0.9	1.6	1.7	2.4	2.8	3.4	5.9	2.4	4.0	1.5	1.4
	PrecMin	5.0	0.0	0.0	0.0	0.1	0.0	0.0	0.3	0.3	0.1	0.1	0.0	0.0
	PrecStd	2.1	0.4	0.2	0.3	0.4	0.6	0.7	0.8	0.9	0.6	0.6	0.3	0.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	34.6	28.4	37.1	49.6	73.4	83.9	82.6	80.6	65.6	51.5	29.5	24.3
		MCWB	30.6	25.5	32.0	40.0	51.9	62.0	62.3	62.3	52.8	44.5	28.3	22.6
	2%	DB	24.3	23.2	27.4	42.5	65.6	77.6	77.8	73.2	59.5	41.5	23.5	18.1
		MCWB	23.0	21.2	24.0	35.5	49.6	58.2	59.7	59.7	49.8	37.2	22.2	17.0
	5%	DB	16.4	18.5	20.1	38.1	59.4	73.0	74.1	68.8	55.3	37.1	19.3	13.0
		MCWB	15.6	16.9	17.5	32.4	46.5	56.1	58.5	57.2	47.8	34.7	18.3	12.4
	10%	DB	8.5	13.1	14.0	33.0	53.7	68.9	70.7	64.8	51.1	33.8	15.7	7.6
		MCWB	7.7	11.9	12.0	28.7	43.3	54.0	57.3	55.4	45.5	32.1	14.8	6.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	31.2	26.3	32.5	39.9	53.1	62.4	64.1	63.2	53.6	44.6	28.2	22.9
		MCDB	34.3	28.2	37.2	48.6	69.0	79.5	77.9	76.6	62.8	50.8	29.8	24.4
	2%	WB	23.1	21.3	23.9	35.6	50.0	59.5	61.9	60.8	50.8	37.7	22.3	17.1
		MCDB	24.4	23.2	27.0	42.0	64.7	74.5	73.7	71.8	58.4	40.7	23.3	18.2
	5%	WB	15.6	16.9	17.6	32.4	46.9	57.3	60.2	58.4	48.4	34.7	18.4	12.3
		MCDB	16.4	18.4	20.0	37.9	59.1	70.7	70.7	66.9	53.8	36.9	19.3	13.0
	10%	WB	7.8	11.8	11.9	28.8	43.5	55.2	58.6	56.2	45.9	32.0	14.7	7.1
		MCDB	8.5	13.0	14.0	32.8	53.2	67.7	67.9	63.5	50.6	33.5	15.6	7.6
Mean Daily Temperature Range	5% DB	MDBR	9.7	11.0	13.7	14.7	15.8	19.1	16.3	13.9	10.8	7.8	8.9	9.3
		MCDBR	15.3	15.4	18.2	17.1	24.5	22.9	20.9	19.4	17.8	10.5	10.5	14.6
		MCWBR	14.6	13.8	14.9	11.5	13.4	10.0	8.9	9.2	9.9	7.4	10.1	14.2
	5% WB	MCDBR	15.3	15.2	18.2	16.6	24.3	21.4	18.2	17.6	16.5	9.8	10.4	14.4
		MCWBR	14.6	13.8	14.9	11.3	13.6	10.0	8.8	9.2	9.7	7.1	10.1	14.0
Clear-Sky Solar Irradiance	taub	0.158	0.214	0.251	0.303	0.345	0.341	0.363	0.336	0.293	0.236	0.157	N/A	
	taud	1.912	2.132	2.226	2.169	2.290	2.453	2.426	2.514	2.559	2.253	1.922	N/A	
	Ebn at Noon	39	193	254	266	267	273	261	258	244	181	32	0	
	Edh at Noon	2	14	23	34	34	30	30	24	18	12	2	0	
All-Sky Solar Radiation	RadAvg	11	171	697	1431	1831	1945	1577	1085	591	192	28	0	
	RadStd	1	11	33	53	142	153	149	110	54	23	3	0	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+4.19	+6.48	+6.52	N/A	N/A	N/A	-1631	-1562	N/A	N/A	
(47)	Regional (9 neighbors)	+1.75	+3.20	+3.65	N/A	N/A	N/A	-769	-760	N/A	N/A	

Nomenclature: See separate page