

CAPE DORSET, NU, Canada

WMO: 713660

Lat: 64.231N

Lon: 76.530W

Elev: 158

StdP: 14.61

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-27.8	-25.0	-36.0	0.7	-27.6	-33.1	0.9	-24.8	35.7	-2.3	30.9	-3.3	6.0	270	1.033

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.7	60.0	50.9	56.9	49.0	53.8	47.6	51.7	58.4	49.7	55.6	48.0	53.2	9.6	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
47.7	49.2	53.1	45.9	45.9	51.7	44.1	42.9	50.0	21.3	58.6	20.2	55.7	19.3	53.5	59.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 32.1	28.3	24.9	-28.9	66.3	4.3	2.9	-32.0	68.4	-34.5	70.1	-36.9	71.7	-40.0	73.8		
(5)			-29.2	55.3	4.2	1.8	-32.2	56.6	-34.7	57.7	-37.1	58.7	-40.1	60.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	18.4	-9.8	-11.1	-4.6	10.2	24.8	37.1	46.6	44.2	36.1	27.3	15.8	1.9		
	DBStd	21.42	9.77	9.17	10.07	9.24	6.50	5.36	5.70	4.55	4.29	5.19	8.95	11.16		
	HDD50	11584	1855	1710	1692	1194	781	389	137	190	417	703	1026	1490		
	HDD65	17016	2320	2130	2157	1644	1246	838	569	646	867	1168	1476	1955		
	CDD50	44	0	0	0	0	0	2	33	9	0	0	0	0		
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0		
	WSAvg	11.1	9.5	9.2	10.2	11.4	11.7	10.8	10.0	10.7	12.5	14.1	12.8	10.7		
	PrecAvg	16.0	0.8	0.8	0.8	0.9	1.0	1.3	1.3	2.2	1.9	1.5	1.3	1.1		
(15) Precipitation	PrecMax	22.7	2.5	4.7	3.5	2.4	2.4	4.2	3.7	5.9	4.1	3.1	2.8	3.4		
	PrecMin	7.7	0.0	0.0	0.0	0.0	0.2	0.0	0.0	0.3	0.3	0.3	0.2	0.1		
	PrecStd	3.7	0.5	1.0	0.7	0.6	0.6	0.9	0.9	1.2	0.8	0.7	0.8	0.7		
	PrecStd	3.7	0.5	1.0	0.7	0.6	0.6	0.9	0.9	1.2	0.8	0.7	0.8	0.7		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	25.9	19.4	24.4	33.8	40.1	57.9	66.4	61.3	50.3	38.6	33.2	31.9		
		MCWB	25.4	18.0	23.3	33.0	36.8	48.7	54.5	51.9	44.0	37.4	32.7	31.5		
	2%	DB	13.9	11.2	19.5	29.7	36.6	52.6	62.0	57.4	46.3	36.5	31.0	26.4		
		MCWB	12.9	10.4	18.8	28.4	34.4	45.4	51.9	49.6	41.8	35.5	30.3	25.8		
	5%	DB	8.8	6.0	14.6	26.8	34.3	48.5	59.2	54.1	43.9	35.0	29.4	22.6		
		MCWB	8.0	5.1	13.7	25.7	32.9	43.0	50.3	48.2	40.8	34.0	28.5	21.7		
	10%	DB	4.3	2.4	9.7	24.0	32.6	45.3	56.3	51.6	42.0	33.8	27.6	18.4		
		MCWB	3.4	1.6	8.8	23.0	31.7	40.8	48.7	46.8	39.7	33.1	26.6	17.6		
	0.4%	WB	25.3	18.2	23.7	33.1	37.3	49.5	55.7	53.2	45.0	37.7	32.7	31.2		
		MCDB	25.8	18.8	24.3	33.6	39.7	56.6	64.1	60.0	48.3	38.3	32.9	31.5		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	12.9	10.5	18.8	28.5	34.8	46.1	52.8	50.6	42.8	35.6	30.5	25.8		
		MCDB	13.6	11.2	19.6	29.2	36.1	51.8	60.7	55.4	45.2	36.1	30.8	26.2		
	5%	WB	8.1	5.2	13.7	25.6	33.2	43.1	50.9	48.9	41.3	34.3	28.6	21.7		
		MCDB	8.9	5.9	14.5	26.5	34.2	48.0	57.9	53.3	43.5	34.8	29.2	22.5		
	10%	WB	3.5	1.6	8.8	22.8	31.8	41.0	49.2	47.3	40.0	33.2	26.6	17.6		
		MCDB	4.2	2.4	9.6	23.9	32.5	44.9	55.4	51.2	41.8	33.7	27.5	18.4		
	5% DB	MDBR	9.0	8.8	9.9	9.9	7.0	8.6	11.7	9.2	6.2	5.2	7.4	9.3		
		MCDBR	12.5	13.6	13.7	10.4	7.9	13.2	15.8	13.5	9.5	4.9	7.4	11.0		
		MCWBR	12.2	13.2	13.4	10.3	6.5	8.5	9.3	8.6	7.0	4.9	7.8	11.1		
		MCWBR	12.6	13.5	13.6	10.5	7.3	12.8	15.1	12.7	8.8	4.8	7.4	11.1		
(35) Mean Daily Temperature Range	5% WB	MCWBR	12.4	13.2	13.3	10.3	6.2	8.6	9.8	8.9	6.9	4.9	7.7	11.2		
		MCWBR	12.4	13.2	13.3	10.3	6.2	8.6	9.8	8.9	6.9	4.9	7.7	11.2		
	Clear-Sky Solar Irradiance	taub	0.176	0.228	0.262	0.315	0.342	0.340	0.353	0.346	0.316	0.273	N/A	0.160		
		taud	1.889	2.129	2.166	2.078	2.134	2.355	2.455	2.482	2.491	2.304	N/A	1.915		
(42) All-Sky Solar Radiation	RadAvg	Ebn at Noon	126	224	264	270	273	278	271	262	247	203	N/A	58		
		Edh at Noon	9	19	28	39	41	34	30	27	21	16	N/A	3		
(44) All-Sky Solar Radiation	RadStd	RadAvg	44	285	849	1496	1698	1829	1689	1145	650	233	57	17		
		RadStd	4	23	34	65	216	148	195	123	80	35	8	1		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
		N/A	N/A	+3.55	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (0 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page