

CAPE DORSET, NU, Canada

WMO: 713660

Lat: 64.231N

Lon: 76.530W

Elev: 48

StdP: 100.75

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-33.2	-31.7	-37.8	0.1	-33.1	-36.2	0.1	-31.5	15.9	-19.1	13.8	-19.6	2.7	270	1.033

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.5	15.6	10.5	13.8	9.5	12.1	8.7	10.9	14.7	9.8	13.1	8.9	11.8	4.3	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8.7	7.0	11.7	7.7	6.6	10.9	6.7	6.1	10.0	31.6	14.8	29.1	13.2	26.9	11.9	15.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 14.3	12.6	11.1	DB	-33.8	19.1	2.4	1.6	-35.5	20.2	-36.9	21.2	-38.3	22.1	-40.0	23.2	(4)
(5)			WB	-34.0	12.9	2.4	1.0	-35.7	13.7	-37.0	14.3	-38.4	14.8	-40.1	15.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	-7.6	-23.2	-23.9	-20.3	-12.1	-4.0	2.8	8.1	6.8	2.3	-2.6	-9.0	-16.7	(6)
(7)		DBStd	11.90	5.43	5.09	5.59	5.13	3.61	2.98	3.16	2.53	2.38	2.88	4.97	6.20	(7)
(8)		HDD10.0	6436	1031	950	940	663	434	216	76	106	232	391	570	828	(8)
(9)		HDD18.3	9453	1289	1183	1198	913	692	466	316	359	482	649	820	1086	(9)
(10)		CDD10.0	24	0	0	0	0	0	1	18	5	0	0	0	0	(10)
(11)		CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)
(12)		CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)
(13)		CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	5.0	4.3	4.1	4.6	5.1	5.2	4.8	4.5	4.8	5.6	6.3	5.7	4.8	(14)
(15)	Precipitation	PrecAvg	406	20	21	21	23	26	32	32	55	48	39	34	27	(15)
(16)		PrecMax	576	64	119	89	61	61	106	94	150	103	78	72	87	(16)
(17)		PrecMin	195	1	0	0	0	4	0	0	8	7	7	6	3	(17)
(18)		PrecStd	95	13	26	18	16	16	22	24	30	21	18	20	18	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-3.4	-7.0	-4.2	1.0	4.5	14.4	19.1	16.3	10.1	3.7	0.7	-0.1	(19)
(20)			MCWB	-3.7	-7.8	-4.8	0.6	2.7	9.3	12.5	11.0	6.7	3.0	0.4	-0.3	(20)
(21)		2%	DB	-10.1	-11.6	-6.9	-1.3	2.6	11.4	16.6	14.1	8.0	2.5	-0.6	-3.1	(21)
(22)			MCWB	-10.6	-12.0	-7.3	-2.0	1.3	7.5	11.0	9.8	5.5	2.0	-0.9	-3.5	(22)
(23)		5%	DB	-12.9	-14.5	-9.7	-2.9	1.3	9.2	15.1	12.3	6.6	1.6	-1.5	-5.2	(23)
(24)			MCWB	-13.3	-14.9	-10.2	-3.5	0.5	6.1	10.2	9.0	4.9	1.1	-1.9	-5.7	(24)
(25)		10%	DB	-15.4	-16.4	-12.4	-4.4	0.4	7.4	13.5	10.9	5.5	1.0	-2.4	-7.6	(25)
(26)			MCWB	-15.9	-16.9	-12.9	-5.0	-0.2	4.9	9.3	8.2	4.3	0.6	-3.0	-8.0	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-3.7	-7.7	-4.6	0.6	3.0	9.7	13.2	11.8	7.2	3.2	0.4	-0.5	(27)
(28)			MDCB	-3.5	-7.3	-4.3	0.9	4.3	13.7	17.8	15.6	9.0	3.5	0.5	-0.3	(28)
(29)		2%	WB	-10.6	-11.9	-7.3	-2.0	1.5	7.8	11.6	10.4	6.0	2.0	-0.8	-3.5	(29)
(30)			MDCB	-10.2	-11.6	-6.9	-1.5	2.3	11.0	16.0	13.0	7.3	2.3	-0.7	-3.2	(30)
(31)		5%	WB	-13.3	-14.9	-10.2	-3.6	0.6	6.2	10.5	9.4	5.2	1.3	-1.9	-5.7	(31)
(32)			MDCB	-12.9	-14.5	-9.7	-3.1	1.2	8.9	14.4	11.8	6.4	1.5	-1.6	-5.3	(32)
(33)		10%	WB	-15.8	-16.9	-12.9	-5.1	-0.1	5.0	9.5	8.5	4.4	0.7	-3.0	-8.0	(33)
(34)			MDCB	-15.4	-16.4	-12.5	-4.5	0.3	7.2	13.0	10.7	5.4	1.0	-2.5	-7.6	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	5.0	4.9	5.5	5.5	3.9	4.8	6.5	5.1	3.5	2.9	4.1	5.2	(35)
(36)			MCDBR	6.9	7.5	7.6	5.8	4.4	7.4	8.8	7.5	5.3	2.7	4.1	6.1	(36)
(37)			MCWBR	6.8	7.4	7.4	5.7	3.6	4.7	5.2	4.8	3.9	2.7	4.3	6.2	(37)
(38)		5% WB	MCDBR	7.0	7.5	7.6	5.9	4.1	7.1	8.4	7.0	4.9	2.7	4.1	6.2	(38)
(39)			MCWBR	6.9	7.4	7.4	5.7	3.4	4.8	5.4	4.9	3.8	2.7	4.3	6.2	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.176	0.228	0.262	0.315	0.342	0.340	0.353	0.346	0.316	0.273	N/A	0.160	(40)	
(41)		taud	1.889	2.129	2.166	2.078	2.134	2.355	2.455	2.482	2.491	2.304	N/A	1.915	(41)	
(42)		Ebn at Noon	398	707	831	850	860	875	853	826	779	639	N/A	184	(42)	
(43)		Edh at Noon	27	59	89	124	130	107	95	84	67	50	N/A	10	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.14	0.90	2.68	4.72	5.35	5.77	5.33	3.61	2.05	0.73	0.18	0.05	(44)	
(45)		RadStd	0.01	0.07	0.11	0.20	0.68	0.47	0.62	0.39	0.25	0.11	0.03	0.00	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	+1.97	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page