

L'ACADIE, QC, Canada

WMO: 713720

Lat: 45.2939N

Lon: 73.3497W

Elev: 144

StdP: 14.62

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-11.4	-6.7	-20.0	1.8	-10.4	-15.1	2.4	-6.0	29.0	32.4	25.5	32.4	6.3	270	0.536

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.9	86.2	71.1	83.5	69.8	80.9	68.5	74.5	82.1	72.6	79.5	71.0	77.6	9.3	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
72.0	118.9	79.0	70.3	112.2	76.8	68.6	105.7	75.1	38.1	82.6	36.4	79.6	34.9	77.8	84.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.9	19.5	16.8	DB	-17.5	91.2	6.7	2.6	-22.3	93.1	-26.2	94.6	-30.0	96.1	-34.8	98.0
			WB	-18.1	78.0	6.5	2.3	-22.7	79.6	-26.5	81.0	-30.1	82.3	-34.8	83.9

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	44.6	15.6	18.3	28.5	42.8	56.8	65.9	69.8	67.6	60.4	48.2	36.2	23.7
	DBStd	21.02	13.21	11.35	10.95	8.32	7.77	6.59	4.97	5.25	7.16	8.10	9.17	11.38
	HDD50	4269	1067	889	670	244	23	0	0	0	5	134	422	815
	HDD65	7865	1532	1309	1133	666	273	67	13	34	172	522	865	1279
	CDD50	2304	0	0	2	29	234	477	613	545	318	79	7	0
	CDD65	426	0	0	0	1	20	94	161	114	35	1	0	0
	CDH74	3194	0	0	0	12	231	745	1170	767	261	8	0	0
	CDH80	743	0	0	0	1	55	205	279	151	52	0	0	0
Wind	WSAvg	7.1	8.5	8.0	7.9	8.0	7.4	6.8	5.8	5.3	5.9	6.9	7.7	7.7
Precipitation	PrecAvg	40.6	2.9	2.4	2.7	3.3	3.5	3.8	4.2	3.8	3.5	3.8	3.1	3.5
	PrecMax	48.2	4.5	3.9	4.6	6.0	7.1	5.8	6.9	6.4	7.9	6.9	6.1	6.6
	PrecMin	34.3	0.9	1.1	0.8	0.6	1.2	2.0	1.9	1.6	1.3	1.2	0.8	1.3
	PrecStd	4.1	1.1	0.8	0.9	1.5	1.4	1.2	1.1	1.3	1.4	1.6	1.1	1.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	47.7	45.2	59.6	74.6	86.2	89.7	90.2	87.4	85.7	74.4	63.1	51.7
		MCWB	46.2	41.6	50.2	58.7	65.8	72.5	74.5	73.7	72.1	63.2	57.4	48.3
	2%	DB	41.1	40.7	51.5	67.3	80.2	85.5	85.8	83.9	80.2	69.2	57.9	45.8
		MCWB	38.7	37.5	45.1	54.1	62.7	69.6	72.1	71.2	69.0	60.7	53.7	43.4
	5%	DB	37.6	37.6	46.2	61.5	75.4	81.8	83.0	81.2	76.6	64.9	53.1	41.7
		MCWB	35.7	34.9	41.7	51.0	59.8	67.4	70.5	69.7	66.8	57.7	49.1	39.5
	10%	DB	34.5	35.1	42.2	56.4	71.0	78.2	80.4	78.4	73.0	60.8	49.5	38.0
		MCWB	32.7	33.1	38.3	47.4	58.8	65.5	69.2	68.2	64.7	55.2	45.9	36.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.5	42.3	53.3	62.8	69.8	75.7	78.0	76.2	73.7	66.1	58.8	49.4
		MCDB	47.7	44.7	57.9	70.1	80.8	85.3	87.1	84.1	81.2	71.5	61.5	51.5
	2%	WB	39.2	37.9	46.0	56.8	66.6	72.8	75.1	73.5	71.0	62.1	54.0	43.8
		MCDB	40.6	40.3	50.3	65.2	75.3	80.9	82.4	80.6	77.5	67.8	57.5	45.6
	5%	WB	35.8	35.2	42.0	52.1	63.7	70.3	72.9	71.7	68.4	58.5	49.8	39.7
		MCDB	37.3	37.2	45.6	58.8	71.5	77.8	79.3	77.9	74.7	63.8	52.5	41.5
	10%	WB	32.7	33.1	38.6	48.9	60.7	68.1	71.2	70.0	66.1	55.8	46.1	36.2
		MCDB	34.4	34.9	41.9	55.6	68.2	75.3	77.8	75.7	71.7	60.0	49.3	37.8
Mean Daily Temperature Range	5% DB	MDBR	15.4	16.1	15.2	17.1	19.2	17.8	17.9	18.6	19.1	15.7	12.8	13.1
		MCDBR	15.0	15.2	18.7	26.7	26.2	22.5	20.8	21.4	22.6	20.7	18.4	13.6
		MCWBR	14.4	13.7	13.9	15.8	12.8	10.7	10.6	11.1	12.5	13.0	15.1	12.7
	5% WB	MCDBR	14.6	14.9	18.2	23.3	20.9	18.2	17.7	18.3	19.6	18.5	17.4	13.7
MCWBR		14.4	13.8	14.5	15.6	12.7	10.7	10.4	10.6	12.0	12.9	15.3	13.0	
Clear-Sky Solar Irradiance	taub	0.264	0.291	0.326	0.363	0.390	0.440	0.436	0.418	0.376	0.335	0.309	0.297	
	taud	2.364	2.278	2.335	2.356	2.338	2.204	2.222	2.264	2.371	2.491	2.484	2.318	
	Ebn at Noon	272	282	287	284	279	264	263	264	266	265	253	241	
	Edh at Noon	23	31	34	37	39	44	43	40	33	25	21	23	
All-Sky Solar Radiation	RadAvg	458	752	1137	1378	1617	1772	1787	1585	1262	730	446	321	
	RadStd	51	77	90	163	157	138	133	74	103	67	56	27	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (46 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page