

ILE AUX PERROQUETS, QC, Canada

WMO: 713750

Lat: 50.2208N

Lon: 64.2072W

Elev: 30

StdP: 14.68

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-6.6	-2.8	-16.5	2.2	-5.2	-12.4	2.8	-1.4	45.7	20.0	42.5	18.5	17.8	320	0.906

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.6	63.6	59.8	61.5	58.3	59.8	57.0	60.6	62.4	58.9	60.6	57.3	58.8	9.4	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
59.7	76.4	61.6	58.0	72.0	59.9	56.4	67.9	58.3	26.8	62.5	25.7	60.8	24.6	58.9	66.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
38.4	33.8	29.6	-12.4	69.2	3.7	2.7	-15.1	71.2	-17.2	72.8	-19.3	74.3	-22.0	76.3		
			-13.4	64.5	3.6	1.7	-16.0	65.7	-18.1	66.7	-20.1	67.7	-22.8	68.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	35.5	14.2	14.8	22.4	32.2	40.5	48.4	53.8	54.0	48.3	41.6	32.5	21.4	
	DBStd	15.30	9.67	9.10	8.10	4.56	3.89	3.89	3.38	4.18	4.18	4.26	6.60	8.78	
	HDD50	5625	1108	987	854	533	294	76	7	12	81	262	524	887	
	HDD65	10780	1573	1407	1319	983	759	499	346	340	502	726	974	1352	
	CDD50	321	0	0	0	0	0	28	126	136	30	1	0	0	
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	
Wind	WSAvg	14.6	18.3	17.3	16.1	14.8	12.3	12.0	11.2	11.2	12.6	14.7	16.7	18.5	
Precipitation	PrecAvg	43.3	3.3	2.7	3.4	3.0	3.6	3.6	3.7	3.3	3.8	4.6	4.6	3.9	
	PrecMax	49.8	7.3	5.6	7.0	7.1	7.9	6.8	7.2	5.9	6.9	7.6	8.0	9.5	
	PrecMin	36.9	0.7	1.0	1.3	0.7	1.4	1.4	1.8	1.6	1.7	1.5	1.9	1.6	
	PrecStd	3.7	1.5	1.1	1.7	1.5	1.6	1.6	1.5	1.1	1.2	1.6	1.5	1.7	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	38.3	37.6	38.9	46.2	54.4	61.8	66.1	66.6	62.4	53.6	48.5	41.6	
		MCWB	35.5	35.2	34.4	39.9	47.1	54.9	60.3	62.3	58.0	50.1	47.4	40.5	
	2%	DB	34.3	33.9	35.8	41.9	50.1	58.9	63.2	64.3	58.7	50.9	44.4	38.6	
		MCWB	32.8	32.0	32.6	37.2	45.6	53.9	59.4	60.7	55.1	48.4	42.9	37.0	
	5%	DB	31.5	31.0	33.8	39.4	48.0	56.5	61.2	62.2	56.3	48.9	42.5	35.9	
		MCWB	30.5	29.9	31.5	35.8	44.3	52.5	58.1	59.2	53.4	46.6	41.0	34.3	
	10%	DB	28.4	28.0	32.2	37.7	46.2	54.4	59.4	60.4	54.2	47.2	40.9	33.8	
		MCWB	27.1	26.6	30.4	34.9	43.0	50.9	56.8	57.8	51.6	44.9	39.3	32.4	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	36.5	36.1	35.9	40.6	48.8	58.7	63.1	63.2	58.5	51.6	47.8	41.0
			MCDB	37.7	37.3	37.6	44.5	51.3	60.6	64.8	65.3	60.6	52.7	48.4	41.7
2%		WB	33.4	32.6	33.6	38.2	46.4	55.6	60.5	61.0	55.4	49.3	43.6	37.6	
		MCDB	34.5	33.9	34.9	40.4	48.8	57.2	62.2	62.8	56.7	50.4	44.2	38.5	
5%		WB	30.8	30.6	32.1	36.7	44.8	53.4	59.0	59.3	53.2	47.3	41.5	34.8	
		MCDB	31.7	31.8	33.4	38.6	47.2	55.4	60.7	60.9	54.5	48.5	42.3	35.6	
10%		WB	27.5	26.8	30.7	35.3	43.2	51.4	57.4	57.6	51.4	45.5	39.4	32.5	
		MCDB	28.6	28.0	32.0	37.2	45.5	53.6	58.9	59.2	52.8	46.7	40.5	33.6	
Mean Daily Temperature Range	5% DB	MDBR	12.0	11.9	11.0	7.7	8.1	9.3	9.7	9.6	8.5	6.8	7.6	9.7	
		MCDBR	13.7	11.4	9.9	9.6	11.1	12.5	12.4	11.4	10.4	8.2	8.1	9.9	
		MCWBR	13.2	10.7	8.5	7.2	7.9	8.8	9.2	8.9	8.4	7.2	8.6	9.8	
	5% WB	MCDBR	13.5	10.9	9.2	8.6	10.2	11.2	11.4	10.7	9.6	7.3	8.3	9.8	
		MCWBR	13.7	10.5	8.7	6.9	7.8	9.1	9.5	9.1	8.6	7.3	8.8	10.2	
Clear-Sky Solar Irradiance	taub		0.267	0.271	0.294	0.338	0.362	0.383	0.417	0.381	0.355	0.331	0.291	0.273	
	taud		2.368	2.333	2.342	2.344	2.410	2.382	2.337	2.440	2.481	2.514	2.517	2.377	
	Ebn at Noon		249	279	291	287	284	278	266	271	267	254	241	228	
	Edh at Noon		20	27	32	36	35	36	38	32	28	23	18	17	
All-Sky Solar Radiation	RadAvg		331	641	1058	1425	1657	1776	1685	1434	1083	660	344	256	
	RadStd		38	53	93	120	100	162	154	73	70	48	32	23	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	N/A	+1.53	N/A	N/A	N/A	N/A	N/A	N/A
Regional (9 neighbors)		N/A	N/A	+2.23	N/A	+0.59	+0.65	N/A	N/A	N/A	N/A

Nomenclature: See separate page