

MISTOOK, QC, Canada

WMO: 713810

Lat: 48.5983N

Lon: 71.7158W

Elev: 369

StdP: 14.50

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -25.5	(c) -20.3	(d) -32.0	(e) 0.9	(f) -25.2	(g) -26.8	(h) 1.3	(i) -19.9	(j) 31.0	(k) 18.2	(l) 26.2	(m) 13.5	(n) 3.7	(o) 20	(p) 0.656

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 18.6	(c) 83.5	(d) 69.7	(e) 80.2	(f) 68.1	(g) 77.1	(h) 66.4	(i) 72.6	(j) 79.9	(k) 70.5	(l) 77.1	(m) 68.5	(n) 74.6	(o) 8.6	(p) 230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
70.1	112.1	76.7	68.1	104.7	74.3	66.2	97.9	72.0	36.5	79.8	34.7	77.2	33.0	74.8	81.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 25.4	(b) 22.1	(c) 19.6	(e) -33.9	(f) 89.1	(g) 6.3	(h) 3.2	(i) -38.4	(j) 91.4	(k) -42.1	(l) 93.3	(m) -45.7	(n) 95.1	(o) -50.3	(p) 97.4		
(a) 25.4	(b) 22.1	(c) 19.6	(e) -33.5	(f) 75.7	(g) 6.7	(h) 2.5	(i) -38.4	(j) 77.5	(k) -42.3	(l) 79.0	(m) -46.1	(n) 80.4	(o) -50.9	(p) 82.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	37.6	4.0	7.3	19.7	34.9	50.6	60.7	64.9	63.2	55.6	43.2	30.4	14.3
	DBStd	23.43	14.78	13.55	12.89	8.59	8.12	7.03	5.04	5.50	7.49	7.66	9.31	12.84
	HDD50	6076	1427	1195	940	454	93	4	0	0	28	238	590	1107
	HDD65	10177	1892	1615	1405	902	452	165	63	102	295	675	1039	1572
	CDD50	1538	0	0	0	2	111	327	463	409	196	29	1	0
	CDD65	161	0	0	0	0	5	37	61	45	13	0	0	0
	CDH74	1396	0	0	0	1	119	406	456	316	95	3	0	0
	CDH80	294	0	0	0	0	27	108	87	55	17	0	0	0
	WSAvg	8.8	8.8	8.6	9.1	9.4	8.8	8.0	7.4	7.4	8.2	10.2	10.6	8.9
	PrecAvg	40.0	2.5	2.2	2.2	2.5	3.1	3.8	4.9	4.3	4.4	3.8	3.1	3.1
(15) Precipitation	PrecMax	46.3	5.7	4.4	4.4	4.2	6.2	5.9	11.5	9.5	8.7	5.7	5.0	4.6
	PrecMin	34.7	0.9	1.2	0.8	1.1	1.2	1.9	2.0	2.0	2.3	1.5	1.0	1.6
	PrecStd	3.2	0.9	0.8	0.9	0.9	1.1	1.1	1.8	1.6	1.3	1.1	0.8	0.7
	PrecStd	3.2	0.9	0.8	0.9	0.9	1.1	1.1	1.8	1.6	1.3	1.1	0.8	0.7
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	42.7	41.9	49.3	66.1	83.7	87.5	86.8	85.1	82.3	71.2	57.0	40.4
		MCWB	41.0	39.8	42.6	50.8	63.0	71.7	72.9	71.4	70.3	62.1	53.8	38.8
	2%	DB	36.5	35.7	42.9	58.3	77.0	83.0	82.4	81.0	76.3	64.7	49.8	37.0
		MCWB	35.5	33.3	38.3	46.7	59.9	68.2	70.5	69.8	67.7	58.0	45.7	35.8
	5%	DB	31.6	32.5	39.5	52.4	71.4	78.6	79.2	77.6	72.0	59.2	45.5	34.3
		MCWB	30.6	30.9	35.8	43.9	57.7	65.9	68.9	67.8	64.5	53.6	42.7	33.2
	10%	DB	26.2	28.6	36.7	47.4	66.1	74.5	76.0	74.2	68.3	54.7	41.7	32.2
		MCWB	24.9	27.2	33.9	40.8	55.3	63.5	67.4	66.1	62.5	50.8	39.6	31.2
	0.4%	WB	41.8	40.3	43.9	54.5	67.0	74.6	76.2	74.2	72.4	63.1	54.4	39.3
		MCDB	42.6	41.6	47.1	62.7	77.3	84.5	83.7	82.5	79.5	69.1	56.9	40.2
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	35.7	33.7	38.9	48.3	63.2	70.9	72.9	71.4	68.8	58.7	46.9	36.0
		MCDB	36.5	35.5	41.8	56.3	72.2	79.3	79.5	78.3	74.1	64.1	48.5	36.8
	5%	WB	30.6	30.9	36.3	45.0	59.4	68.0	70.6	69.3	66.0	54.8	42.8	33.4
		MCDB	31.6	32.5	38.8	51.1	69.1	75.3	76.9	75.5	71.0	58.1	44.9	34.2
	10%	WB	25.0	27.2	34.3	41.9	56.0	65.2	68.5	67.3	63.1	51.3	39.7	31.2
		MCDB	26.2	28.7	36.5	46.9	64.7	71.9	74.3	72.8	67.4	54.4	41.6	32.1
(35) Mean Daily Temperature Range	5% DB	MDBR	19.4	21.0	19.8	18.0	21.8	20.6	18.6	18.5	18.1	13.4	11.4	14.6
		MCDBR	20.4	17.8	19.7	26.7	31.9	27.5	23.6	23.6	23.7	21.3	16.1	13.1
		MCWBR	19.5	16.3	15.2	17.1	16.9	15.3	13.6	13.7	15.0	15.1	13.5	12.7
	5% WB	MCDWR	20.3	17.6	17.0	24.2	26.7	24.1	20.4	20.4	21.3	19.3	14.9	13.0
		MCWBR	19.9	16.4	13.7	16.9	15.8	14.6	13.0	12.6	14.5	14.6	13.5	12.9
(40) Clear-Sky Solar Irradiance	taub		0.269	0.284	0.311	0.372	0.353	0.384	0.399	0.378	0.365	0.328	0.320	0.262
	taud		2.239	2.215	2.220	2.262	2.425	2.365	2.344	2.401	2.425	2.510	2.349	2.311
	Ebn at Noon		251	275	285	278	288	278	272	273	266	259	230	240
	Edh at Noon		24	31	37	39	35	37	38	34	30	23	22	19
(44) All-Sky Solar Radiation	RadAvg		412	723	1127	1426	1644	1755	1640	1391	1063	607	328	268
	RadStd		52	95	97	114	154	122	159	90	81	62	34	30

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (23 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page