

MISTOOK, QC, Canada

WMO: 713810

Lat: 48.5983N

Lon: 71.7158W

Elev: 113

StdP: 99.98

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-31.9	-29.0	-35.6	0.1	-31.8	-32.7	0.2	-28.8	13.9	-7.6	11.7	-10.3	1.7	20	0.656

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.3	28.6	20.9	26.8	20.1	25.1	19.1	22.5	26.6	21.4	25.1	20.3	23.6	3.9	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.1	16.0	24.8	20.1	15.0	23.5	19.0	14.0	22.2	67.1	26.6	62.8	25.1	58.8	23.8	27.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.4	9.9	8.7	DB	-36.6	31.7	3.5	1.8	-39.1	33.0	-41.2	34.0	-43.2	35.0	-45.7	36.3	(4)
(5)			WB	-36.4	24.3	3.7	1.4	-39.1	25.3	-41.3	26.1	-43.4	26.9	-46.1	27.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	3.1	-15.6	-13.7	-6.8	1.6	10.3	16.0	18.3	17.3	13.1	6.2	-0.9	-9.8	(6)	
	DBStd	13.02	8.21	7.53	7.16	4.77	4.51	3.90	2.80	3.06	4.16	4.25	5.17	7.13	(7)	
	HDD10.0	3376	793	664	522	252	52	2	0	0	16	132	328	615	(8)	
	HDD18.3	5654	1051	897	781	501	251	92	35	57	164	375	577	873	(9)	
	CDD10.0	854	0	0	0	1	62	182	257	227	109	16	1	0	(10)	
	CDD18.3	89	0	0	0	0	3	21	34	25	7	0	0	0	(11)	
	CDH23.3	776	0	0	0	1	66	226	253	176	53	2	0	0	(12)	
	CDH26.7	163	0	0	0	0	15	60	48	31	9	0	0	0	(13)	
(14) Wind	WSAvg	3.9	3.9	3.9	4.1	4.2	3.9	3.6	3.3	3.3	3.7	4.6	4.7	4.0	(14)	
(15) Precipitation	PrecAvg	1016	64	56	55	63	80	96	125	109	111	97	79	80	(15)	
	PrecMax	1175	145	111	111	106	158	149	292	242	221	145	127	118	(16)	
	PrecMin	881	22	30	21	29	31	47	50	51	58	37	26	40	(17)	
	PrecStd	81	24	20	24	23	28	27	46	41	33	28	21	17	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.0	5.5	9.6	19.0	28.7	30.8	30.4	29.5	27.9	21.8	13.9	4.7	(19)	
		MCWB	5.0	4.3	5.9	10.4	17.2	22.0	22.7	21.9	21.3	16.7	12.1	3.8	(20)	
	2%	DB	2.5	2.1	6.1	14.6	25.0	28.3	28.0	27.2	24.6	18.1	9.9	2.8	(21)	
		MCWB	1.9	0.7	3.5	8.2	15.5	20.1	21.4	21.0	19.8	14.4	7.6	2.1	(22)	
	5%	DB	-0.2	0.3	4.2	11.3	21.9	25.9	26.2	25.4	22.2	15.1	7.5	1.3	(23)	
		MCWB	-0.8	-0.6	2.1	6.6	14.3	18.8	20.5	19.9	18.1	12.0	6.0	0.7	(24)	
	10%	DB	-3.2	-1.9	2.6	8.6	19.0	23.6	24.4	23.4	20.2	12.6	5.4	0.1	(25)	
		MCWB	-4.0	-2.7	1.0	4.9	12.9	17.5	19.7	19.0	17.0	10.4	4.2	-0.5	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.5	4.6	6.6	12.5	19.4	23.7	24.6	23.4	22.5	17.3	12.5	4.0	(27)	
		MCDB	5.9	5.3	8.4	17.1	25.2	29.2	28.7	28.1	26.4	20.6	13.8	4.5	(28)	
	2%	WB	2.0	1.0	3.8	9.1	17.3	21.6	22.7	21.9	20.5	14.8	8.3	2.2	(29)	
		MCDB	2.5	2.0	5.5	13.5	22.3	26.3	26.4	25.7	23.4	17.8	9.1	2.7	(30)	
	5%	WB	-0.8	-0.6	2.4	7.2	15.2	20.0	21.5	20.7	18.9	12.7	6.0	0.8	(31)	
		MCDB	-0.2	0.3	3.8	10.6	20.6	24.1	24.9	24.1	21.7	14.5	7.2	1.2	(32)	
	10%	WB	-3.9	-2.7	1.3	5.5	13.3	18.4	20.3	19.6	17.3	10.7	4.3	-0.5	(33)	
		MCDB	-3.2	-1.9	2.5	8.3	18.2	22.2	23.5	22.7	19.7	12.4	5.3	0.1	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	10.8	11.7	11.0	10.0	12.1	11.5	10.3	10.3	10.1	7.4	6.3	8.1	(35)	
		MCDBR	11.4	9.9	10.9	14.8	17.7	15.3	13.1	13.1	13.2	11.8	8.9	7.3	(36)	
	5% WB	MCWBR	10.8	9.1	8.4	9.5	9.4	8.5	7.5	7.6	8.3	8.4	7.5	7.1	(37)	
		MCDWR	11.3	9.8	9.4	13.4	14.9	13.4	11.3	11.4	11.8	10.7	8.3	7.2	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.269	0.284	0.311	0.372	0.353	0.384	0.399	0.378	0.365	0.328	0.320	0.262	(40)	
		taud	2.239	2.215	2.220	2.262	2.425	2.365	2.344	2.401	2.425	2.510	2.349	2.311	(41)	
	Edn at Noon	Edn at Noon	791	867	900	875	908	877	857	861	837	818	724	757	(42)	
		Edh at Noon	75	98	116	124	110	118	119	107	95	74	69	61	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1.30	2.28	3.55	4.50	5.18	5.53	5.17	4.39	3.35	1.92	1.03	0.85	(44)	
	RadStd	RadStd	0.16	0.30	0.30	0.36	0.49	0.38	0.50	0.28	0.26	0.20	0.11	0.09	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (23 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page