

POINTE NOIRE, QC, Canada

WMO: 713900

Lat: 50.151N

Lon: 66.425W

Elev: 79

StdP: 14.65

Time Zone: -5.00 (NAE)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -9.7	(c) -5.6	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) 23.7	(k) 13.7	(l) 21.2	(m) 12.7	(n) 10.5	(o) 290	(p) 0.662

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 11.8	(c) 76.4	(d) N/A	(e) 72.8	(f) N/A	(g) 70.0	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) 11.8	(p) 210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 20.5	(b) 18.4	(c) 16.4	(d) DB	(e) -14.9	(f) 82.7	(g) 4.3	(h) 2.9	(i) -17.9	(j) 84.8	(k) -20.4	(l) 86.5	(m) -22.9	(n) 88.2	(o) -26.0	(p) 90.3	(q) N/A
(4)			(r) WB	(s) N/A	(t) N/A	(u) N/A	(v) N/A	(w) N/A	(x) N/A	(y) N/A	(z) N/A	(aa) N/A	(ab) N/A	(ac) N/A	(ad) N/A	(ae) N/A

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	38.5	12.6	14.3	23.4	35.0	45.8	55.5	62.0	61.4	53.7	43.3	32.9	20.6		
	DBStd	18.61	10.53	10.26	9.55	6.02	5.72	5.91	4.56	4.12	5.29	5.32	6.85	9.40		
	HDD50	5271	1159	1000	823	451	157	14	0	0	21	219	514	913		
	HDD65	9715	1624	1420	1288	901	594	292	114	125	341	674	964	1378		
	CDD50	1076	0	0	0	0	28	178	373	355	132	10	0	0		
	CDD65	43	0	0	0	0	0	6	22	14	1	0	0	0		
	CDH74	224	0	0	0	0	4	44	110	55	10	1	0	0		
	CDH80	27	0	0	0	0	0	7	16	4	0	0	0	0		
	WSAvg	7.7	9.1	8.4	8.2	8.1	6.9	6.9	6.5	6.2	6.9	7.9	8.4	9.4		
	PrecAvg	42.8	3.1	2.4	2.8	3.0	3.3	3.6	4.2	3.3	4.0	4.7	4.1	3.7		
	PrecMax	53.7	7.2	5.5	5.9	6.1	5.9	6.1	7.4	8.7	8.3	8.7	6.8	8.5		
(15) Precipitation	PrecMin	35.9	0.0	1.0	0.9	0.6	1.3	1.6	1.8	1.1	1.1	1.3	1.7	1.6		
	PrecStd	4.9	1.5	1.1	1.1	1.5	1.3	1.3	1.5	1.6	1.5	2.0	1.4	1.9		
	DB	38.1	39.7	45.4	55.2	71.5	79.5	82.2	80.0	74.6	64.5	50.2	42.4			
	MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	2% DB	34.5	35.5	40.9	50.0	62.5	73.3	76.9	74.7	68.7	56.7	45.9	39.3			
	MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5% DB	31.3	32.4	37.8	45.9	58.1	69.2	73.1	71.4	64.7	53.2	43.8	36.5			
	MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10% DB	28.1	29.4	35.2	43.0	54.3	65.1	70.2	68.6	61.6	50.3	41.8	33.5			
	MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	0.4% WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2% WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5% WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10% WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5% DB	12.9	14.1	13.4	10.5	11.2	11.8	11.8	11.3	11.0	8.4	8.4	10.0			
	MCDBR	14.9	13.4	13.6	15.0	18.9	20.2	17.9	16.5	16.5	13.0	10.0	10.8			
(35) Mean Daily Temperature Range	MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5% WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(40) Clear-Sky Solar Irradiance	taub	0.264	0.269	0.295	0.347	0.368	0.393	0.426	0.388	0.365	0.329	0.295	0.270			
	taud	2.361	2.322	2.320	2.301	2.386	2.365	2.304	2.412	2.449	2.519	2.501	2.390			
	Ebn at Noon	251	279	290	284	282	275	263	268	263	255	239	231			
	Edh at Noon	20	27	32	37	36	37	39	33	29	23	18	17			
(44) All-Sky Solar Radiation	RadAvg	358	679	1095	1436	1654	1743	1634	1386	1039	625	331	257			
	RadStd	41	63	87	119	105	143	162	87	75	53	32	22			

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (9 neighbors)		N/A	N/A	N/A	N/A	N/A	+0.59	N/A	N/A	N/A	N/A

Nomenclature: See separate page