

POINTE NOIRE, QC, Canada

WMO: 713900

Lat: 50.151N

Lon: 66.425W

Elev: 24

StdP: 101.04

Time Zone: -5.00 (NAE)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -23.2	(c) -20.9	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) 10.6	(k) -10.2	(l) 9.5	(m) -10.7	(n) 4.7	(o) 290	(p) 0.662

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 6.6	(c) 24.7	(d) N/A	(e) 22.7	(f) N/A	(g) 21.1	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) 5.3	(p) 210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 9.2	(b) 8.2	(c) 7.3	(e) -26.0	(f) 28.2	(g) 2.4	(h) 1.6	(i) -27.7	(j) 29.3	(k) -29.1	(l) 30.3	(m) -30.5	(n) 31.2	(o) -32.2	(p) 32.4		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	3.6	-10.8	-9.9	-4.8	1.7	7.7	13.0	16.7	16.4	12.1	6.3	0.5	-6.4
	DBStd	10.34	5.85	5.70	5.31	3.35	3.18	3.28	2.53	2.29	2.94	2.96	3.81	5.22
	HDD10.0	2928	644	556	457	251	87	8	0	0	12	122	286	507
	HDD18.3	5397	902	789	716	501	330	162	63	69	189	374	536	766
	CDD10.0	598	0	0	0	0	16	99	207	197	73	6	0	0
	CDD18.3	24	0	0	0	0	0	3	12	8	1	0	0	0
	CDH23.3	124	0	0	0	0	2	24	61	31	6	1	0	0
	CDH26.7	15	0	0	0	0	0	4	9	2	0	0	0	0
Wind	WSAvg	3.5	4.1	3.8	3.7	3.6	3.1	3.1	2.9	2.8	3.1	3.5	3.8	4.2
Precipitation	PrecAvg	1088	78	61	71	76	85	92	106	85	102	119	103	93
	PrecMax	1365	184	139	149	154	151	156	189	221	212	222	172	216
	PrecMin	912	0	25	23	14	33	41	45	27	29	33	44	40
	PrecStd	124	38	29	29	37	33	33	38	40	38	52	36	49
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	3.4	4.3	7.5	12.9	21.9	26.4	27.9	26.6	23.7	18.0	10.1	5.8
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	1.4	1.9	4.9	10.0	16.9	22.9	25.0	23.7	20.4	13.7	7.7	4.1
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	-0.4	0.2	3.2	7.7	14.5	20.6	22.9	21.9	18.2	11.8	6.5	2.5
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	-2.1	-1.4	1.8	6.1	12.4	18.4	21.2	20.3	16.5	10.2	5.4	0.8
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	7.2	7.8	7.4	5.8	6.2	6.6	6.6	6.3	6.1	4.7	4.6	5.6
		MCDBR	8.3	7.4	7.5	8.3	10.5	11.2	10.0	9.2	9.2	7.2	5.6	6.0
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub		0.264	0.269	0.295	0.347	0.368	0.393	0.426	0.388	0.365	0.329	0.295	0.270
	taud		2.361	2.322	2.320	2.301	2.386	2.365	2.304	2.412	2.449	2.519	2.501	2.390
	Ebn at Noon		791	881	914	896	889	866	828	846	830	803	752	727
	Edh at Noon		63	85	102	118	114	117	123	105	91	72	57	54
All-Sky Solar Radiation	RadAvg		1.13	2.14	3.45	4.53	5.21	5.49	5.15	4.37	3.28	1.97	1.04	0.81
	RadStd		0.13	0.20	0.27	0.38	0.33	0.45	0.51	0.27	0.24	0.17	0.10	0.07

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (9 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	+0.33	N/A	N/A	N/A	N/A

Nomenclature: See separate page