

HALIFAX STANFIELD, NS, Canada

WMO: 713950

Lat: 44.880N

Lon: 63.500W

Elev: 145

StdP: 99.59

Time Zone: -4.00 (NAA)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-17.6	-15.2	-23.1	0.5	-16.5	-20.4	0.6	-14.0	15.7	4.0	13.8	3.7	4.7	320	0.668

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.2	27.9	20.5	26.2	19.5	24.8	18.8	22.0	25.7	21.1	24.2	20.2	22.9	5.2	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.9	15.8	23.5	20.1	15.0	22.5	19.1	14.2	21.6	65.2	25.8	61.7	24.4	58.5	23.0	25.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
12.8	11.1	9.8	-20.6	31.3	3.0	1.6	-22.7	32.4	-24.5	33.3	-26.2	34.2	-28.3	35.3		
			-21.0	23.7	2.9	0.9	-23.2	24.3	-24.9	24.8	-26.5	25.3	-28.7	25.9		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	7.2	-5.0	-4.6	-0.9	4.5	10.1	15.1	19.3	19.2	15.4	9.5	4.0	-1.4
	DBStd	9.50	5.74	5.24	4.62	3.63	3.44	3.48	2.52	2.53	3.46	3.84	4.57	5.04
	HDD10.0	2024	466	408	339	168	40	3	0	0	2	56	187	353
	HDD18.3	4193	724	642	597	414	255	106	19	21	99	273	431	612
	CDD10.0	993	0	0	1	4	44	157	289	285	164	42	6	0
	CDD18.3	119	0	0	0	0	1	10	49	47	12	1	0	0
	CDH23.3	663	0	0	1	1	16	91	270	231	53	1	0	0
	CDH26.7	111	0	0	0	0	3	16	45	35	12	0	0	0
(14) Wind	WSAvg	4.8	5.2	5.4	5.4	5.3	4.7	4.4	4.1	3.9	4.2	4.7	5.1	5.3
(15) Precipitation	PrecAvg	1532	155	124	128	132	114	102	99	110	96	131	159	173
	PrecMax	2037	313	214	250	237	238	313	197	397	166	240	276	308
	PrecMin	1100	37	37	52	37	29	45	10	17	20	29	38	59
	PrecStd	237	58	49	47	49	51	52	51	71	39	52	59	62
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.7	10.6	14.5	18.8	25.7	28.8	30.2	29.7	28.0	22.0	16.5	13.0
		MCWB	11.4	9.4	9.8	12.4	15.9	20.6	21.9	21.5	21.3	16.9	15.4	12.7
	2%	DB	8.7	7.3	10.0	14.9	21.5	25.9	27.8	27.5	24.5	19.2	14.8	10.7
		MCWB	8.4	6.5	8.0	9.9	14.3	18.4	20.7	20.2	19.3	16.6	14.0	10.3
	5%	DB	6.0	4.9	7.7	12.7	18.8	23.6	26.2	25.9	22.5	17.3	13.4	8.7
		MCWB	5.3	4.0	5.8	8.9	12.7	17.1	19.6	19.6	18.2	15.3	12.6	8.2
	10%	DB	3.0	2.7	5.7	10.6	16.5	21.6	24.7	24.3	20.8	15.8	11.5	5.9
		MCWB	2.3	1.8	3.8	7.7	11.5	16.1	18.9	18.7	17.7	13.9	10.4	5.1
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.6	9.7	11.2	13.9	18.3	21.7	23.2	23.1	22.3	19.1	16.0	12.9
		MCDB	11.8	10.7	13.1	16.4	23.0	27.2	27.4	27.4	25.5	20.3	16.2	12.9
	2%	WB	8.5	6.7	8.5	11.8	15.7	20.1	22.1	21.9	20.7	17.4	14.4	10.5
		MCDB	8.7	7.1	9.4	13.1	19.1	24.1	25.9	25.2	23.0	18.3	14.7	10.8
	5%	WB	5.5	4.2	6.2	9.9	14.0	18.5	21.1	20.9	19.7	16.0	12.8	8.3
		MCDB	5.9	4.7	7.2	11.5	16.9	21.7	24.4	23.7	21.3	17.0	13.3	8.6
	10%	WB	2.4	2.0	4.0	8.1	12.5	17.2	20.1	19.9	18.6	14.2	10.6	5.3
		MCDB	2.9	2.6	5.2	10.2	15.3	19.9	23.1	22.7	20.2	15.4	11.3	5.8
(35) Mean Daily Temperature Range	5% DB	MDBR	8.1	8.1	7.9	8.5	9.7	9.6	9.2	9.0	8.7	7.8	6.9	7.1
		MCDBR	11.7	9.7	10.8	12.4	13.8	12.8	11.5	11.2	10.4	9.5	8.9	9.9
		MCWBR	12.1	9.2	9.0	8.3	7.9	7.0	5.7	5.7	6.1	7.0	8.5	10.3
		MCDBR	11.8	9.7	10.3	10.2	11.8	11.0	9.8	9.2	8.5	8.6	8.6	10.0
	5% WB	MCWBR	12.3	9.8	9.7	8.5	7.9	6.9	5.8	5.4	5.9	7.5	8.8	10.5
(40) Clear-Sky Solar Irradiance	taub	0.297	0.289	0.317	0.343	0.361	0.389	0.405	0.388	0.347	0.324	0.308	0.289	
	taud	2.466	2.519	2.480	2.448	2.439	2.378	2.354	2.400	2.493	2.555	2.557	2.540	
	Ebn at Noon	825	910	922	920	908	879	859	863	877	855	810	805	
	Edh at Noon	70	79	94	106	111	118	120	110	93	76	64	59	
(44) All-Sky Solar Radiation	RadAvg	1.41	2.28	3.48	4.26	4.92	5.35	5.36	4.97	4.00	2.58	1.47	1.09	
	RadStd	0.11	0.17	0.23	0.36	0.61	0.49	0.39	0.35	0.28	0.27	0.16	0.08	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	+1.06	+1.51	N/A	+0.46	+0.84	N/A	N/A	+56	+18
(47) Regional (36 neighbors)	N/A	N/A	N/A	N/A	+0.36	+0.50	N/A	N/A	+50	+14

Nomenclature: See separate page