

CFB GREENWOOD, NS, Canada

WMO: 713970

Lat: 44.980N

Lon: 64.920W

Elev: 92

StdP: 14.65

Time Zone: -4.00 (NAA)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	1.4	5.4	-5.0	4.2	2.9	-1.3	5.1	6.7	31.6	30.5	28.6	31.4	7.9	290	0.590

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.0	84.8	70.1	82.0	68.3	79.2	66.8	73.0	80.3	71.4	78.0	69.8	76.1	12.6	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
70.7	113.4	76.5	69.1	107.4	75.4	67.5	101.3	73.8	36.7	80.6	35.3	78.5	33.9	76.2	80.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
26.2	22.8	19.9	DB	-5.5	90.5	5.3	2.1	-9.4	92.0	-12.5	93.2	-15.5	94.4	-19.4	95.9	
			WB	-6.2	76.2	5.1	1.7	-9.9	77.4	-12.9	78.4	-15.7	79.4	-19.4	80.6	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	46.2	23.8	24.6	31.5	42.2	52.9	61.8	68.9	67.3	60.0	49.3	40.1	30.4
	DBStd	17.41	10.49	9.65	8.65	7.12	6.51	6.35	4.65	4.99	6.95	7.26	8.42	9.19
	HDD50	3424	812	710	576	251	41	2	0	0	5	102	316	609
	HDD65	7187	1277	1130	1039	683	380	135	17	33	182	490	748	1073
	CDD50	2033	1	0	2	18	130	355	585	537	304	80	19	2
	CDD65	317	0	0	0	0	4	39	136	105	31	2	0	0
	CDH74	2256	0	0	1	4	51	321	976	726	170	7	0	0
	CDH80	465	0	0	0	1	6	59	223	146	30	0	0	0
	WSAvg	8.4	9.8	9.8	9.8	9.4	8.2	7.5	6.8	6.5	6.7	8.1	9.0	9.3
Precipitation	PrecAvg	51.3	4.8	4.1	4.3	3.8	3.7	3.6	3.3	3.3	4.4	4.8	5.5	5.8
	PrecMax	62.4	8.1	7.4	9.3	6.8	7.4	9.3	6.5	6.8	10.5	9.9	9.9	9.4
	PrecMin	38.6	2.5	1.5	1.6	1.7	1.3	1.0	0.9	1.1	2.2	1.2	2.3	2.9
	PrecStd	5.9	1.4	1.5	1.7	1.2	1.6	1.9	1.5	1.5	2.1	1.9	1.9	1.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	59.5	55.0	61.1	70.0	79.7	85.9	88.7	87.7	84.2	74.6	67.4	59.6
		MCWB	56.6	51.6	53.0	59.9	63.2	69.1	72.4	71.1	71.2	64.9	63.0	56.9
	2%	DB	51.2	47.4	53.6	63.7	73.9	81.0	85.2	84.0	78.4	69.2	62.7	54.0
		MCWB	48.9	44.7	48.3	55.1	60.0	66.6	70.5	69.7	67.6	62.0	59.4	52.1
	5%	DB	44.0	42.2	48.7	59.2	69.6	77.6	82.4	80.8	75.0	65.7	58.6	48.4
		MCWB	41.4	39.5	44.2	51.9	57.9	64.6	68.9	67.8	66.3	60.4	55.4	46.2
	10%	DB	38.2	38.3	44.1	55.0	65.7	74.3	79.6	78.1	72.0	61.9	53.6	43.1
		MCWB	36.1	36.0	39.6	48.1	55.5	63.1	67.3	66.8	64.7	57.0	50.4	40.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	56.9	51.7	55.0	62.3	66.9	72.2	75.4	74.8	73.1	67.4	64.0	57.4
		MCDB	59.5	54.2	58.6	66.8	75.7	80.5	84.0	82.9	79.2	71.5	66.9	59.1
	2%	WB	49.3	45.4	49.8	57.5	63.5	70.0	73.4	72.7	70.9	64.3	60.0	52.3
		MCDB	50.8	47.1	53.0	61.6	70.0	77.5	81.3	79.7	76.3	67.7	62.1	54.1
	5%	WB	41.8	39.8	44.8	53.5	60.2	67.8	71.7	70.9	68.6	61.1	55.9	46.6
		MCDB	43.7	41.6	47.5	57.3	66.6	74.8	78.3	77.4	73.1	64.6	58.3	48.0
	10%	WB	36.2	36.1	40.1	49.1	57.3	65.1	69.9	69.1	66.4	57.7	50.4	41.0
		MCDB	37.9	37.9	43.5	53.8	63.5	71.5	76.7	75.2	70.2	61.3	52.9	42.9
Mean Daily Temperature Range	5% DB	MDBR	14.9	15.1	15.0	16.4	19.0	19.4	19.0	19.4	18.9	16.5	13.5	12.9
		MCDBR	24.0	19.4	21.9	25.0	26.4	25.2	23.5	23.3	22.2	22.1	20.0	19.7
	5% WB	MCWBR	23.5	17.6	17.5	17.3	14.5	13.0	11.3	11.4	13.1	15.8	17.7	19.3
		MCDWR	24.1	18.8	20.9	20.5	21.5	20.8	18.6	18.7	18.0	18.3	18.9	19.2
Clear-Sky Solar Irradiance	taub		0.294	0.291	0.323	0.349	0.371	0.398	0.423	0.398	0.366	0.332	0.312	0.297
		taud	2.455	2.486	2.443	2.410	2.390	2.343	2.299	2.370	2.431	2.527	2.531	2.483
	Ebn at Noon		262	287	290	289	285	276	267	271	271	267	254	249
		Edh at Noon	22	26	31	35	37	39	40	36	31	25	21	20
All-Sky Solar Radiation	RadAvg		450	722	1091	1369	1580	1724	1754	1588	1272	816	459	345
	RadStd		38	55	76	128	181	157	124	107	89	88	50	27

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	+1.57	N/A	+1.06	+1.21	N/A	N/A	+115	+54
(47) Regional (41 neighbors)	N/A	N/A	N/A	N/A	+0.61	+0.85	N/A	N/A	+94	N/A

Nomenclature: See separate page