

CFB GREENWOOD, NS, Canada

WMO: 713970

Lat: 44.980N

Lon: 64.920W

Elev: 28

StdP: 100.99

Time Zone: -4.00 (NAA)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-17.0	-14.8	-20.6	0.6	-16.2	-18.5	0.7	-14.0	14.1	-0.8	12.8	-0.3	3.5	290	0.590

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.6	29.3	21.2	27.8	20.2	26.2	19.4	22.8	26.8	21.9	25.6	21.0	24.5	5.7	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
21.5	16.2	24.7	20.6	15.3	24.1	19.7	14.5	23.2	67.5	27.0	64.2	25.8	61.0	24.5	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.7	10.2	8.9	DB	-20.9	32.5	3.0	1.2	-23.0	33.3	-24.7	34.0	-26.4	34.7	-28.5	35.5	(4)
(5)			WB	-21.2	24.5	2.8	1.0	-23.3	25.2	-24.9	25.8	-26.5	26.3	-28.6	27.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	7.9	-4.5	-4.1	-0.3	5.7	11.6	16.5	20.5	19.6	15.5	9.6	4.5	-0.9	(6)	
	DBStd	9.67	5.83	5.36	4.81	3.95	3.62	3.53	2.59	2.77	3.86	4.03	4.68	5.11	(7)	
	HDD10.0	1902	451	394	320	139	23	1	0	0	3	57	176	338	(8)	
	HDD18.3	3993	709	628	577	379	211	75	9	18	101	272	416	596	(9)	
	CDD10.0	1129	1	0	1	10	72	197	325	298	169	44	11	1	(10)	
	CDD18.3	176	0	0	0	2	22	76	58	17	1	0	0	0	(11)	
	CDH23.3	1253	0	0	1	2	28	178	542	403	94	4	0	0	(12)	
	CDH26.7	258	0	0	0	1	3	33	124	81	17	0	0	0	(13)	
(14) Wind	WSAvg	3.8	4.4	4.4	4.4	4.2	3.6	3.4	3.0	2.9	3.0	3.6	4.0	4.2	(14)	
(15) Precipitation	PrecAvg	1304	122	104	110	97	93	91	85	83	113	121	140	147	(15)	
	PrecMax	1585	206	187	237	172	188	236	166	173	267	251	252	238	(16)	
	PrecMin	981	63	39	40	44	34	25	24	27	56	31	59	74	(17)	
	PrecStd	151	35	39	44	30	40	47	39	39	54	49	49	42	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	15.3	12.8	16.2	21.1	26.5	30.0	31.5	30.9	29.0	23.7	19.7	15.4	(19)	
		MCWB	13.7	10.9	11.7	15.5	17.3	20.6	22.4	21.7	21.8	18.3	17.2	13.8	(20)	
	2%	DB	10.6	8.6	12.0	17.6	23.3	27.2	29.5	28.9	25.8	20.7	17.1	12.2	(21)	
		MCWB	9.4	7.0	9.0	12.8	15.6	19.2	21.4	21.0	19.8	16.7	15.2	11.2	(22)	
	5%	DB	6.6	5.6	9.3	15.1	20.9	25.3	28.0	27.1	23.9	18.7	14.8	9.1	(23)	
		MCWB	5.2	4.2	6.8	11.0	14.4	18.1	20.5	19.9	19.1	15.8	13.0	7.9	(24)	
	10%	DB	3.4	3.5	6.7	12.8	18.7	23.5	26.5	25.6	22.2	16.6	12.0	6.2	(25)	
		MCWB	2.3	2.2	4.2	9.0	13.0	17.3	19.6	19.3	18.1	13.9	10.2	4.8	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.9	10.9	12.8	16.8	19.4	22.4	24.1	23.8	22.9	19.7	17.8	14.1	(27)	
		MCDB	15.3	12.3	14.8	19.3	24.3	26.9	28.9	28.3	26.2	21.9	19.4	15.1	(28)	
	2%	WB	9.6	7.4	9.9	14.2	17.5	21.1	23.0	22.6	21.6	17.9	15.5	11.3	(29)	
		MCDB	10.5	8.4	11.7	16.4	21.1	25.3	27.4	26.5	24.6	19.8	16.7	12.3	(30)	
	5%	WB	5.4	4.3	7.1	11.9	15.7	19.9	22.1	21.6	20.3	16.2	13.3	8.1	(31)	
		MCDB	6.5	5.4	8.6	14.1	19.2	23.8	25.7	25.2	22.8	18.1	14.6	8.9	(32)	
	10%	WB	2.3	2.3	4.5	9.5	14.0	18.4	21.1	20.6	19.1	14.3	10.2	5.0	(33)	
		MCDB	3.3	3.3	6.4	12.1	17.5	22.0	24.8	24.0	21.2	16.3	11.6	6.0	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	8.3	8.4	8.3	9.1	10.6	10.8	10.6	10.8	10.5	9.1	7.5	7.2	(35)	
		MCDBR	13.4	10.8	12.2	13.9	14.6	14.0	13.0	12.9	12.3	12.3	11.1	10.9	(36)	
	5% WB	MCWBR	13.1	9.8	9.7	9.6	8.1	7.2	6.3	6.3	7.3	8.8	9.8	10.7	(37)	
		MCWBR	13.4	10.4	11.6	11.4	12.0	11.6	10.3	10.4	10.0	10.2	10.5	10.7	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.294	0.291	0.323	0.349	0.371	0.398	0.423	0.398	0.366	0.332	0.312	0.297	(40)	
		taud	2.455	2.486	2.443	2.410	2.390	2.343	2.299	2.370	2.431	2.527	2.531	2.483	(41)	
	Edn at Noon	Edn at Noon	827	904	913	912	898	871	843	853	854	843	802	785	(42)	
		Edh at Noon	70	81	98	110	116	122	127	114	98	78	65	62	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1.42	2.27	3.44	4.32	4.98	5.44	5.53	5.00	4.01	2.57	1.45	1.09	(44)	
	RadStd	RadStd	0.12	0.17	0.24	0.41	0.57	0.49	0.39	0.34	0.28	0.28	0.16	0.09	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
		N/A	N/A	+0.87	N/A	+0.59	+0.67	N/A	N/A	+64	+30
Regional (41 neighbors)		N/A	N/A	N/A	N/A	+0.34	+0.47	N/A	N/A	+52	N/A

Nomenclature: See separate page