

BEAVER ISLAND, NS, Canada

WMO: 714030

Lat: 44.825N

Lon: 62.339W

Elev: 16

StdP: 101.13

Time Zone: -4.00 (NAA)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-14.3	-12.2	-19.0	0.7	-12.4	-17.1	0.8	-10.8	21.3	-0.1	19.2	0.5	8.7	320	0.837

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.1	20.9	18.6	20.0	18.1	19.2	17.5	19.6	20.4	18.7	19.6	18.0	18.9	5.7	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.2	14.0	20.1	18.4	13.3	19.3	17.7	12.7	18.6	55.9	20.4	53.3	19.7	51.1	18.9	22.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
17.9	15.8	13.8	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
			-17.1	23.4	2.7	1.5	-19.1	24.5	-20.6	25.3	-22.1	26.2	-24.1	27.3
			-18.3	20.8	3.1	1.2	-20.5	21.7	-22.4	22.3	-24.1	23.0	-26.4	23.8
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	6.6	-2.8	-3.3	-0.8	3.0	6.7	10.9	15.0	17.1	15.4	10.8	5.8	0.8	(6)
(7)		DBStd	7.60	4.64	4.07	3.31	2.08	2.03	2.20	2.00	1.74	2.29	2.90	3.59	4.17	(7)
(8)		HDD10.0	1872	397	372	334	211	104	15	0	0	0	26	131	284	(8)
(9)		HDD18.3	4288	655	606	592	461	360	222	103	47	91	233	377	542	(9)
(10)		CDD10.0	637	0	0	0	0	2	43	157	219	162	51	4	0	(10)
(11)		CDD18.3	11	0	0	0	0	0	0	1	7	2	0	0	0	(11)
(12)		CDH23.3	3	0	0	0	0	0	0	1	2	1	0	0	0	(12)
(13)		CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	7.0	8.3	8.1	7.9	7.1	6.0	5.7	5.1	5.5	6.5	7.5	8.1	8.4	(14)
(15)	Precipitation	PrecAvg	1545	138	109	118	112	110	122	118	117	151	159	174	(15)	
(16)		PrecMax	1906	213	166	219	221	185	235	205	211	345	337	255	321	(16)
(17)		PrecMin	1225	70	41	48	41	52	49	55	58	38	53	104	126	(17)
(18)		PrecStd	164	32	35	39	39	35	44	40	37	64	64	44	43	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.2	5.7	7.5	10.7	14.4	18.5	21.6	22.6	22.1	18.1	13.9	10.3	(19)
(20)		MCWB	6.8	5.3	4.7	6.8	9.7	14.5	17.0	19.5	19.6	16.1	13.2	9.8	(20)	
(21)		2%	DB	5.8	4.0	5.2	7.8	11.8	16.2	19.6	21.2	20.3	17.0	12.7	9.0	(21)
(22)		MCWB	5.3	3.3	3.9	5.5	9.2	13.7	17.4	19.0	18.0	15.8	12.0	8.4	(22)	
(23)		5%	DB	4.5	2.7	4.0	6.5	10.5	14.9	18.7	20.4	19.4	16.0	11.7	7.9	(23)
(24)		MCWB	3.9	2.2	3.0	5.0	8.5	12.9	17.1	18.6	17.5	14.8	11.0	7.4	(24)	
(25)		10%	DB	3.4	1.8	3.0	5.5	9.4	13.9	17.8	19.7	18.6	15.0	10.8	6.7	(25)
(26)		MCWB	2.8	1.3	2.0	4.4	7.8	12.4	16.6	18.1	17.0	13.6	9.9	6.0	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.8	4.7	6.0	7.6	11.4	16.2	18.8	20.7	20.9	17.2	13.6	9.8	(27)
(28)		MCDWB	7.0	4.8	6.8	9.0	12.7	17.5	19.6	21.7	22.1	17.5	13.8	9.9	(28)	
(29)		2%	WB	5.2	3.1	4.5	6.2	10.2	14.7	18.0	20.0	19.0	16.3	12.4	8.6	(29)
(30)		MCDWB	5.4	3.3	5.1	7.1	11.2	15.6	18.6	20.8	19.7	16.8	12.8	8.8	(30)	
(31)		5%	WB	3.8	2.1	3.3	5.4	9.1	13.5	17.4	19.2	18.2	15.2	11.3	7.5	(31)
(32)		MCDWB	4.1	2.3	3.9	6.1	9.9	14.3	18.1	20.1	18.9	15.9	11.7	7.8	(32)	
(33)		10%	WB	2.6	1.2	2.2	4.6	8.3	12.6	16.8	18.6	17.5	14.0	10.2	6.2	(33)
(34)		MCDWB	3.1	1.5	2.8	5.3	9.1	13.4	17.5	19.5	18.2	14.8	10.7	6.8	(34)	
(35)	Mean Daily Temperature Range	MDBR	6.5	5.8	4.8	4.1	4.1	4.1	4.0	4.1	4.5	4.5	4.7	5.6	(35)	
(36)		5% DB	MCDBR	7.1	5.6	5.6	5.8	6.0	6.2	5.3	4.9	4.7	5.0	6.0	(36)	
(37)		MCWBR	7.6	5.9	4.9	4.3	4.2	4.3	3.6	3.5	3.8	4.6	5.5	6.4	(37)	
(38)		5% WB	MCDWB	7.0	5.8	5.4	4.8	5.2	5.6	4.3	4.1	3.9	4.5	5.0	5.8	(38)
(39)		MCWBR	7.4	6.2	5.0	4.1	4.2	4.3	3.4	3.3	3.7	4.7	5.7	6.5	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.306	0.305	0.328	0.351	0.375	0.394	0.416	0.395	0.353	0.341	0.324	0.298	(40)	
(41)		taud	2.465	2.496	2.462	2.444	2.423	2.402	2.370	2.426	2.507	2.528	2.522	2.528	(41)	
(42)		Ebn at Noon	813	889	909	911	895	876	851	857	871	834	787	791	(42)	
(43)		Edh at Noon	70	81	96	107	112	115	118	108	92	79	67	60	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.33	2.20	3.47	4.28	4.94	5.33	5.24	4.88	3.99	2.56	1.46	1.06	(44)	
(45)		RadStd	0.10	0.18	0.24	0.36	0.57	0.52	0.37	0.35	0.28	0.26	0.16	0.08	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (31 neighbors)		N/A	N/A	N/A	N/A	N/A	+0.48	N/A	N/A	N/A	N/A

Nomenclature: See separate page