

FEROLLE POINT, NL, Canada

WMO: 714060

Lat: 51.022N

Lon: 57.096W

Elev: 19

StdP: 14.69

Time Zone: -3.50 (NAF)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-4.7	-0.8	-11.3	3.0	-4.0	-6.7	3.9	-0.1	47.6	24.9	42.7	24.5	15.6	270	0.974

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.9	66.4	62.3	64.7	61.2	63.4	60.3	63.3	65.3	62.0	64.0	60.8	62.8	17.1	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
62.3	84.2	64.6	61.0	80.3	63.5	59.7	76.5	62.4	28.8	65.6	27.9	64.0	27.0	62.8	71.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 40.9	36.1	32.2	DB	-9.9	71.8	6.1	2.6	-14.3	73.7	-17.8	75.2	-21.3	76.6	-25.7	78.5	(4)
(5)			WB	-10.7	65.7	5.8	2.3	-14.9	67.4	-18.3	68.7	-21.6	70.0	-25.8	71.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	37.1	18.2	16.2	21.9	31.0	39.0	47.4	56.0	59.0	52.3	43.1	34.4	25.4		
	DBStd	15.58	9.15	9.44	8.79	5.44	4.21	4.66	4.18	3.99	5.20	5.32	6.05	7.85		
	HDD50	5317	985	946	870	571	343	105	7	1	35	224	469	761		
	HDD65	10180	1450	1366	1335	1021	807	529	280	186	381	680	919	1226		
	CDD50	615	0	0	0	0	1	26	193	282	104	9	0	0		
	CDD65	1	0	0	0	0	0	0	0	1	0	0	0	0		
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0		
	WSAvg	16.7	19.0	17.0	16.4	15.7	14.3	14.5	14.9	15.6	17.8	17.5	18.5	19.7		
	PrecAvg	43.9	4.3	3.6	3.8	2.6	2.7	3.2	3.8	4.2	3.9	3.7	3.5	4.4		
(15) Precipitation	PrecMax	59.6	13.9	6.5	7.0	5.3	6.1	7.2	8.7	9.4	8.0	8.1	6.1	6.9		
	PrecMin	34.3	1.9	1.6	2.3	1.5	0.4	1.7	1.5	1.8	2.1	1.9	1.7	1.9		
	PrecStd	5.3	2.4	1.3	1.1	0.9	1.3	1.1	1.4	1.8	1.5	1.5	1.2	1.3		
	PrecStd	5.3	2.4	1.3	1.1	0.9	1.3	1.1	1.4	1.8	1.5	1.5	1.2	1.3		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	41.0	40.2	41.0	49.5	55.1	62.5	68.4	69.4	67.4	58.8	53.7	44.1		
		MCWB	39.1	38.5	38.4	45.7	49.6	57.8	62.8	64.0	63.6	56.0	51.4	42.4		
	2%	DB	36.2	34.1	36.1	43.2	49.9	58.0	64.9	67.0	63.7	55.3	48.6	40.1		
		MCWB	35.2	33.1	34.4	40.2	45.9	53.8	61.0	62.9	60.5	52.7	46.7	38.8		
	5%	DB	33.3	32.1	33.5	39.1	47.1	55.7	63.0	65.6	61.7	52.8	44.9	37.3		
		MCWB	32.4	31.4	32.3	36.8	43.9	52.3	59.7	61.9	58.8	50.4	43.1	35.9		
	10%	DB	30.9	30.1	32.1	36.6	44.9	53.8	61.5	64.4	60.0	50.6	42.1	35.1		
		MCWB	29.9	29.3	31.1	34.6	42.1	50.9	58.5	61.1	57.2	48.1	40.6	33.8		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	39.5	38.9	39.0	45.6	51.0	58.3	64.6	66.2	64.2	56.2	51.1	42.0		
		MCDB	40.6	40.3	40.8	48.4	53.7	61.5	66.8	68.0	66.7	58.0	53.0	43.1		
	2%	WB	35.4	33.2	34.9	40.4	46.5	54.9	62.1	63.8	61.1	53.1	46.5	38.0		
		MCDB	36.1	33.7	36.1	42.6	48.9	57.0	64.0	65.7	62.8	54.8	48.2	38.9		
	5%	WB	32.7	31.2	32.7	36.8	44.4	53.0	60.4	62.8	59.3	50.8	43.1	35.3		
		MCDB	33.4	31.8	33.5	38.5	46.7	55.1	62.3	64.7	61.1	52.5	44.3	36.3		
	10%	WB	30.0	28.8	31.2	34.6	42.4	51.2	58.9	61.7	57.5	48.4	40.5	33.5		
		MCDB	30.8	29.5	32.0	35.9	44.7	53.4	60.9	63.7	59.4	50.2	41.7	34.5		
(35) Mean Daily Temperature Range	5% DB	MDBR	11.1	11.5	10.6	7.8	8.6	8.7	7.8	7.9	7.8	6.9	7.5	8.6		
		MCDBR	12.8	11.3	10.4	11.4	12.5	11.6	9.5	8.7	9.4	9.9	11.7	10.5		
		MCWBR	12.8	11.9	10.0	9.2	8.9	8.2	6.9	6.5	8.1	8.9	11.9	11.6		
		MCDBR	12.7	12.5	10.9	10.8	11.8	10.9	8.5	7.6	9.1	9.8	11.9	10.6		
	5% WB	MCWBR	12.7	12.3	10.6	9.0	9.0	8.7	6.8	6.2	8.6	9.3	11.9	11.0		
		MCWBR	12.7	12.3	10.6	9.0	9.0	8.7	6.8	6.2	8.6	9.3	11.9	11.0		
(40) Clear-Sky Solar Irradiance	taub		0.284	0.284	0.308	0.346	0.376	0.378	0.412	0.381	0.357	0.327	0.296	0.282		
	taud		2.327	2.338	2.305	2.320	2.349	2.387	2.349	2.433	2.472	2.516	2.501	2.374		
	Ebn at Noon		235	270	283	284	279	279	266	270	265	253	234	218		
	Edh at Noon		20	26	33	36	37	36	37	32	28	22	17	17		
(44) All-Sky Solar Radiation	RadAvg		252	448	791	1184	1551	1613	1581	1342	977	586	306	202		
	RadStd		33	70	111	166	129	154	127	91	78	45	30	25		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (9 neighbors)		N/A	N/A	+2.57	N/A	+0.67	+0.99	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page