

FEROLLE POINT, NL, Canada

WMO: 714060

Lat: 51.022N

Lon: 57.096W

Elev: 6

StdP: 101.26

Time Zone: -3.50 (NAF)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-20.4	-18.2	-24.1	0.4	-20.0	-21.5	0.6	-17.8	21.3	-4.0	19.1	-4.2	7.0	270	0.974

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.4	19.1	16.8	18.2	16.2	17.4	15.7	17.4	18.5	16.7	17.8	16.0	17.1	7.7	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.9	12.0	18.1	16.1	11.5	17.5	15.4	10.9	16.9	49.2	18.7	47.0	17.8	44.9	17.1	21.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.3	16.2	14.4	DB	-23.3	22.1	3.4	1.4	-25.7	23.1	-27.7	24.0	-29.6	24.8	-32.1	25.8	(4)
(5)			WB	-23.7	18.7	3.2	1.3	-26.1	19.7	-27.9	20.4	-29.8	21.1	-32.1	22.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	2.8	-7.7	-8.8	-5.6	-0.6	3.9	8.5	13.3	15.0	11.3	6.2	1.3	-3.6
	DBStd	8.65	5.08	5.25	4.88	3.02	2.34	2.59	2.32	2.22	2.89	2.95	3.36	4.36
	HDD10.0	2954	547	526	483	317	191	58	4	1	19	124	261	423
	HDD18.3	5656	806	759	742	567	448	294	156	103	212	378	511	681
	CDD10.0	342	0	0	0	0	1	14	107	157	58	5	0	0
	CDD18.3	1	0	0	0	0	0	0	0	1	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	7.5	8.5	7.6	7.3	7.0	6.4	6.5	6.7	7.0	8.0	7.8	8.3	8.8
Precipitation	PrecAvg	1114	109	92	96	67	69	82	96	107	98	95	90	112
	PrecMax	1514	353	165	177	135	156	182	221	239	204	207	154	176
	PrecMin	870	49	41	58	38	9	42	38	45	53	47	42	47
	PrecStd	134	61	32	27	22	34	29	36	46	38	37	30	33
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	5.0	4.5	5.0	9.7	12.8	17.0	20.2	20.8	19.7	14.9	12.0	6.7
		MCWB	3.9	3.6	3.6	7.6	9.8	14.3	17.1	17.8	17.5	13.3	10.8	5.8
	2%	DB	2.3	1.1	2.3	6.2	9.9	14.4	18.3	19.5	17.6	12.9	9.2	4.5
		MCWB	1.8	0.6	1.3	4.6	7.7	12.1	16.1	17.2	15.9	11.5	8.2	3.8
	5%	DB	0.7	0.1	0.8	4.0	8.4	13.1	17.2	18.7	16.5	11.6	7.2	3.0
		MCWB	0.2	-0.4	0.2	2.6	6.6	11.3	15.4	16.6	14.9	10.2	6.2	2.2
	10%	DB	-0.6	-1.1	0.1	2.6	7.2	12.1	16.4	18.0	15.5	10.3	5.6	1.7
		MCWB	-1.2	-1.5	-0.5	1.4	5.6	10.5	14.7	16.2	14.0	9.0	4.8	1.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.2	3.8	3.9	7.6	10.5	14.6	18.1	19.0	17.9	13.4	10.6	5.6
		MCDB	4.8	4.6	4.9	9.1	12.0	16.4	19.3	20.0	19.3	14.4	11.7	6.2
	2%	WB	1.9	0.7	1.6	4.7	8.1	12.7	16.7	17.7	16.2	11.7	8.1	3.3
		MCDB	2.3	0.9	2.3	5.9	9.4	13.9	17.8	18.7	17.1	12.7	9.0	3.8
	5%	WB	0.4	-0.5	0.4	2.7	6.9	11.7	15.8	17.1	15.1	10.5	6.2	1.8
		MCDB	0.8	-0.1	0.8	3.6	8.2	12.8	16.8	18.1	16.2	11.4	6.9	2.4
	10%	WB	-1.1	-1.8	-0.4	1.4	5.8	10.7	15.0	16.5	14.2	9.1	4.7	0.9
		MCDB	-0.7	-1.4	0.0	2.2	7.0	11.9	16.1	17.6	15.2	10.1	5.4	1.4
Mean Daily Temperature Range	5% DB	MDBR	6.2	6.4	5.9	4.4	4.8	4.8	4.3	4.4	4.3	3.8	4.2	4.8
		MCDBR	7.1	6.3	5.8	6.3	7.0	6.5	5.3	4.9	5.2	5.5	6.5	5.9
		MCWBR	7.1	6.6	5.5	5.1	4.9	4.6	3.8	3.6	4.5	4.9	6.6	6.4
	5% WB	MCDBR	7.0	6.9	6.0	6.0	6.5	6.1	4.7	4.2	5.1	5.5	6.6	5.9
MCWBR		7.0	6.9	5.9	5.0	5.0	4.8	3.8	3.4	4.8	5.1	6.6	6.1	
Clear-Sky Solar Irradiance	taub	0.284	0.284	0.308	0.346	0.376	0.378	0.412	0.381	0.357	0.327	0.296	0.282	
	taud	2.327	2.338	2.305	2.320	2.349	2.387	2.349	2.433	2.472	2.516	2.501	2.374	
	Ebn at Noon	741	852	893	894	878	878	839	850	834	798	737	687	
	Edh at Noon	64	82	103	115	117	114	117	102	88	70	55	53	
All-Sky Solar Radiation	RadAvg	0.79	1.41	2.49	3.73	4.89	5.08	4.99	4.23	3.08	1.85	0.97	0.64	
	RadStd	0.10	0.22	0.35	0.52	0.41	0.49	0.40	0.29	0.24	0.14	0.10	0.08	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (9 neighbors)	N/A	N/A	+1.43	N/A	+0.37	+0.55	N/A	N/A	N/A	N/A

Nomenclature: See separate page