

EAST POINT, PE, Canada

WMO: 714120

Lat: 46.4597N

Lon: 61.9878W

Elev: 25

StdP: 14.68

Time Zone: -4.00 (NAA)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	0.7	4.9	-6.8	3.8	2.0	-2.3	4.9	6.1	44.0	21.3	40.8	21.2	13.7	250	0.776

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	10.4	76.0	69.1	73.7	67.6	71.6	66.5	70.5	74.4	68.9	72.4	67.5	70.7	11.2	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
69.1	107.2	73.0	67.5	101.2	71.2	66.1	96.3	69.8	34.5	74.6	33.1	72.6	32.0	70.8	80.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 39.4	34.3	29.5	DB	-5.0	82.8	4.8	3.0	-8.5	85.0	-11.3	86.8	-14.0	88.5	-17.5	90.7	(4)
(5)			WB	-5.5	73.0	4.7	2.9	-8.9	75.1	-11.7	76.8	-14.4	78.4	-17.8	80.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	43.2	22.9	21.9	27.3	35.5	44.9	55.0	64.6	65.6	59.6	49.4	40.0	30.7	(6)	
	DBStd	16.48	9.14	8.59	7.13	5.37	5.81	5.98	4.20	4.21	5.24	6.07	6.92	7.67	(7)	
	HDD50	3960	840	788	704	437	181	19	0	0	2	86	305	598	(8)	
	HDD65	8067	1305	1208	1169	886	622	303	59	43	176	484	749	1063	(9)	
	CDD50	1492	0	0	0	1	24	169	453	484	288	67	6	0	(10)	
	CDD65	126	0	0	0	0	0	4	48	61	13	0	0	0	(11)	
	CDH74	187	0	0	0	0	1	11	68	89	18	0	0	0	(12)	
	CDH80	12	0	0	0	0	0	1	4	6	1	0	0	0	(13)	
(14) Wind	WSAvg	14.3	16.4	15.2	14.7	14.0	12.8	12.3	11.5	11.6	13.7	15.8	16.4	17.6	(14)	
(15) Precipitation	PrecAvg	42.1	3.5	3.0	3.1	3.1	3.0	3.3	2.9	3.8	4.2	4.6	4.5	4.5	(15)	
	PrecMax	53.1	9.7	8.2	7.1	5.6	5.2	8.6	4.8	8.2	13.1	7.8	9.4	10.9	(16)	
	PrecMin	29.1	1.3	1.0	1.2	1.8	1.5	1.4	1.2	0.9	1.5	1.7	2.4	1.8	(17)	
	PrecStd	6.4	1.8	1.6	1.5	1.1	1.0	1.6	1.1	2.0	2.5	1.7	1.6	1.8	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	45.8	42.8	44.7	56.1	68.2	75.0	79.5	80.0	76.3	68.0	59.2	51.1	(19)	
		MCWB	44.8	41.2	42.4	51.1	58.7	65.4	71.0	71.4	69.0	62.7	57.1	49.9	(20)	
	2%	DB	41.0	38.7	40.4	49.1	60.9	70.0	75.6	76.3	71.9	63.4	55.5	46.9	(21)	
		MCWB	40.0	37.4	38.6	45.4	54.3	63.4	69.1	69.4	66.7	60.1	54.0	45.7	(22)	
	5%	DB	37.8	35.9	37.9	45.1	56.1	66.4	73.2	74.1	69.4	60.7	53.1	44.3	(23)	
		MCWB	36.6	34.7	36.2	42.6	51.0	61.6	67.7	68.1	64.9	57.7	51.5	43.2	(24)	
	10%	DB	35.0	33.3	35.8	42.3	52.7	63.5	71.0	72.1	67.1	58.3	50.3	41.2	(25)	
		MCWB	34.1	32.1	34.1	40.0	48.9	59.3	66.2	66.9	63.4	55.5	48.5	39.7	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	45.2	41.7	43.2	52.3	61.0	67.8	72.7	72.9	70.8	63.9	57.5	50.2	(27)	
		MCDB	45.8	42.4	44.1	55.2	65.8	71.8	77.6	77.5	73.9	66.3	58.7	51.0	(28)	
	2%	WB	40.3	37.7	39.1	46.3	55.3	64.7	70.4	70.8	68.0	60.6	54.5	45.9	(29)	
		MCDB	40.8	38.4	39.9	48.2	59.3	68.3	74.3	74.7	71.2	62.6	55.3	46.6	(30)	
	5%	WB	36.8	34.9	36.5	43.0	51.7	62.1	68.8	69.3	65.8	58.3	51.8	43.4	(31)	
		MCDB	37.6	35.8	37.7	44.8	54.7	65.7	72.0	72.9	68.2	60.4	53.0	44.3	(32)	
	10%	WB	34.1	32.2	34.2	40.3	49.4	59.7	67.3	67.8	64.0	55.9	48.8	40.0	(33)	
		MCDB	34.9	33.1	35.6	41.9	52.5	63.1	70.2	71.3	66.5	58.0	50.2	41.1	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	11.8	11.4	9.6	9.0	10.7	10.5	10.2	10.4	10.0	9.2	9.1	9.5	(35)	
		MCDBR	14.9	13.8	12.5	14.7	18.0	15.9	13.2	13.0	12.8	11.9	12.1	13.1	(36)	
	5% WB	MCWBR	15.5	13.7	11.7	11.9	12.4	10.3	8.3	8.4	9.1	10.2	12.3	13.7	(37)	
		MCWBR	14.9	13.9	12.4	13.9	16.1	14.2	11.8	11.4	11.0	11.1	12.4	13.3	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.301	0.293	0.324	0.351	0.371	0.383	0.411	0.399	0.360	0.345	0.326	0.303	(40)	
		taud	2.387	2.293	2.281	2.400	2.430	2.412	2.383	2.418	2.504	2.502	2.466	2.444	(41)	
	Ebn at Noon		252	279	285	287	284	280	270	269	272	259	241	238	(42)	
		Edh at Noon	23	30	36	35	35	36	37	34	29	25	21	20	(43)	
(44) All-Sky Solar Radiation	RadAvg		314	546	962	1327	1617	1753	1773	1559	1188	727	371	242	(44)	
	RadStd		21	78	102	117	138	144	116	97	101	72	45	21	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+1.06	N/A	+3.47	N/A	N/A	N/A	N/A	N/A	+128	N/A
(47) Regional (27 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page