

CARIBOU POINT, NS, Canada

WMO: 714150

Lat: 45.7643N

Lon: 62.6806W

Elev: 8

StdP: 14.69

Time Zone: -4.00 (NAA)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-0.1	4.1	-8.7	3.5	1.6	-4.2	4.4	5.7	41.0	18.5	36.8	19.2	13.6	270	0.674

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	11.8	81.2	68.7	77.9	67.7	75.0	66.4	71.5	77.7	69.8	75.2	68.2	73.1	10.0	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
69.2	107.2	75.1	67.7	101.8	73.4	66.2	96.6	71.6	35.3	78.0	33.9	75.1	32.5	73.2	76.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 35.9	31.1	27.2	DB	-6.0	87.7	4.9	2.1	-9.6	89.2	-12.4	90.4	-15.2	91.6	-18.8	93.1	(4)
(5)			WB	-6.4	74.1	4.8	1.4	-9.9	75.1	-12.7	76.0	-15.4	76.8	-19.0	77.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	44.8	22.8	22.4	28.9	38.1	48.3	57.9	67.2	67.1	60.8	50.9	41.0	31.1		
	DBStd	17.27	10.41	9.32	7.73	6.59	6.57	6.42	4.82	4.44	5.61	6.34	7.56	8.41		
	HDD50	3695	844	773	654	363	114	7	0	0	1	66	286	587		
	HDD65	7595	1309	1193	1119	807	519	227	33	27	149	439	721	1052		
	CDD50	1806	0	0	0	6	60	245	532	529	326	93	15	0		
	CDD65	231	0	0	0	0	1	15	99	91	24	1	0	0		
	CDH74	835	0	0	0	0	17	80	372	294	70	2	0	0		
	CDH80	134	0	0	0	0	1	11	64	52	6	0	0	0		
(14) Wind	WSAvg	12.4	14.7	13.5	13.0	12.1	10.9	10.0	9.0	9.3	11.3	13.6	15.0	16.2		
(15) Precipitation	PrecAvg	45.4	4.1	3.3	3.5	3.2	3.3	3.0	3.3	3.5	3.9	4.6	4.8	4.9		
	PrecMax	54.0	6.2	6.5	6.1	5.5	6.7	5.9	6.0	8.0	13.7	9.4	8.4	9.3		
	PrecMin	33.7	1.7	1.1	1.7	1.2	1.6	1.1	0.9	1.3	1.0	1.3	2.1	2.5		
	PrecStd	5.4	1.1	1.4	1.3	1.0	1.1	1.4	1.3	1.5	2.7	2.1	1.4	1.5		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.7	50.2	53.6	64.3	76.0	81.4	85.6	85.5	80.2	71.9	64.2	55.8		
		MCWB	51.6	48.0	48.5	55.9	61.0	66.1	71.4	69.9	69.9	62.9	59.7	53.0		
	2%	DB	47.1	43.7	47.6	56.9	67.4	75.8	81.6	80.7	75.7	66.6	60.2	50.6		
		MCWB	45.3	41.3	44.2	51.9	56.8	63.5	69.2	68.9	67.1	60.9	57.1	48.6		
	5%	DB	41.2	38.7	42.8	52.2	62.3	71.3	78.2	77.1	72.1	63.2	56.4	46.0		
		MCWB	38.7	36.3	39.2	48.1	54.6	62.8	68.4	67.6	65.7	58.8	53.6	44.2		
	10%	DB	35.9	34.8	38.5	47.3	57.8	67.4	75.0	74.1	69.3	60.2	52.1	42.1		
		MCWB	33.9	32.9	35.5	43.2	52.2	61.1	67.0	66.8	64.2	56.3	49.2	40.3		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	51.6	47.9	49.1	57.3	63.9	69.7	73.7	73.6	71.8	66.1	60.8	53.4		
		MCDB	53.7	50.5	52.1	62.2	70.6	75.9	82.3	81.0	77.4	69.8	63.3	55.0		
	2%	WB	45.4	41.8	44.6	53.0	59.3	66.7	71.8	71.1	69.3	62.0	57.4	48.8		
		MCDB	46.9	43.5	47.3	56.4	65.0	72.6	78.7	76.8	73.9	65.2	59.6	50.6		
	5%	WB	39.1	36.6	39.7	48.6	55.7	64.1	70.1	69.5	67.0	59.4	53.8	44.3		
		MCDB	40.8	38.3	42.2	51.7	60.7	69.5	75.9	74.7	70.8	62.4	56.2	45.7		
	10%	WB	34.2	33.0	35.7	43.6	52.5	61.4	68.2	68.0	64.9	56.8	49.6	40.4		
		MCDB	35.6	34.6	38.3	46.9	57.3	66.3	73.3	72.9	68.4	59.7	51.8	41.8		
(35) Mean Daily Temperature Range	MDBR		13.4	13.2	11.4	10.9	12.3	12.5	12.5	11.8	11.8	10.4	10.5	10.7		
	5% DB	MCDBR	21.0	18.5	18.4	19.3	21.1	19.6	18.2	16.9	16.3	15.3	16.0	16.2		
		MCWBR	20.8	17.3	16.0	14.4	12.4	10.7	9.1	8.3	9.9	11.6	14.6	16.3		
	5% WB	MCDBR	21.3	18.3	18.0	18.5	18.8	17.3	15.2	13.9	13.5	13.5	15.6	16.0		
		MCWBR	21.4	17.6	16.8	15.7	13.0	11.1	8.9	8.1	9.8	11.8	15.1	16.3		
(40) Clear-Sky Solar Irradiance	taub		0.293	0.292	0.322	0.351	0.371	0.391	0.414	0.401	0.355	0.334	0.317	0.292		
	taud		2.451	2.410	2.383	2.401	2.399	2.379	2.339	2.376	2.485	2.526	2.506	2.505		
	Ebn at Noon		260	283	288	288	284	278	270	269	274	265	249	249		
	Edh at Noon		22	27	32	35	36	37	38	36	30	24	21	19		
(44) All-Sky Solar Radiation	RadAvg		402	645	1041	1315	1562	1698	1735	1565	1215	766	417	299		
	RadStd		33	64	77	121	167	143	121	111	102	81	48	23		

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46) Station Only	DBAvg	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(47) Regional (42 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page