

CARIBOU POINT, NS, Canada

WMO: 714150

Lat: 45.7643N

Lon: 62.6806W

Elev: 2

StdP: 101.30

Time Zone: -4.00 (NAA)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-17.8	-15.5	-22.6	0.5	-16.9	-20.1	0.6	-14.6	18.3	-7.5	16.4	-7.1	6.1	270	0.674

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.6	27.3	20.4	25.5	19.8	23.9	19.1	21.9	25.4	21.0	24.0	20.1	22.8	4.5	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.6	15.3	24.0	19.8	14.5	23.0	19.0	13.8	22.0	64.2	25.6	60.9	24.0	57.8	22.9	24.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.0	13.9	12.2	-21.1	30.9	2.7	1.2	-23.1	31.8	-24.7	32.4	-26.2	33.1	-28.2	34.0
			-21.3	23.4	2.7	0.8	-23.3	24.0	-24.8	24.4	-26.4	24.9	-28.3	25.5
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	7.1	-5.1	-5.3	-1.7	3.4	9.0	14.4	19.5	19.5	16.0	10.5	5.0	-0.5
	DBStd	9.59	5.78	5.18	4.29	3.66	3.65	3.56	2.68	2.47	3.12	3.52	4.20	4.67
	HDD10.0	2053	469	429	363	202	63	4	0	0	1	37	159	326
	HDD18.3	4219	727	663	622	448	288	126	18	15	83	244	401	584
	CDD10.0	1003	0	0	0	3	33	136	296	294	181	52	8	0
	CDD18.3	128	0	0	0	0	1	8	55	51	13	1	0	0
	CDH23.3	464	0	0	0	0	9	44	207	163	39	1	0	0
	CDH26.7	74	0	0	0	0	1	6	36	29	3	0	0	0
(14) Wind	WSAvg	5.5	6.6	6.0	5.8	5.4	4.9	4.5	4.0	4.2	5.1	6.1	6.7	7.3
(15) Precipitation	PrecAvg	1154	104	85	90	81	84	77	83	88	99	118	122	125
	PrecMax	1371	157	166	156	139	169	150	153	203	349	238	213	235
	PrecMin	857	44	28	42	31	40	28	22	34	26	33	53	63
	PrecStd	136	28	35	32	25	28	35	32	38	69	54	36	37
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.1	10.1	12.0	17.9	24.4	27.4	29.8	29.7	26.8	22.2	17.9	13.2
		MCWB	10.9	8.9	9.2	13.3	16.1	18.9	21.9	21.1	21.0	17.2	15.4	11.7
	2%	DB	8.4	6.5	8.7	13.8	19.7	24.3	27.5	27.0	24.3	19.2	15.7	10.3
		MCWB	7.4	5.2	6.8	11.1	13.8	17.5	20.7	20.5	19.5	16.1	14.0	9.2
	5%	DB	5.1	3.7	6.0	11.2	16.9	21.8	25.7	25.1	22.3	17.3	13.6	7.8
		MCWB	3.7	2.4	4.0	8.9	12.6	17.1	20.2	19.8	18.7	14.9	12.0	6.8
	10%	DB	2.1	1.5	3.6	8.5	14.3	19.7	23.9	23.4	20.7	15.7	11.2	5.6
		MCWB	1.1	0.5	1.9	6.2	11.2	16.2	19.4	19.4	17.9	13.5	9.5	4.6
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.9	8.9	9.5	14.1	17.7	21.0	23.1	23.1	22.1	18.9	16.0	11.9
		MCDB	12.0	10.3	11.1	16.8	21.4	24.4	27.9	27.2	25.2	21.0	17.4	12.8
	2%	WB	7.5	5.4	7.0	11.6	15.2	19.3	22.1	21.7	20.7	16.7	14.1	9.4
		MCDB	8.3	6.4	8.5	13.6	18.4	22.6	25.9	24.9	23.3	18.5	15.3	10.3
	5%	WB	4.0	2.6	4.3	9.2	13.1	17.8	21.2	20.8	19.5	15.2	12.1	6.9
		MCDB	4.9	3.5	5.7	11.0	15.9	20.8	24.4	23.7	21.6	16.9	13.4	7.6
	10%	WB	1.2	0.6	2.1	6.5	11.4	16.3	20.1	20.0	18.3	13.8	9.8	4.7
		MCDB	2.0	1.4	3.5	8.3	14.1	19.1	22.9	22.7	20.2	15.4	11.0	5.5
(35) Mean Daily Temperature Range	5% DB	MDBR	7.4	7.3	6.3	6.0	6.8	6.9	7.0	6.6	6.6	5.8	5.8	5.9
		MCDBR	11.7	10.3	10.2	10.7	11.7	10.9	10.1	9.4	9.1	8.5	8.9	9.0
	5% WB	MCWBR	11.6	9.6	8.9	8.0	6.9	6.0	5.0	4.6	5.5	6.5	8.1	9.0
		MCWBR	11.8	10.2	10.0	10.3	10.5	9.6	8.5	7.7	7.5	7.5	8.7	8.9
(40) Clear-Sky Solar Irradiance	taub		0.293	0.292	0.322	0.351	0.371	0.391	0.414	0.401	0.355	0.334	0.317	0.292
		taud	2.451	2.410	2.383	2.401	2.399	2.379	2.339	2.376	2.485	2.526	2.506	2.505
	Ebn at Noon		819	893	909	908	896	876	850	848	864	835	784	784
		Edh at Noon	69	86	102	110	115	118	121	112	93	77	66	59
(44) All-Sky Solar Radiation	RadAvg		1.27	2.03	3.28	4.15	4.92	5.35	5.47	4.93	3.83	2.42	1.31	0.94
	RadStd		0.10	0.20	0.24	0.38	0.53	0.45	0.38	0.35	0.32	0.26	0.15	0.07

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	+0.51	N/A	+2.57	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (42 neighbors)	N/A	N/A	N/A	N/A	N/A	+0.41	N/A	N/A	N/A	+15

Nomenclature: See separate page