

FOURCHU HEAD, NS, Canada

WMO: 714160

Lat: 45.717N

Lon: 60.230W

Elev: 10

StdP: 101.20

Time Zone: -4.00 (NAA)

Period: 86-96

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-17.4	-15.1	-22.7	0.5	-16.2	-20.1	0.6	-14.0	21.2	-0.7	18.6	-0.5	5.4	270	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.1	20.8	16.2	19.3	16.7	18.3	16.3	18.2	19.4	17.5	18.7	16.8	18.0	6.3	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.7	12.7	18.9	17.0	12.1	18.4	16.2	11.5	17.7	51.5	19.4	49.4	18.7	47.3	18.2	21.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.5	14.6	12.9	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	4.9	-5.0	-5.7	-2.6	1.1	4.8	9.3	14.3	16.3	13.6	9.0	4.3	-1.4
	DBStd	8.02	4.71	4.88	3.48	1.93	2.28	2.25	2.31	1.78	2.35	2.93	3.36	4.20
	HDD10.0	2347	464	441	390	267	162	41	0	0	2	54	171	354
	HDD18.3	4911	723	674	648	517	419	272	127	67	143	288	420	613
	CDD10.0	482	0	0	0	0	1	18	133	194	109	24	1	0
	CDD18.3	6	0	0	0	0	0	0	2	3	0	0	0	0
	CDH23.3	15	0	0	0	0	2	0	9	4	0	0	0	0
	CDH26.7	1	0	0	0	0	0	0	1	0	0	0	0	0
Wind	WSAvg	6.4	7.0	6.7	6.7	6.2	5.8	5.4	5.3	5.9	6.1	6.9	7.0	7.2
Precipitation	PrecAvg	1500	148	131	117	112	101	104	88	100	119	153	153	172
	PrecMax	1851	227	182	221	187	177	173	170	228	308	267	241	355
	PrecMin	1151	70	48	47	59	49	51	37	44	43	61	96	97
	PrecStd	152	38	38	42	33	36	37	30	34	60	56	40	53
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	5.4	4.7	5.7	9.3	14.7	20.0	24.5	23.3	20.1	16.2	12.6	7.8
		MCWB	4.8	3.9	1.6	5.2	8.6	13.6	17.5	16.7	16.0	14.7	11.4	6.8
	2%	DB	4.0	2.9	3.2	6.3	10.9	16.0	21.0	20.9	18.4	15.0	11.2	6.7
		MCWB	3.7	2.3	1.9	3.2	7.0	11.3	16.0	16.6	15.9	13.8	10.4	5.9
	5%	DB	2.8	1.7	2.3	4.5	8.5	13.7	18.5	19.7	17.6	14.2	10.4	5.4
		MCWB	2.3	1.2	1.2	2.6	6.0	11.1	16.1	17.2	15.8	12.9	9.5	4.6
	10%	DB	1.6	0.8	1.4	3.3	7.2	12.0	17.0	18.7	17.0	13.5	9.3	4.4
		MCWB	1.0	0.2	0.4	2.0	5.6	10.6	15.3	17.0	15.2	12.2	8.4	3.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.1	4.0	3.7	6.2	10.2	14.7	19.1	19.3	17.6	15.2	12.0	7.2
		MCDB	5.5	4.4	4.0	8.5	13.2	18.5	22.3	20.5	18.4	16.0	12.5	7.8
	2%	WB	3.7	2.5	2.4	4.0	7.7	12.8	17.7	18.7	17.0	14.1	10.7	6.1
		MCDB	4.0	3.0	2.9	5.1	9.3	15.1	19.5	19.9	18.1	14.9	11.2	6.7
	5%	WB	2.4	1.3	1.5	3.1	6.7	11.5	16.4	18.0	16.4	13.4	9.7	4.8
		MCDB	2.8	1.6	2.1	4.0	8.2	12.8	18.1	18.9	17.3	14.1	10.3	5.4
	10%	WB	1.1	0.3	0.7	2.3	5.7	10.7	15.5	17.4	15.7	12.6	8.6	3.5
		MCDB	1.5	0.6	1.3	3.1	6.8	11.9	16.9	18.5	16.7	13.4	9.3	4.2
Mean Daily Temperature Range	5% DB	MDBR	7.2	7.6	5.5	4.2	4.6	4.5	4.5	4.1	5.3	4.9	5.0	5.9
		MCDBR	7.1	6.9	5.7	6.5	8.1	8.3	8.0	5.8	5.9	4.7	5.4	6.9
		MCWBR	7.5	7.2	4.8	4.8	5.1	5.0	4.5	3.9	4.7	4.8	5.6	7.2
	5% WB	MCDBR	7.0	6.6	5.1	5.2	7.2	6.6	6.5	4.4	5.1	4.3	5.1	7.0
	MCWBR	7.5	6.9	4.9	4.4	5.0	4.8	4.3	3.7	4.5	4.8	5.5	7.4	
Clear-Sky Solar Irradiance	taub	0.305	0.298	0.328	0.358	0.372	0.393	0.424	0.395	0.365	0.344	0.326	0.301	
	taud	2.404	2.452	2.420	2.415	2.436	2.409	2.357	2.435	2.499	2.521	2.500	2.474	
	Ebn at Noon	798	888	903	901	896	875	841	855	855	824	772	769	
	Edh at Noon	72	83	99	109	111	114	119	106	92	78	67	62	
All-Sky Solar Radiation	RadAvg	1.15	2.00	3.29	4.22	5.04	5.35	5.31	4.82	3.83	2.41	1.32	0.87	
	RadStd	0.08	0.20	0.24	0.33	0.49	0.48	0.36	0.33	0.27	0.21	0.16	0.07	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (17 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page