

ENGLEEE, NL, Canada

WMO: 714170

Lat: 50.721N

Lon: 56.113W

Elev: 99

StdP: 14.64

Time Zone: -3.50 (NAF)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-2.5	1.2	-9.1	3.4	-1.3	-5.1	4.2	2.3	52.7	12.8	47.9	13.4	19.6	320	0.855

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	13.0	73.3	62.2	70.3	60.9	67.5	59.8	64.8	70.3	62.7	68.0	60.8	65.8	18.1	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
62.5	85.0	67.3	60.3	78.4	65.5	58.5	73.3	63.3	30.0	70.3	28.4	68.1	27.0	65.7	72.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 42.9	36.6	31.6	DB	-7.7	79.4	4.4	2.9	-10.9	81.5	-13.5	83.2	-16.0	84.8	-19.2	86.9	(4)
(5)			WB	-7.9	68.2	4.3	2.1	-11.0	69.7	-13.6	70.9	-16.0	72.1	-19.2	73.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	37.9	18.9	18.5	24.3	32.9	40.0	48.3	57.2	59.3	52.4	42.8	33.7	25.1		
	DBStd	15.38	8.79	9.05	8.31	5.23	4.99	6.44	6.04	5.00	5.72	5.51	5.94	7.55		
	HDD50	5121	965	882	796	513	316	107	10	2	37	233	488	772		
	HDD65	9911	1430	1302	1261	963	777	501	250	186	378	688	938	1237		
	CDD50	706	0	0	0	0	5	57	234	290	110	10	0	0		
	CDD65	19	0	0	0	0	0	1	9	8	1	0	0	0		
	CDH74	60	0	0	0	0	0	3	31	23	3	0	0	0		
	CDH80	2	0	0	0	0	0	0	1	1	0	0	0	0		
	WSAvg	13.6	17.1	16.1	15.0	13.3	11.2	11.0	10.7	10.9	13.3	13.6	15.0	16.5		
	PrecAvg	42.5	4.4	3.7	3.2	2.4	2.8	3.0	3.5	3.7	3.7	3.9	4.1	4.3		
(15) Precipitation	PrecMax	51.3	9.1	5.8	5.7	4.2	5.7	6.0	7.0	7.6	7.8	7.3	7.8	6.3		
	PrecMin	35.2	1.8	1.9	1.3	0.8	0.7	1.2	1.4	1.1	1.3	1.6	1.7	2.0		
	PrecStd	3.9	1.6	1.1	1.1	0.8	1.2	1.0	1.2	1.3	1.2	1.4	1.3	1.3		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	40.6	40.9	43.4	51.2	63.7	72.2	77.4	77.0	71.8	61.1	53.2	42.8		
		MCWB	39.4	38.8	36.7	44.2	53.5	59.4	64.5	65.0	62.3	54.8	50.6	40.7		
	2%	DB	35.7	35.2	38.5	45.5	56.7	67.6	73.7	73.2	67.1	56.8	47.8	38.5		
		MCWB	34.9	33.8	34.2	39.6	47.9	57.6	62.1	62.7	59.4	51.8	45.4	37.5		
	5%	DB	33.0	33.0	35.9	42.3	52.2	63.4	70.3	70.4	64.1	53.6	44.1	36.6		
		MCWB	32.3	31.9	33.0	37.1	45.2	54.8	61.0	61.5	57.8	49.6	42.1	35.7		
	10%	DB	31.0	31.2	33.9	39.6	48.4	59.6	67.1	67.8	61.2	50.6	41.3	34.4		
		MCWB	30.2	30.3	32.0	35.4	43.3	52.6	59.7	60.4	55.7	47.3	39.8	33.6		
	0.4%	WB	39.5	39.0	37.6	46.2	55.2	62.5	67.7	67.4	64.3	56.6	51.4	40.5		
		MCDB	40.1	40.6	40.9	50.0	61.6	69.1	73.6	73.3	69.2	59.6	52.7	41.7		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	35.0	34.1	35.4	40.9	49.6	58.9	64.8	65.0	61.1	52.8	46.1	37.9		
		MCDB	35.4	34.6	37.5	44.3	55.5	65.6	70.3	70.7	65.4	55.6	47.3	38.3		
	5%	WB	32.5	32.1	33.7	38.0	46.1	55.8	62.5	63.1	58.8	50.3	42.7	35.9		
		MCDB	32.9	32.7	35.1	41.2	51.0	62.1	68.0	68.4	62.9	53.0	43.7	36.6		
	10%	WB	30.2	30.1	32.2	36.1	43.4	53.1	60.3	61.2	56.4	47.7	40.1	33.8		
		MCDB	30.8	30.9	33.7	38.7	47.9	59.0	65.7	66.1	60.3	50.1	41.3	34.5		
(35) Mean Daily Temperature Range	5% DB	MDBR	11.6	12.8	12.9	11.5	12.9	14.5	13.9	13.0	12.0	9.6	8.5	9.0		
		MCDBR	11.8	12.0	13.7	15.7	20.1	21.4	18.6	17.0	15.7	13.5	11.7	9.3		
		MCWBR	11.3	10.9	10.7	10.7	12.9	13.0	10.4	9.2	10.0	10.0	11.0	8.7		
		MCDBR	11.4	11.4	12.7	14.3	18.7	20.1	17.2	15.5	14.5	12.5	11.5	8.7		
	5% WB	MCWBR	11.4	10.9	10.6	10.5	13.1	13.8	11.5	10.1	10.7	10.3	11.5	8.6		
(40) Clear-Sky Solar Irradiance	taub		0.285	0.291	0.313	0.352	0.381	0.384	0.411	0.385	0.361	0.328	0.305	0.295		
	taud		2.329	2.311	2.274	2.285	2.331	2.383	2.356	2.423	2.470	2.520	2.466	2.308		
	Ebn at Noon		236	268	281	282	277	277	267	269	264	253	230	210		
	Edh at Noon		21	27	34	38	38	36	37	33	28	23	18	18		
(44) All-Sky Solar Radiation	RadAvg		245	482	863	1244	1544	1620	1620	1358	993	597	304	194		
	RadStd		28	64	118	155	147	160	135	89	87	53	29	21		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	+4.25	N/A	+1.37	+1.71	N/A	N/A	N/A	N/A
Regional (12 neighbors)	N/A	N/A	+2.77	N/A	+0.72	+1.01	N/A	N/A	N/A	N/A

Nomenclature: See separate page