

ENGLEE, NL, Canada

WMO: 714170

Lat: 50.721N

Lon: 56.113W

Elev: 30

StdP: 100.96

Time Zone: -3.50 (NAF)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-19.2	-17.1	-22.8	0.5	-18.5	-20.6	0.6	-16.5	23.5	-10.7	21.4	-10.3	8.7	320	0.855

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.2	22.9	16.8	21.3	16.1	19.7	15.4	18.2	21.3	17.1	20.0	16.0	18.8	8.1	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.0	12.1	19.6	15.7	11.2	18.6	14.7	10.5	17.4	51.8	21.3	48.2	20.1	45.0	18.7	22.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 19.2	16.3	14.1	DB	-22.0	26.3	2.5	1.6	-23.8	27.5	-25.3	28.4	-26.6	29.3	-28.4	30.5	(4)
(5)			WB	-22.2	20.1	2.4	1.2	-23.9	20.9	-25.3	21.6	-26.7	22.3	-28.4	23.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	3.3	-7.3	-7.5	-4.3	0.5	4.4	9.1	14.0	15.2	11.3	6.0	1.0	-3.8	(6)
(7)		DBStd	8.55	4.88	5.03	4.62	2.90	2.77	3.58	3.36	2.78	3.18	3.06	3.30	4.19	(7)
(8)		HDD10.0	2845	536	490	442	285	176	59	6	1	21	129	271	429	(8)
(9)		HDD18.3	5506	794	723	701	535	432	278	139	103	210	382	521	687	(9)
(10)		CDD10.0	392	0	0	0	0	3	32	130	161	61	6	0	0	(10)
(11)		CDD18.3	11	0	0	0	0	0	1	5	4	1	0	0	0	(11)
(12)		CDH23.3	33	0	0	0	0	0	2	17	13	2	0	0	0	(12)
(13)		CDH26.7	1	0	0	0	0	0	0	1	1	0	0	0	0	(13)
(14)	Wind	WSAvg	6.1	7.6	7.2	6.7	6.0	5.0	4.9	4.8	4.9	6.0	6.1	6.7	7.4	(14)
(15)	Precipitation	PrecAvg	1080	111	93	82	62	70	76	90	93	93	99	103	108	(15)
(16)		PrecMax	1304	232	147	145	107	144	153	177	192	197	185	198	161	(16)
(17)		PrecMin	894	46	48	34	20	17	30	36	29	32	41	42	51	(17)
(18)		PrecStd	100	41	28	28	21	31	26	30	32	30	35	34	32	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	4.8	4.9	6.3	10.6	17.6	22.3	25.2	22.1	16.1	11.8	6.0	(19)	
(20)			MCWB	4.1	3.8	2.6	6.8	11.9	15.2	18.1	18.4	16.9	12.6	10.3	4.8	(20)
(21)		2%	DB	2.1	1.8	3.6	7.5	13.7	19.8	23.2	22.9	19.5	13.8	8.8	3.6	(21)
(22)			MCWB	1.6	1.0	1.2	4.2	8.8	14.2	16.7	17.1	15.2	11.0	7.4	3.0	(22)
(23)		5%	DB	0.6	0.5	2.1	5.7	11.2	17.5	21.3	21.4	17.8	12.0	6.7	2.6	(23)
(24)			MCWB	0.2	-0.1	0.6	2.8	7.3	12.6	16.1	16.4	14.3	9.8	5.6	2.0	(24)
(25)		10%	DB	-0.6	-0.5	1.0	4.2	9.1	15.3	19.5	19.9	16.2	10.3	5.2	1.4	(25)
(26)			MCWB	-1.0	-0.9	0.0	1.9	6.3	11.5	15.4	15.8	13.1	8.5	4.3	0.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.1	3.9	3.1	7.9	12.9	16.9	19.8	19.7	17.9	13.7	10.8	4.7	(27)
(28)			MCD B	4.5	4.8	4.9	10.0	16.4	20.6	23.1	22.9	20.7	15.3	11.5	5.4	(28)
(29)		2%	WB	1.7	1.2	1.9	4.9	9.8	14.9	18.2	18.3	16.2	11.6	7.8	3.3	(29)
(30)			MCD B	1.9	1.5	3.0	6.8	13.1	18.6	21.3	21.5	18.5	13.1	8.5	3.5	(30)
(31)		5%	WB	0.3	0.1	0.9	3.4	7.9	13.2	16.9	17.3	14.9	10.2	5.9	2.2	(31)
(32)			MCD B	0.5	0.4	1.7	5.1	10.6	16.7	20.0	20.2	17.2	11.7	6.5	2.5	(32)
(33)		10%	WB	-1.0	-1.0	0.1	2.3	6.3	11.7	15.7	16.2	13.5	8.7	4.5	1.0	(33)
(34)			MCD B	-0.7	-0.6	0.9	3.7	8.8	15.0	18.7	18.9	15.7	10.1	5.1	1.4	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.4	7.1	7.2	6.4	7.2	8.1	7.7	7.2	6.7	5.3	4.7	5.0	(35)
(36)			MCD BR	6.5	6.7	7.6	8.7	11.2	11.9	10.3	9.5	8.7	7.5	6.5	5.1	(36)
(37)			MCWBR	6.3	6.1	5.9	5.9	7.2	7.2	5.8	5.1	5.6	5.5	6.1	4.8	(37)
(38)		5% WB	MCD BR	6.3	6.3	7.0	8.0	10.4	11.2	9.5	8.6	8.0	6.9	6.4	4.8	(38)
(39)			MCWBR	6.3	6.1	5.9	5.8	7.3	7.7	6.4	5.6	6.0	5.7	6.4	4.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.285	0.291	0.313	0.352	0.381	0.384	0.411	0.385	0.361	0.328	0.305	0.295	(40)	
(41)		taud	2.329	2.311	2.274	2.285	2.331	2.383	2.356	2.423	2.470	2.520	2.466	2.308	(41)	
(42)		Ebn at Noon	744	844	887	888	874	873	841	848	832	799	726	663	(42)	
(43)		Edh at Noon	65	85	107	119	120	115	116	104	89	71	58	58	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.77	1.52	2.72	3.92	4.87	5.11	5.11	4.28	3.13	1.88	0.96	0.61	(44)	
(45)		RadStd	0.09	0.20	0.37	0.49	0.46	0.50	0.43	0.28	0.28	0.17	0.09	0.07	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	+2.36	N/A	+0.76	+0.95	N/A	N/A	N/A	N/A
(47) Regional (12 neighbors)		N/A	N/A	+1.54	N/A	+0.40	+0.56	N/A	N/A	N/A	N/A

Nomenclature: See separate page