

HEATH POINT, QC, Canada

WMO: 714230

Lat: 49.085N

Lon: 61.701W

Elev: 23

StdP: 14.68

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-4.4	-0.6	-12.7	2.8	-3.1	-8.3	3.5	0.4	46.0	19.5	42.5	20.0	14.7	320	0.894

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.1	66.2	61.7	64.7	61.1	63.3	60.3	63.7	65.1	62.4	63.9	61.3	62.8	13.3	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
63.0	86.1	64.5	61.7	82.4	63.4	60.5	78.7	62.3	29.0	65.2	28.2	64.0	27.3	62.9	69.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 39.7	35.2	30.8	DB	-9.7	72.2	5.0	2.9	-13.3	74.3	-16.2	76.0	-19.1	77.6	-22.7	79.7	(4)
(5)			WB	-9.7	65.5	6.9	2.4	-14.7	67.3	-18.7	68.7	-22.5	70.0	-27.5	71.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	37.2	17.5	15.8	22.9	31.1	39.2	48.4	56.9	58.6	52.2	43.1	33.8	25.1
	DBStd	15.58	9.00	8.78	7.42	4.33	3.88	4.58	3.61	3.28	4.62	5.06	6.47	7.84
	HDD50	5297	1007	958	841	567	334	82	1	0	29	219	486	773
	HDD65	10156	1472	1378	1306	1017	799	497	253	199	383	678	936	1238
	CDD50	616	0	0	0	0	0	35	213	266	96	6	0	0
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	2	0	0	0	0	0	1	0	1	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	15.1	17.7	16.9	17.0	15.4	13.3	12.6	11.4	12.0	14.1	15.8	17.3	18.1
Precipitation	PrecAvg	57.1	4.6	3.7	3.5	4.1	4.4	4.1	4.6	5.7	5.6	6.3	5.2	5.1
	PrecMax	72.1	7.4	7.9	6.9	6.9	9.4	6.7	10.0	12.0	10.7	9.6	9.4	10.0
	PrecMin	40.4	1.7	1.6	1.3	1.7	1.5	2.0	1.8	1.3	2.8	2.0	2.2	2.5
	PrecStd	6.7	1.5	1.3	1.5	1.3	1.9	1.2	1.8	2.2	2.0	1.9	1.6	2.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	36.9	35.7	36.9	42.8	55.2	65.5	69.0	69.2	65.4	57.9	49.3	42.1
		MCWB	35.5	35.2	33.3	36.6	45.2	53.0	61.4	61.4	59.1	53.7	48.7	41.0
	2%	DB	34.8	32.8	34.4	39.1	49.0	59.6	65.8	66.6	62.1	53.9	46.2	39.9
		MCWB	34.0	31.8	32.3	35.6	44.0	52.4	61.7	62.1	58.8	51.2	45.0	38.9
	5%	DB	32.8	30.9	32.9	37.4	46.3	56.7	64.0	65.2	60.3	52.0	44.3	37.8
		MCWB	32.1	30.0	31.2	35.1	42.5	52.0	60.8	61.7	57.1	49.6	43.1	36.8
	10%	DB	30.7	28.6	31.6	36.0	44.5	54.5	62.5	64.0	59.0	50.3	42.7	35.8
		MCWB	29.7	27.8	30.2	34.0	41.6	51.2	60.0	61.0	56.4	48.3	41.1	34.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	35.8	34.9	34.8	38.8	48.0	58.3	65.1	65.5	62.6	55.3	48.9	41.4
		MCDB	36.2	35.3	35.8	40.7	52.6	61.7	66.6	66.4	63.0	56.5	49.1	41.8
	2%	WB	33.9	31.3	32.7	36.9	45.3	54.9	63.3	64.1	60.0	52.1	45.3	39.2
		MCDB	34.6	31.9	33.7	38.0	47.7	57.4	64.6	65.6	61.1	53.5	45.8	40.0
	5%	WB	32.0	29.3	31.3	35.7	43.6	53.2	61.9	63.0	58.3	50.3	43.3	37.1
		MCDB	32.5	30.0	32.1	36.7	45.8	55.6	63.3	64.5	59.8	51.4	44.0	37.7
	10%	WB	29.6	27.0	30.1	34.4	42.0	51.6	60.7	62.0	56.9	48.8	41.4	34.9
		MCDB	30.3	27.7	30.9	35.5	44.1	53.6	62.2	63.6	58.4	50.0	42.4	35.7
Mean Daily Temperature Range	5% DB	MDBR	13.0	12.5	9.6	6.9	7.8	8.0	8.2	9.1	9.9	9.2	9.1	10.5
		MCDBR	12.7	10.9	8.9	8.7	12.0	13.1	11.2	10.7	10.9	10.3	8.7	9.1
		MCWBR	12.4	12.5	9.2	7.0	8.1	8.4	7.6	8.3	8.4	8.8	9.1	9.5
	5% WB	MCDBR	11.8	12.2	8.9	7.3	10.9	10.8	9.1	9.0	8.9	8.8	8.6	9.3
		MCWBR	12.3	12.5	8.8	6.3	8.0	8.0	7.1	7.7	7.8	8.1	9.4	9.7
Clear-Sky Solar Irradiance	taub	0.293	0.294	0.314	0.344	0.365	0.382	0.412	0.385	0.362	0.347	0.312	0.296	
	taud	2.368	2.346	2.361	2.422	2.429	2.379	2.358	2.436	2.471	2.455	2.474	2.368	
	Ebn at Noon	242	272	285	287	284	279	268	271	266	250	236	224	
	Edh at Noon	21	27	32	34	35	37	37	33	29	25	19	19	
All-Sky Solar Radiation	RadAvg	288	564	1010	1390	1671	1801	1722	1531	1151	713	346	223	
	RadStd	26	47	83	127	124	162	162	93	84	53	37	23	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (4 neighbors)	N/A	N/A	+2.63	N/A	+0.67	+0.77	N/A	N/A	N/A	+5	

Nomenclature: See separate page