

HEATH POINT, QC, Canada

WMO: 714230

Lat: 49.085N

Lon: 61.701W

Elev: 7

StdP: 101.24

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-20.2	-18.1	-24.8	0.4	-19.5	-22.4	0.5	-17.6	20.6	-7.0	19.0	-6.7	6.6	320	0.894

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.0	19.0	16.5	18.2	16.2	17.4	15.7	17.6	18.4	16.9	17.7	16.3	17.1	5.9	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.2	12.3	18.0	16.5	11.8	17.4	15.8	11.2	16.8	49.7	18.4	47.6	17.8	45.7	17.2	21.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 17.8	15.8	13.8	DB	-23.2	22.3	2.8	1.6	-25.2	23.5	-26.8	24.4	-28.4	25.3	-30.4	26.5	(4)
(5)			WB	-23.2	18.6	3.8	1.3	-25.9	19.6	-28.2	20.4	-30.3	21.1	-33.1	22.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	2.9	-8.0	-9.0	-5.1	-0.5	4.0	9.1	13.8	14.8	11.2	6.2	1.0	-3.9	(6)	
	DBStd	8.65	5.00	4.88	4.12	2.41	2.16	2.55	2.01	1.82	2.57	2.81	3.60	4.35	(7)	
	HDD10.0	2943	559	532	467	315	186	46	1	0	16	122	270	429	(8)	
	HDD18.3	5642	818	766	726	565	444	276	141	111	213	377	520	688	(9)	
	CDD10.0	342	0	0	0	0	0	19	118	148	53	3	0	0	(10)	
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)	
	CDH23.3	1	0	0	0	0	0	1	0	1	0	0	0	0	(12)	
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)	
(14) Wind	WSAvg	6.8	7.9	7.6	7.6	6.9	5.9	5.6	5.1	5.4	6.3	7.1	7.7	8.1	(14)	
(15) Precipitation	PrecAvg	1450	117	95	90	105	113	104	117	144	143	161	132	130	(15)	
	PrecMax	1832	187	200	174	174	239	169	254	305	271	245	239	254	(16)	
	PrecMin	1026	42	40	32	42	37	51	46	34	71	52	55	63	(17)	
	PrecStd	171	39	34	38	34	48	31	45	55	50	47	41	50	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	2.7	2.1	2.7	6.0	12.9	18.6	20.6	20.7	18.5	14.4	9.6	5.6	(19)	
		MCWB	2.0	1.8	0.7	2.5	7.3	11.7	16.3	16.3	15.1	12.1	9.3	5.0	(20)	
	2%	DB	1.6	0.5	1.4	4.0	9.4	15.3	18.8	19.2	16.7	12.2	7.9	4.4	(21)	
		MCWB	1.1	-0.1	0.2	2.0	6.7	11.3	16.5	16.7	14.9	10.7	7.2	3.8	(22)	
	5%	DB	0.4	-0.6	0.5	3.0	7.9	13.7	17.8	18.5	15.7	11.1	6.8	3.2	(23)	
		MCWB	0.0	-1.1	-0.5	1.7	5.9	11.1	16.0	16.5	13.9	9.8	6.1	2.7	(24)	
	10%	DB	-0.7	-1.9	-0.2	2.2	6.9	12.5	17.0	17.8	15.0	10.2	5.9	2.1	(25)	
		MCWB	-1.3	-2.3	-1.0	1.1	5.3	10.6	15.6	16.1	13.6	9.0	5.1	1.5	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	2.1	1.6	1.5	3.8	8.9	14.6	18.4	18.6	17.0	12.9	9.4	5.2	(27)	
		MCDB	2.3	1.8	2.1	4.8	11.5	16.5	19.2	19.1	17.2	13.6	9.5	5.4	(28)	
	2%	WB	1.0	-0.4	0.4	2.7	7.4	12.7	17.4	17.9	15.5	11.2	7.4	4.0	(29)	
		MCDB	1.4	-0.1	0.9	3.3	8.7	14.1	18.1	18.7	16.2	12.0	7.7	4.4	(30)	
	5%	WB	0.0	-1.5	-0.4	2.1	6.4	11.8	16.6	17.2	14.6	10.2	6.3	2.8	(31)	
		MCDB	0.3	-1.1	0.0	2.6	7.7	13.1	17.4	18.1	15.4	10.8	6.7	3.2	(32)	
	10%	WB	-1.3	-2.8	-1.1	1.3	5.6	10.9	15.9	16.7	13.8	9.3	5.2	1.6	(33)	
		MCDB	-0.9	-2.4	-0.6	1.9	6.7	12.0	16.8	17.6	14.7	10.0	5.8	2.0	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	7.2	7.0	5.4	3.8	4.3	4.5	4.6	5.0	5.5	5.1	5.1	5.8	(35)	
		MCDBR	7.0	6.0	5.0	4.8	6.7	7.3	6.2	5.9	6.0	5.7	4.8	5.1	(36)	
	5% WB	MCWBR	6.9	7.0	5.1	3.9	4.5	4.6	4.2	4.6	4.7	4.9	5.1	5.3	(37)	
		MCWBR	6.6	6.8	5.0	4.0	6.1	6.0	5.0	5.0	4.9	4.9	4.8	5.2	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.293	0.294	0.314	0.344	0.365	0.382	0.412	0.385	0.362	0.347	0.312	0.296	(40)	
		taud	2.368	2.346	2.361	2.422	2.429	2.379	2.358	2.436	2.471	2.455	2.474	2.368	(41)	
	Edn at Noon	Edn at Noon	764	858	899	906	895	878	844	854	839	787	743	705	(42)	
		Edh at Noon	67	86	100	106	109	116	117	104	91	78	61	59	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	0.91	1.78	3.18	4.38	5.27	5.68	5.43	4.83	3.63	2.25	1.09	0.70	(44)	
	RadStd	RadStd	0.08	0.15	0.26	0.40	0.39	0.51	0.51	0.29	0.26	0.17	0.12	0.07	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (4 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		N/A	N/A	+1.46	N/A	+0.37	+0.43	N/A	N/A	N/A	+3

Nomenclature: See separate page