

POINTE-DES-MONTS, QC, Canada

WMO: 714270

Lat: 49.326N

Lon: 67.367W

Elev: 19

StdP: 14.69

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-10.8	-6.6	-21.5	1.7	-9.7	-16.9	2.2	-5.3	42.6	19.3	39.6	17.9	12.2	270	0.818

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.8	67.4	61.1	65.1	60.1	63.2	58.9	63.1	65.7	61.3	63.8	59.8	62.2	10.3	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
61.9	82.7	64.7	60.1	77.5	62.9	58.5	73.2	61.4	28.6	66.0	27.4	63.8	26.3	62.5	72.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
35.5	29.9	25.8	-15.7	75.6	3.9	3.8	-18.5	78.3	-20.8	80.5	-23.0	82.6	-25.9	85.3		
			-17.6	66.5	4.4	2.9	-20.8	68.6	-23.3	70.3	-25.8	71.9	-29.0	74.0		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	36.8	12.3	14.4	23.1	33.3	44.0	53.0	57.8	56.8	50.9	41.9	32.1	20.4	(6)
(7)		DBStd	17.16	10.78	9.99	8.67	5.56	4.80	4.30	3.54	4.19	4.45	4.56	6.84	9.45	(7)
(8)		HDD50	5467	1169	997	835	502	196	18	0	3	41	253	536	917	(8)
(9)		HDD65	10302	1634	1417	1300	952	652	361	225	253	424	716	986	1382	(9)
(10)		CDD50	641	0	0	0	0	9	107	241	215	67	2	0	0	(10)
(11)		CDD65	2	0	0	0	0	0	0	1	1	0	0	0	0	(11)
(12)		CDH74	5	0	0	0	0	0	3	1	1	0	0	0	0	(12)
(13)		CDH80	1	0	0	0	0	0	1	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	12.0	13.5	12.7	12.5	11.8	11.1	10.9	10.8	10.6	11.5	12.1	12.8	13.3	(14)
(15)	Precipitation	PrecAvg	42.8	3.1	2.6	2.7	3.2	3.5	3.5	4.6	3.6	3.7	4.8	3.7	3.5	(15)
(16)		PrecMax	48.3	6.2	5.1	4.6	5.2	6.7	6.1	10.8	9.0	8.2	7.9	6.3	6.3	(16)
(17)		PrecMin	33.5	1.1	1.3	0.9	1.1	1.2	1.7	2.6	1.5	1.4	2.1	1.0	1.9	(17)
(18)		PrecStd	3.9	1.3	1.0	1.1	1.3	1.3	1.1	1.7	1.8	1.4	1.6	1.2	1.2	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	37.2	36.8	41.1	48.9	61.5	70.1	71.1	70.0	65.8	55.9	47.9	40.2	(19)
(20)		MCWB	35.2	35.2	34.7	41.0	52.0	55.4	62.9	62.8	59.0	50.6	45.4	38.4	(20)	
(21)		2%	DB	33.3	33.1	37.3	44.5	56.5	64.4	67.7	66.7	61.2	51.7	44.3	37.4	(21)
(22)		MCWB	32.2	31.7	33.9	39.0	49.4	57.0	61.7	62.0	56.8	48.1	42.4	35.7	(22)	
(23)		5%	DB	30.9	30.8	35.0	41.9	53.5	61.6	65.4	64.6	58.9	49.6	42.4	35.1	(23)
(24)		MCWB	29.8	29.7	32.3	37.4	48.2	55.4	60.7	60.5	55.1	46.5	40.6	33.6	(24)	
(25)		10%	DB	28.2	28.8	33.2	39.8	51.1	59.4	63.4	63.0	57.1	48.0	40.8	33.3	(25)
(26)		MCWB	27.0	27.6	31.1	36.2	46.4	54.3	59.3	59.4	53.8	45.2	39.2	31.8	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	35.7	35.4	37.1	43.6	53.9	61.1	65.7	65.7	61.0	51.7	45.9	39.1	(27)
(28)		MDCB	36.4	36.1	39.1	46.9	57.6	65.1	69.0	67.9	62.7	53.5	47.0	39.7	(28)	
(29)		2%	WB	32.5	32.1	34.3	40.3	51.0	58.6	63.3	63.3	57.6	49.0	42.8	36.0	(29)
(30)		MDCB	33.3	32.8	36.2	43.2	54.7	62.1	66.1	65.7	59.7	50.8	43.9	36.7	(30)	
(31)		5%	WB	29.8	30.0	32.8	38.4	49.0	56.7	61.5	61.5	55.7	47.3	41.0	34.1	(31)
(32)		MDCB	30.6	30.7	34.5	41.0	52.4	60.1	64.1	63.9	58.0	49.0	42.1	35.0	(32)	
(33)		10%	WB	27.0	27.7	31.5	36.7	47.2	55.0	60.0	60.1	54.2	45.8	39.5	32.2	(33)
(34)		MDCB	28.1	28.7	33.0	39.2	50.3	58.2	62.5	62.3	56.4	47.4	40.8	33.2	(34)	
(35)	Mean Daily Temperature Range	MDBR	14.0	13.0	11.5	9.2	10.1	10.4	9.8	9.6	9.1	8.2	8.5	11.2	(35)	
(36)		5% DB	MCDBR	14.4	11.0	10.5	12.0	14.4	15.0	13.0	11.6	11.2	10.0	8.2	8.9	(36)
(37)		MCWBR	14.3	10.8	9.1	9.0	9.9	9.5	8.9	8.1	8.3	8.0	8.1	8.9	(37)	
(38)		5% WB	MCDBR	14.5	10.6	9.9	10.8	12.7	13.1	11.4	10.3	10.0	8.7	7.9	8.9	(38)
(39)		MCWBR	14.7	10.6	9.2	8.8	9.5	9.2	8.9	7.8	8.3	7.7	8.1	9.2	(39)	
(40)		Clear-Sky Solar Irradiance	taub	0.270	0.277	0.301	0.362	0.369	0.393	0.414	0.394	0.369	0.335	0.298	0.274	(40)
(41)	taud		2.355	2.317	2.324	2.269	2.373	2.362	2.345	2.400	2.443	2.505	2.492	2.395	(41)	
(42)	Ebn at Noon		252	279	289	280	282	275	267	268	263	255	241	234	(42)	
(43)	Edh at Noon		21	28	33	39	37	37	37	34	30	23	19	18	(43)	
(44)	All-Sky Solar Radiation	RadAvg	365	670	1067	1414	1666	1789	1728	1483	1096	657	341	255	(44)	
(45)		RadStd	42	66	70	125	105	125	171	87	84	52	40	26	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	-2
(47)	Regional (11 neighbors)	N/A	N/A	+2.38	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page