

COVE ISLAND, ON, Canada

WMO: 714390

Lat: 45.327N

Lon: 81.735W

Elev: 593

StdP: 14.38

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-1.9	2.9	-9.4	3.4	-0.6	-4.9	4.3	4.7	36.8	21.2	35.2	21.9	14.7	320	0.658

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.9	75.4	67.5	73.4	66.7	71.9	65.4	69.9	73.1	68.4	71.9	67.2	70.8	8.3	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
68.6	107.3	72.1	67.1	101.9	71.0	65.7	96.8	69.9	34.2	73.2	33.1	72.0	32.0	70.9	75.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 33.3	29.5	26.1	-7.6	79.7	7.0	2.5	-12.7	81.5	-16.8	83.0	-20.8	84.4	-25.9	86.2		
(5)			-9.3	71.3	6.5	1.7	-14.0	72.6	-17.7	73.6	-21.4	74.5	-26.0	75.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	44.0	22.1	22.4	28.2	37.4	46.9	56.9	64.5	66.5	61.8	50.6	38.8	30.3
	DBStd	17.12	10.20	9.69	8.12	5.95	5.71	5.97	4.57	4.08	6.04	6.78	7.35	8.56
	HDD50	3864	864	773	676	381	133	9	0	0	2	77	340	609
	HDD65	7841	1329	1193	1141	829	562	253	65	32	131	445	787	1074
	CDD50	1667	0	0	0	1	36	214	450	510	356	97	3	0
	CDD65	172	0	0	0	0	0	9	50	78	35	0	0	0
	CDH74	132	0	0	0	0	1	18	43	57	13	0	0	0
	CDH80	5	0	0	0	0	0	1	2	2	0	0	0	0
Wind	WSAvg	12.1	15.5	14.2	12.9	12.2	9.8	8.7	9.2	9.3	10.3	13.6	14.9	14.9
Precipitation	PrecAvg	39.0	2.9	2.1	2.2	3.2	3.5	3.3	3.3	3.7	3.9	4.3	3.5	3.0
	PrecMax	46.1	4.7	4.4	5.5	5.8	6.1	5.6	5.4	6.6	7.6	7.0	5.4	6.1
	PrecMin	31.9	1.5	0.8	0.3	1.2	1.3	1.1	1.5	1.9	1.5	1.9	1.6	1.3
	PrecStd	3.8	0.8	0.9	1.1	1.1	1.2	1.1	1.1	1.1	1.4	1.4	1.0	0.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	43.9	42.9	49.0	58.3	68.2	76.5	78.0	78.8	75.9	67.9	57.0	50.3
		MCWB	42.5	39.8	43.6	49.6	56.9	64.4	67.9	68.8	67.9	62.2	53.2	48.6
	2%	DB	39.7	39.1	44.3	52.3	62.3	71.8	74.8	75.4	73.1	64.3	53.7	45.9
		MCWB	38.0	35.8	40.6	46.5	54.1	62.3	66.8	68.8	66.8	59.7	50.6	43.4
	5%	DB	37.5	36.7	40.1	47.9	58.3	68.4	72.7	73.4	71.8	61.7	51.3	43.3
		MCWB	35.6	34.4	36.7	42.3	51.6	61.9	65.8	67.4	65.4	57.5	48.2	40.6
	10%	DB	35.5	34.7	37.2	44.4	55.0	65.6	70.8	71.9	70.9	59.4	49.0	41.1
		MCWB	33.8	32.7	34.4	39.0	49.1	59.9	65.1	65.6	65.1	54.8	46.0	38.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	42.9	41.9	45.2	53.2	60.8	67.5	71.1	71.9	70.5	63.6	53.8	49.0
		MCDB	43.8	42.7	48.0	55.7	65.2	73.0	74.9	75.5	73.3	66.2	55.9	50.3
	2%	WB	38.5	36.4	40.8	46.8	56.3	65.1	69.1	70.2	68.8	60.8	50.8	43.6
		MCDB	39.4	37.9	43.9	51.4	61.1	70.0	72.4	73.7	72.0	63.6	53.2	45.3
	5%	WB	36.0	34.5	37.2	42.6	52.5	63.0	67.5	68.9	67.3	58.1	48.5	40.9
		MCDB	37.1	36.3	39.3	46.9	56.9	67.2	71.1	72.3	70.9	60.9	50.9	42.7
	10%	WB	33.7	32.7	34.8	39.8	49.8	60.7	66.1	67.6	65.6	56.0	46.1	38.4
		MCDB	35.5	34.7	36.8	43.5	54.2	65.0	70.0	70.9	69.4	59.4	48.7	40.7
Mean Daily Temperature Range	5% DB	MDBR	10.5	10.4	9.3	8.7	10.5	10.8	8.5	6.9	7.3	7.2	8.0	8.4
		MCDBR	9.8	9.1	11.2	15.3	16.8	14.8	11.0	9.5	8.0	9.6	9.8	8.4
		MCWBR	9.9	8.8	8.3	10.0	10.9	8.5	6.3	6.0	5.9	7.8	9.5	8.8
	5% WB	MCDBR	10.1	9.3	10.6	14.8	16.7	13.0	10.1	8.1	7.0	9.1	9.6	8.9
		MCWBR	10.2	9.5	8.9	11.2	12.7	9.0	6.8	6.4	6.2	8.4	9.5	9.3
Clear-Sky Solar Irradiance	taub	0.291	0.299	0.303	0.346	0.367	0.396	0.402	0.396	0.371	0.354	0.318	0.283	
	taud	2.464	2.390	2.432	2.360	2.419	2.356	2.378	2.386	2.433	2.440	2.493	2.529	
	Ebn at Noon	263	281	296	290	286	277	273	271	269	257	249	256	
	Edh at Noon	22	28	31	36	36	38	37	36	31	27	21	19	
All-Sky Solar Radiation	RadAvg	364	651	1116	1475	1768	1932	1959	1663	1276	750	402	261	
	RadStd	43	60	109	132	168	140	84	86	119	84	63	26	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (29 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page