

EAGLESHAM AGCM, AB, CanadaWMO: **714610**Lat: **55.8081N**Lon: **117.8867W**Elev: **1847**StdP: **13.74**Time Zone: **-7.00 (NAM)**Period: **08-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-27.8	-22.2	-34.4	0.8	-27.5	-28.2	1.2	-21.8	27.4	38.1	23.6	36.7	3.3	100	0.674

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	22.8	82.3	61.3	79.2	59.9	76.3	59.4	65.2	76.9	63.3	74.9	61.7	72.6	8.5	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
60.8	85.2	70.5	58.8	79.4	67.9	57.0	74.1	65.7	31.1	77.2	29.7	75.0	28.4	73.0	72.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 22.4	19.2	16.7	DB	-35.1	87.0	5.5	2.4	-39.0	88.7	-42.3	90.1	-45.4	91.5	-49.4	93.2	(4)
(5)			WB	-35.3	68.9	5.5	2.9	-39.2	71.0	-42.4	72.7	-45.5	74.3	-49.5	76.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	36.4	11.7	11.4	21.7	38.0	51.9	58.8	61.7	59.8	51.6	38.9	20.5	9.0		
	DBStd	22.61	16.65	15.80	14.56	9.27	7.90	5.75	4.41	5.80	8.00	8.77	13.44	15.02		
	HDD50	6182	1189	1080	877	369	74	5	0	3	75	354	884	1272		
	HDD65	10493	1654	1500	1342	810	409	198	121	177	403	808	1334	1737		
	CDD50	1214	0	0	0	9	132	269	362	307	124	11	0	0		
	CDD65	50	0	0	0	0	2	12	18	16	2	0	0	0		
	CDH74	1156	0	0	0	9	106	230	382	328	101	0	0	0		
	CDH80	215	0	0	0	2	19	37	66	77	14	0	0	0		
	WSAvg	7.3	7.2	6.7	7.1	8.6	8.8	8.0	6.5	6.3	7.2	7.9	6.9	6.8		
	PrecAvg	19.1	1.3	0.7	0.7	0.8	1.9	3.3	3.1	2.4	1.6	1.0	1.1	1.0		
(15) Precipitation	PrecMax	27.1	3.7	1.6	1.4	1.7	3.9	5.9	4.8	5.2	4.6	2.1	2.9	2.0		
	PrecMin	12.6	0.3	0.2	0.2	0.1	0.7	1.7	1.1	0.9	0.2	0.3	0.3	0.2		
	PrecStd	3.6	0.9	0.4	0.4	0.4	0.9	1.1	1.2	1.1	1.0	0.5	0.7	0.5		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	44.1	43.7	51.6	72.9	82.6	84.6	85.7	86.9	81.7	70.3	50.8	42.3		
		MCWB	38.0	37.5	42.7	52.0	55.9	62.4	65.5	63.3	59.7	53.3	42.5	36.1		
	2%	DB	41.9	40.6	46.7	63.9	76.6	79.6	81.5	81.7	76.9	61.1	44.4	38.9		
		MCWB	36.9	35.9	38.8	46.0	53.5	58.8	62.5	62.6	58.8	48.6	38.9	34.1		
	5%	DB	39.6	37.7	43.0	57.3	72.2	76.3	78.2	77.3	71.7	56.4	41.2	35.3		
		MCWB	35.5	33.8	36.7	43.5	51.4	57.6	61.5	61.2	56.5	45.7	36.5	31.3		
	10%	DB	36.3	34.0	40.0	52.5	68.4	72.8	75.1	73.9	66.4	52.3	37.6	30.8		
		MCWB	32.8	30.8	34.9	41.2	49.8	56.3	60.8	60.1	53.3	43.3	33.7	28.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	38.6	38.6	43.3	52.6	57.9	64.7	68.9	67.1	62.9	54.6	43.7	37.1		
		MCDB	43.3	42.6	50.1	72.0	75.9	78.1	80.3	78.4	77.7	66.1	48.9	41.4		
	2%	WB	37.1	36.0	39.4	47.5	55.0	62.2	65.9	64.8	59.6	50.1	39.6	34.2		
		MCDB	41.2	39.6	45.7	61.6	69.8	75.3	76.5	77.0	72.5	59.3	44.5	38.4		
	5%	WB	35.7	33.9	37.0	44.1	53.0	59.6	63.9	63.0	57.1	46.7	36.6	31.4		
		MCDB	39.5	37.6	42.4	55.3	69.3	71.8	74.6	74.5	69.2	53.8	40.5	35.1		
	10%	WB	32.9	30.7	35.0	41.6	51.3	57.8	62.0	61.3	54.7	44.3	34.1	27.8		
		MCDB	36.3	34.1	39.6	51.3	65.8	69.3	72.3	71.8	65.3	51.3	37.4	30.8		
(35) Mean Daily Temperature Range	5% DB	MDBR	16.3	17.5	19.0	19.5	24.5	21.4	22.8	23.9	22.8	17.2	15.1	15.6		
		MCDBR	15.8	17.2	19.9	29.2	31.2	28.5	29.9	30.8	31.6	24.0	17.2	19.6		
		MCWBR	12.6	13.7	13.3	15.1	13.6	11.8	14.0	13.9	14.9	13.6	12.5	16.6		
	5% WB	MCDBR	15.9	16.3	19.6	27.4	28.0	24.7	27.0	27.1	30.0	22.7	17.4	19.6		
		MCWBR	13.0	13.2	13.4	14.9	12.9	11.4	14.8	14.3	15.1	13.9	13.4	16.8		
(40) Clear-Sky Solar Irradiance	taub		0.245	0.249	0.298	0.331	0.345	0.353	0.355	0.354	0.313	0.286	0.244	0.232		
	taud		2.266	2.350	2.295	2.361	2.387	2.387	2.403	2.391	2.517	2.546	2.417	2.208		
	Ebn at Noon		220	270	277	283	284	282	279	272	272	254	226	193		
	Edh at Noon		16	22	30	33	35	35	34	32	25	19	14	13		
(44) All-Sky Solar Radiation	RadAvg		232	541	1027	1492	1777	1918	1870	1521	1037	555	249	161		
	RadStd		23	44	82	90	127	150	119	128	87	66	21	14		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (20 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+103	N/A

Nomenclature: See separate page