

EAGLESHAM AGCM, AB, CanadaWMO: **714610**Lat: **55.8081N**Lon: **117.8867W**Elev: **563**StdP: **94.74**Time Zone: **-7.00 (NAM)**Period: **08-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-33.2	-30.1	-36.9	0.1	-33.1	-33.4	0.2	-29.9	12.3	3.4	10.6	2.6	1.5	100	0.674

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.6	28.0	16.3	26.2	15.5	24.6	15.2	18.5	24.9	17.4	23.8	16.5	22.6	3.8	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.0	12.2	21.4	14.9	11.3	20.0	13.9	10.6	18.7	54.4	25.1	51.2	23.9	48.2	22.8	22.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10.0	8.6	7.4	-37.3	30.6	3.1	1.3	-39.5	31.5	-41.3	32.3	-43.0	33.0	-45.2	34.0
			-37.4	20.5	3.1	1.6	-39.6	21.7	-41.3	22.6	-43.1	23.5	-45.3	24.7
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	2.4	-11.3	-11.4	-5.7	3.3	11.0	14.9	16.5	15.5	10.9	3.9	-6.4	-12.8
	DBStd	12.56	9.25	8.78	8.09	5.15	4.39	3.20	2.45	3.22	4.45	4.87	7.47	8.34
	HDD10.0	3434	661	600	487	205	41	3	0	2	42	197	491	707
	HDD18.3	5829	919	833	746	450	227	110	67	98	224	449	741	965
	CDD10.0	674	0	0	0	5	73	149	201	171	69	6	0	0
	CDD18.3	28	0	0	0	0	1	7	10	9	1	0	0	0
	CDH23.3	642	0	0	0	5	59	128	212	182	56	0	0	0
	CDH26.7	119	0	0	0	1	11	21	37	43	8	0	0	0
Wind	WSAvg	3.3	3.2	3.0	3.2	3.8	4.0	3.6	2.9	2.8	3.2	3.5	3.1	3.0
Precipitation	PrecAvg	486	32	19	19	20	49	85	78	60	40	26	29	26
	PrecMax	688	93	41	36	43	98	151	122	132	118	54	73	50
	PrecMin	320	8	5	5	3	18	43	27	22	4	7	8	5
	PrecStd	91	23	9	10	10	24	29	30	28	26	12	19	13
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.7	6.5	10.9	22.7	28.1	29.2	29.9	30.5	27.6	21.3	10.5	5.7
		MCWB	3.3	3.1	6.0	11.1	13.3	16.9	18.6	17.4	15.4	11.8	5.8	2.3
	2%	DB	5.5	4.8	8.1	17.7	24.8	26.4	27.5	27.6	25.0	16.1	6.9	3.8
		MCWB	2.7	2.2	3.8	7.8	12.0	14.9	17.0	17.0	14.9	9.2	3.8	1.2
	5%	DB	4.2	3.2	6.1	14.0	22.3	24.6	25.7	25.2	22.1	13.5	5.1	1.8
		MCWB	1.9	1.0	2.6	6.4	10.8	14.2	16.4	16.2	13.6	7.6	2.5	-0.4
	10%	DB	2.4	1.1	4.4	11.4	20.2	22.7	24.0	23.3	19.1	11.3	3.1	-0.6
		MCWB	0.5	-0.6	1.6	5.1	9.9	13.5	16.0	15.6	11.8	6.3	1.0	-2.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.7	3.7	6.3	11.5	14.4	18.2	20.5	19.5	17.2	12.6	6.5	2.8
		MCDB	6.3	5.9	10.0	22.2	24.4	25.6	26.9	25.8	25.4	18.9	9.4	5.2
	2%	WB	2.8	2.2	4.1	8.6	12.8	16.8	18.8	18.2	15.4	10.1	4.2	1.2
		MCDB	5.1	4.2	7.6	16.4	21.0	24.1	24.7	25.0	22.5	15.1	6.9	3.6
	5%	WB	2.0	1.0	2.8	6.7	11.7	15.3	17.7	17.2	13.9	8.2	2.6	-0.3
		MCDB	4.1	3.1	5.8	12.9	20.7	22.1	23.7	23.6	20.6	12.1	4.7	1.7
	10%	WB	0.5	-0.7	1.7	5.3	10.7	14.3	16.7	16.3	12.6	6.8	1.2	-2.3
		MCDB	2.4	1.2	4.2	10.7	18.8	20.7	22.4	22.1	18.5	10.7	3.0	-0.7
Mean Daily Temperature Range	5% DB	MDBR	9.0	9.7	10.6	10.8	13.6	11.9	12.6	13.3	12.7	9.6	8.4	8.6
		MCDBR	8.8	9.6	11.0	16.2	17.3	15.8	16.6	17.1	17.5	13.3	9.6	10.9
		MCWBR	7.0	7.6	7.4	8.4	7.5	6.5	7.8	7.7	8.3	7.5	7.0	9.2
	5% WB	MCDBR	8.8	9.0	10.9	15.2	15.5	13.7	15.0	15.1	16.7	12.6	9.6	10.9
		MCWBR	7.2	7.3	7.4	8.3	7.1	6.3	8.2	7.9	8.4	7.7	7.5	9.3
Clear-Sky Solar Irradiance	taub	0.245	0.249	0.298	0.331	0.345	0.353	0.355	0.354	0.313	0.286	0.244	0.232	
	taud	2.266	2.350	2.295	2.361	2.387	2.387	2.403	2.391	2.517	2.546	2.417	2.208	
	Ebn at Noon	693	851	873	891	896	890	881	857	856	802	711	608	
	Edh at Noon	52	70	96	105	109	111	107	102	78	59	44	42	
All-Sky Solar Radiation	RadAvg	0.73	1.71	3.24	4.70	5.60	6.05	5.89	4.79	3.27	1.75	0.78	0.51	
	RadStd	0.07	0.14	0.26	0.28	0.40	0.47	0.38	0.40	0.27	0.21	0.07	0.04	

Historical Trends

		Heating		Cooling		Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD18.3
(46) Station Only	DBAvg	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(m)
(47) Regional (20 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page