

SACHS HARBOUR, NT, Canada

WMO: 714670

Lat: 71.992N

Lon: 125.243W

Elev: 287

StdP: 14.54

Time Zone: -7.00 (NAM)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-38.6	-35.3	-45.8	0.4	-38.1	-42.1	0.5	-34.8	35.7	-5.7	31.1	-7.6	9.2	0	1.128

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.6	60.8	53.1	56.9	50.9	53.4	48.6	53.8	59.7	51.2	56.2	48.7	53.0	12.0	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
50.2	54.4	56.6	47.8	49.6	54.1	45.5	45.4	51.1	22.6	59.8	21.1	56.6	19.7	53.2	72.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
30.9	27.4	24.3	DB	-42.5	65.0	4.5	5.2	-45.7	68.7	-48.3	71.8	-50.8	74.7	-54.1	78.5	
			WB	-42.4	56.8	4.5	3.9	-45.7	59.6	-48.3	61.9	-50.8	64.2	-54.0	67.0	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	10.7	-16.2	-17.0	-15.1	0.7	20.2	37.7	43.8	39.5	30.4	15.1	-1.1	-11.9		
	DBStd	24.33	10.26	10.25	11.51	10.63	9.56	7.10	7.99	6.99	7.21	9.21	9.99	10.21		
	HDD50	14412	2053	1876	2018	1480	923	375	231	335	587	1081	1534	1919		
	HDD65	19836	2518	2296	2483	1930	1388	820	658	792	1037	1546	1984	2384		
	CDD50	51	0	0	0	0	0	5	38	8	0	0	0	0		
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0		
	WSAvg	12.2	10.6	10.8	11.6	12.0	12.2	12.1	12.6	12.3	13.6	14.6	12.7	11.5		
	PrecAvg	5.3	0.1	0.2	0.2	0.2	0.4	0.4	0.7	1.1	0.8	0.7	0.3	0.2		
	PrecMax	8.3	0.5	0.9	0.7	0.7	1.8	1.0	1.7	1.9	1.8	2.0	1.1	0.6		
(15) Precipitation	PrecMin	1.9	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.1	0.2	0.2	0.0	0.0		
	PrecStd	1.3	0.1	0.2	0.2	0.2	0.4	0.3	0.4	0.5	0.5	0.5	0.2	0.2		
	DB	13.6	12.8	17.5	30.4	43.2	60.7	67.5	61.0	50.3	34.4	27.7	15.7			
	MCWB	13.0	12.1	17.2	29.1	39.1	52.9	56.4	54.4	47.8	33.5	26.7	14.8			
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	2% DB	6.9	7.5	10.5	24.5	39.1	55.5	63.2	56.2	46.0	31.9	21.9	11.1			
	2% MCWB	6.2	7.0	9.6	23.4	35.9	49.3	54.6	51.2	43.9	31.3	21.3	10.6			
	5% DB	2.6	2.7	5.4	20.2	35.5	51.7	59.7	52.8	42.6	29.5	17.0	7.3			
	5% MCWB	1.9	2.1	4.8	19.0	33.4	46.7	52.6	48.7	40.8	28.7	16.3	6.6			
	10% DB	-1.0	-1.9	1.5	15.9	32.5	48.4	56.2	49.7	39.9	27.3	13.2	3.3			
	10% MCWB	-1.7	-2.4	1.0	14.8	31.1	44.4	50.1	46.4	38.6	26.5	12.5	2.7			
	WB	13.0	12.1	17.0	29.5	39.6	53.9	59.0	54.9	48.1	33.9	26.7	15.3			
	MCDB	13.6	12.8	17.3	30.3	42.5	58.9	65.5	59.6	49.5	34.2	27.5	15.6			
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2% WB	6.1	6.9	10.0	23.7	36.1	50.3	55.3	51.4	44.1	31.5	21.5	10.7			
	2% MCDB	6.7	7.4	10.7	24.6	38.7	54.8	61.8	55.5	45.7	31.9	21.9	11.2			
	5% WB	1.9	2.2	5.0	19.1	33.5	47.0	52.9	49.2	41.1	28.8	16.6	6.7			
	5% MCDB	2.5	2.7	5.4	20.1	35.4	51.1	59.0	52.4	42.5	29.4	17.1	7.4			
	10% WB	-1.7	-2.4	1.1	14.9	31.2	44.4	50.3	46.8	38.8	26.6	12.8	2.9			
	10% MCDB	-1.1	-1.9	1.6	15.8	32.5	48.4	55.7	49.4	39.9	27.3	13.4	3.4			
	MDBR	11.0	11.4	11.8	12.0	9.7	9.4	10.6	9.1	7.4	9.2	11.0	10.9			
	5% DB	13.7	14.9	12.8	12.8	9.9	14.2	14.1	12.9	9.1	7.0	12.1	12.9			
(36) Mean Daily Temperature Range	5% MCWBR	13.8	14.8	12.7	12.3	8.5	10.9	9.5	9.3	7.4	6.9	12.1	12.9			
	5% WB	14.0	15.0	12.9	12.5	9.4	13.9	13.9	12.1	8.7	7.1	12.2	12.8			
	MCWBR	13.9	14.8	12.8	12.2	8.2	11.3	10.1	9.2	7.4	7.1	12.2	12.7			
	MCWBR	13.9	14.8	12.8	12.2	8.2	11.3	10.1	9.2	7.4	7.1	12.2	12.7			
(40) Clear-Sky Solar Irradiance	taub	N/A	0.176	0.234	0.299	0.320	0.322	0.334	0.324	0.286	0.194	N/A	N/A			
	taud	N/A	1.962	2.165	2.044	2.104	2.338	2.435	2.488	2.474	2.047	N/A	N/A			
	Ebn at Noon	0	154	240	254	266	272	265	253	226	137	0	0			
	Edh at Noon	0	10	21	35	38	32	28	23	16	8	0	0			
(44) All-Sky Solar Radiation	RadAvg	0	85	574	1377	1902	2041	1695	992	454	113	0	0			
	RadStd	0	8	28	64	193	193	175	131	46	22	0	0			

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+1.82	+2.81	+3.13	N/A	N/A	N/A	-745	-792	N/A	N/A
(47) Regional (0 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page