

SACHS HARBOUR, NT, Canada

WMO: 714670

Lat: 71.992N

Lon: 125.243W

Elev: 88

StdP: 100.28

Time Zone: -7.00 (NAM)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-39.2	-37.4	-43.2	0.1	-39.0	-41.2	0.1	-37.1	15.9	-21.0	13.9	-22.0	4.1	0	1.128

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.9	16.0	11.7	13.8	10.5	11.9	9.2	12.1	15.4	10.7	13.5	9.3	11.7	5.4	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
10.1	7.8	13.7	8.8	7.1	12.3	7.5	6.5	10.6	34.6	15.4	31.1	13.6	27.9	11.8	22.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.8	12.2	10.9	DB	-41.4	18.3	2.5	2.9	-43.2	20.4	-44.6	22.1	-46.0	23.7	-47.8	25.8	(4)
(5)			WB	-41.4	13.8	2.5	2.2	-43.1	15.4	-44.6	16.6	-46.0	17.9	-47.8	19.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	-11.9	-26.8	-27.2	-26.2	-17.4	-6.5	3.2	6.5	4.1	-0.9	-9.4	-18.4	-24.4	(6)	
	DBStd	13.52	5.70	5.69	6.40	5.91	5.31	3.94	4.44	3.89	4.00	5.11	5.55	5.67	(7)	
	HDD10.0	8007	1141	1042	1121	822	513	208	128	186	326	601	852	1066	(8)	
	HDD18.3	11020	1399	1276	1379	1072	771	456	366	440	576	859	1102	1324	(9)	
	CDD10.0	28	0	0	0	0	0	3	21	4	0	0	0	0	(10)	
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)	
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)	
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)	
(14) Wind	WSAvg	5.5	4.7	4.9	5.2	5.4	5.4	5.4	5.6	5.5	6.1	6.5	5.7	5.1	(14)	
(15) Precipitation	PrecAvg	134	3	5	4	5	11	9	17	29	21	19	8	5	(15)	
	PrecMax	211	12	24	18	18	46	26	44	48	46	50	28	14	(16)	
	PrecMin	48	0	0	0	0	0	0	2	2	4	4	1	0	(17)	
	PrecStd	34	3	6	4	5	11	7	11	13	13	13	6	4	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-10.2	-10.7	-8.1	-0.9	6.2	15.9	19.7	16.1	10.2	1.4	-2.4	-9.1	(19)	
		MCWB	-10.6	-11.1	-8.2	-1.6	3.9	11.6	13.6	12.4	8.8	0.9	-3.0	-9.6	(20)	
	2%	DB	-13.9	-13.6	-12.0	-4.2	3.9	13.0	17.4	13.4	7.8	0.0	-5.6	-11.6	(21)	
		MCWB	-14.3	-13.9	-12.5	-4.8	2.2	9.6	12.5	10.7	6.6	-0.4	-6.0	-11.9	(22)	
	5%	DB	-16.3	-16.3	-14.8	-6.6	1.9	10.9	15.4	11.6	5.9	-1.4	-8.3	-13.7	(23)	
		MCWB	-16.7	-16.6	-15.1	-7.2	0.8	8.2	11.4	9.3	4.9	-1.8	-8.7	-14.1	(24)	
	10%	DB	-18.3	-18.8	-16.9	-8.9	0.3	9.1	13.5	9.8	4.4	-2.6	-10.5	-15.9	(25)	
		MCWB	-18.7	-19.1	-17.2	-9.5	-0.5	6.9	10.1	8.0	3.7	-3.0	-10.8	-16.3	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-10.5	-11.1	-8.4	-1.4	4.2	12.2	15.0	12.7	8.9	1.0	-2.9	-9.3	(27)	
		MCDB	-10.2	-10.7	-8.2	-0.9	5.9	15.0	18.6	15.3	9.7	1.2	-2.5	-9.1	(28)	
	2%	WB	-14.4	-13.9	-12.2	-4.6	2.3	10.2	12.9	10.8	6.7	-0.3	-5.8	-11.8	(29)	
		MCDB	-14.1	-13.7	-11.8	-4.1	3.7	12.7	16.6	13.1	7.6	0.0	-5.6	-11.6	(30)	
	5%	WB	-16.7	-16.5	-15.0	-7.2	0.8	8.4	11.6	9.6	5.1	-1.8	-8.6	-14.0	(31)	
		MCDB	-16.4	-16.3	-14.8	-6.6	1.9	10.6	15.0	11.3	5.9	-1.4	-8.3	-13.6	(32)	
	10%	WB	-18.7	-19.1	-17.2	-9.5	-0.4	6.9	10.2	8.2	3.8	-3.0	-10.7	-16.2	(33)	
		MCDB	-18.4	-18.9	-16.9	-9.0	0.3	9.1	13.2	9.7	4.4	-2.6	-10.3	-15.9	(34)	
(35) Mean Daily Temperature Range	MDBR		6.1	6.3	6.6	6.7	5.4	5.2	5.9	5.1	4.1	5.1	6.1	6.1	(35)	
	5% DB	MCDBR	7.6	8.3	7.1	7.1	5.5	7.9	7.9	7.2	5.0	3.9	6.7	7.2	(36)	
		MCWBR	7.7	8.2	7.1	6.9	4.7	6.0	5.3	5.1	4.1	3.8	6.7	7.2	(37)	
	5% WB	MCDBR	7.8	8.3	7.2	6.9	5.2	7.7	7.7	6.7	4.8	4.0	6.8	7.1	(38)	
		MCWBR	7.7	8.2	7.1	6.8	4.5	6.3	5.6	5.1	4.1	4.0	6.8	7.1	(39)	
(40) Clear-Sky Solar Irradiance	taub		N/A	0.176	0.234	0.299	0.320	0.322	0.334	0.324	0.286	0.194	N/A	N/A	(40)	
	taud		N/A	1.962	2.165	2.044	2.104	2.338	2.435	2.488	2.474	2.047	N/A	N/A	(41)	
	Ebn at Noon		0	486	758	802	839	859	835	797	713	432	0	0	(42)	
	Edh at Noon		0	31	66	111	121	100	88	73	52	26	0	0	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.00	0.27	1.81	4.34	6.00	6.43	5.34	3.13	1.43	0.36	0.00	0.00	(44)	
	RadStd		0.00	0.03	0.09	0.20	0.61	0.61	0.55	0.41	0.14	0.07	0.00	0.00	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		+1.01	+1.56	+1.74	N/A	N/A	N/A	-414	-440	N/A	N/A	
(47) Regional (0 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page